

Asbestos Register

(Hazardous Materials and Risk Assessment)

School:	Hillston Central School (2165)
Region:	Southern NSW AMU
State Electorate:	Murray
Local Government Area:	Carrathool

Last Reviewed By:	WSP 14-FEB-2017
Last Revised By:	

Historical Fibro In Grounds Investigations/Events	No
No previous investigations have been recorded against the school. However, asbestos containing materials maybe present in grounds from time to time and caution must be exercised prior to any grounds disturbance.	



Preface to Asbestos Register

Limitations

Asbestos Registers established (first surveyed 2007/08) and maintained for the Department of Education (DoE) are limited in extent, in that:

1. All inspections and surveys of materials and finishes in DoE facilities are non-disturbance, with
2. Samples undertaken by hygienist to determine whether a sample is an Asbestos Containing Material (ACM),
3. The hygienist may apply a single sample to like materials within a space and adjoining spaces, but not normally between buildings,
4. Successive inspections have reduced any inconclusive records such as 'assumed asbestos' in difficult to access areas, by undertaking additional sampling with lifting devices.
5. In compliance with WHS Act 2011 and WHS Regulations 2017, additional inspections have been undertaken in ceiling spaces and sub-floor areas where access is possible.
 - o Where the ground floor is slab on ground, no inspection is made beneath the slab.
 - o Where fibro fragments (ACM taken for sampling) are located in ceiling spaces or sub floor voids air monitoring is normally undertaken at time of sampling, and clearance undertaken as soon as practicable.
6. No attempt has been made to identify any ACM that is hidden from view or encapsulated within
 - o Any wall cavity
 - o Sub floor area, particularly formwork for slabs in/on ground,
 - o Services (that may use ACM) such as: pipe lagging, asbestos cement pipes, flues.
7. All known ACM in Grounds (Fibro in Grounds) is made available in associated site specific asbestos management plans in DoE electronic files.
Notwithstanding information provided, ACM may be present in grounds from time to time and caution must be exercised prior to any grounds disturbance.

Use of the Asbestos Register

Prior to any disturbance works being undertaken in a building to which this asbestos register applies it will be necessary to confirm the extent of any ACM by a disturbance investigation:

- If the building was built prior to 2003
- If any ACM has been identified in the Asbestos Register for the building.

Update of Asbestos Registers

Asbestos Register Data is updated regularly by the DoE Hygienist Panel via the Online Asbestos Register Tool (Managed by Business Systems, School Infrastructure NSW). Internal users can view the latest edition of the Asbestos Register in the AMS.

Please note: The Department's external website may not contain the latest revision of the Asbestos Register.

Notes 1: Vermiculite

- During 2018/19, all vermiculite occurrences in DoE schools identified in 2007/08, were 'composite tested' in accordance with a safe work NSW agreed procedure. This required multiple testing of all vermiculite occurrences.
- During the period 2007/08 to 2018/19, some vermiculite has been over sheeted and a warning is indicated for schools where this has happened.

Note 2: DoE website link for information is here:

<https://www.schoolinfrastructure.nsw.gov.au/about-us/working-with-us/schools-asbestos-register.html>

<https://education.nsw.gov.au/about-us/strategies-and-reports/our-reports-and-reviews/schools-asbestos-register>

Note 3: Material Condition Assessment

The material condition assessment descriptors from Section 3 of the Asbestos Management Plan (AMP) is extracted below. Please read the AMP in its entirety for further information.

3.3.2.1 Material condition assessment

The OART records the material condition of identified ACM in the following format:

Rating	Description
Good condition (1)	For non-friable asbestos that is sealed and has no visible damage. This primarily related to asbestos cement (AC) sheet and vinyl tiles
Minimal damage (2)	For non-friable asbestos that has a very small amount of damage, eg hairline cracks.
Some damage / unsealed (3)	For non-friable asbestos with significant breakage or several small areas where material has been damaged, revealing loose asbestos fibres. Non-friable asbestos that is unsealed.
Poor condition (4)	For non-friable asbestos that has extensive damage. Visible asbestos debris
Friable asbestos (5)	Any occurrence of friable asbestos

Product	Material Description	Extent	Location	Material Condition	Risk Status	Remediation Priority	Result
B00A - Administration - 1975 - Brick/Block							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Interior							
B00A - R0001 - Staff Room Annexe - 27.22 m2							
No Asbestos							
B00A - R0002 - Movement - 28.48 m2							
Ceiling Structures/Linings	Flat AC Sheeting	29m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00A - R0003 - Staff Room Annexe - 15.01 m2							
No Asbestos							
B00A - R0004 - Principal - 21.05 m2							
No Asbestos							
B00A - R0005 - Movement - 46.79 m2							
Ceiling Structures/Linings	Flat AC Sheeting	47m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00A - R0008 - Deputy Principal - 16.98 m2							
No Asbestos							
B00A - R0009 - General Storeroom - .53 m2							
No Asbestos							
B00A - R0011 - Clerical Office - 28.09 m2							
No Asbestos							
B00A - R0012 - Duplicating Workroom - 11.67 m2							
No Asbestos							
B00A - R0013 - Staff Toilet - 2.17 m2							
Plant / Equipment - Incinerator	Encapsulated Asbestos material within unit	1	North facing	Friable Asbestos (5)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00A - R0014 - Staff Shower/Change - 5.75 m2							
No Asbestos							
B00A - R0016 - Movement - 18.51 m2							
No Asbestos							
B00A - R0017 - Cleaning Supplies - 2.54 m2							
Floor Coverings Res/Textile	Vinyl Tiles	3m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B00A - R0018 - Sick Bay - 7.17 m2							
Floor Coverings Res/Textile	Vinyl Tiles	8m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B00A - R0019 - General Storeroom - 8.48 m2							
No Asbestos							
B00A - R0020 - Main Switch Board - 2.62 m2							
Electrical - Mounting Board	Resinous Board	2	North facing, South facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00A - R0021 - Staff Room - 55.16 m2							
No Asbestos							
B00A - R0022 - Entry Vestibule - 32.23 m2							
No Asbestos							
B00A - R0023 - Movement - 4.73 m2							
No Asbestos							
B00A - R0024 - Toilet - Lobby - 3.13 m2							

No Asbestos							
B00A - R0025 - Staff Toilet - 1.36 m2							
No Asbestos							
B00B - Library/Pupil Facilities - 1975 - Brick/Block							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Interior							
B00B - R0001 - Movement - 99.92 m2							
Ceiling Structures/Linings	Flat AC Sheeting	100m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0002 - Home Base - 75.3 m2							
No Asbestos							
B00B - R0003 - Movement - 30.96 m2							
Ceiling Structures/Linings	Flat AC Sheeting	31m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0004 - Home Base - 75.5 m2							
No Asbestos							
B00B - R0005 - Special Programs Room - 37.05 m2							
Door - Infill	Flat AC Sheeting						
B00B - R0006 - General Storeroom - 10.15 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	To entrance	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0007 - Darkroom Space - 7.75 m2							
No Asbestos							
B00B - R0008 - Distribution Board - .52 m2							
							Note: No inspection of live electrical installation
No Asbestos							
B00B - R0009 - Kiln Room - 6.5 m2							
Ceiling Structures/Linings	Flat AC Sheeting	7m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0010 - Art Learning Space - 75.69 m2							
No Asbestos							
B00B - R0011 - Communications Room - 12.6 m2							
Ceiling Structures/Linings	Flat AC Sheeting	1m2	To exhaust fan	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0012 - Seminar/Study - 15.01 m2							
No Asbestos							
B00B - R0013 - Library Office/Workroom - 10.61 m2							
No Asbestos							
B00B - R0014 - Library Office/Workroom - 12.36 m2							
No Asbestos							
B00B - R0015 - Reading Area - 110.66 m2							
No Asbestos							
B00B - R0016 - Movement - 25.64 m2							
Ceiling Structures/Linings	Flat AC Sheeting	26m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0017 - Reading Area - 94.39 m2							
No Asbestos							
B00B - R0018 - General Storeroom - 3.76 m2							
Ceiling Structures/Linings	Flat AC Sheeting	4m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00B - R0019 - Covered Area - 84.46 m2							

Requires Inspection							
B00C - Technological & Applied Studies - 1985 - Brick/Veneer							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Interior							
B00C - R0002 - External Movement - 42.28 m2							
Ceiling Structures/Linings	Flat AC Sheeting	43m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00C - R0007 - General Storeroom - 11.72 m2							
Ceiling Structures/Linings	Flat AC Sheeting	12m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00C - R0008 - External Movement - 22.89 m2							
Ceiling Structures/Linings	Flat AC Sheeting	23m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00C - R0014 - Food Technology L.S. - 96.75 m2							
Requires Inspection							
B00C - R0015 - Seminar/Technology Space - 41.34 m2							
Requires Inspection							
B00C - R0016 - Lecture Store - 6.57 m2							
Requires Inspection							
B00C - R0017 - Food/Research Space - 18.14 m2							
Requires Inspection							
B00C - R0018 - Pantry - 7.08 m2							
Requires Inspection							
B00D - Pupil Facilities - 1975 - Brick/Block							
Exterior							
Plant / Equipment - Flue	Fibre Cement Pipe	1	East facing	Some Damage - Unsealed (3)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Ceiling Voids - Flat Roof	No Asbestos Found						
Underfloor Voids - Slab on Ground	No Asbestos Found						
Interior							
B00D - R0001 - Shower/Change - 29.94 m2							
Ceiling Structures/Linings	Flat AC Sheeting	30m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	30m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Partition Walls (Cubicles)	Compressed AC Sheet	6m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00D - R0002 - Shower/Change - 30.19 m2							
Ceiling Structures/Linings	Flat AC Sheeting	31m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	30m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Partition Walls (Cubicles)	Compressed AC Sheet	6m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00D - R0003 - Toilets - Girls - 38.73 m2							
Wall Linings Internal	Flat AC Sheeting	40m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Partition Walls (Cubicles)	Compressed AC Sheet	8m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos

Ceiling Structures/Linings	Flat AC Sheeting	39m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00D - R0004 - Toilets - Boys - 41.38 m2							
Ceiling Structures/Linings	Flat AC Sheeting	42m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	30m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Partition Walls (Cubicles)	Compressed AC Sheet	6m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00D - R0005 - Movement - 22.18 m2							
Ceiling Structures/Linings	Flat AC Sheeting	23m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00D - R0007 - Sports Store - 6.32 m2							
No Asbestos							
B00D - R0008 - Sports Store - 13.1 m2							
No Asbestos							
B00E - General Learning - 1925 - Timber							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Eaves Linings	Flat AC Sheeting	10m2	North facing, South facing, East facing, West facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Interior							
B00E - R0001 - Home Base - 53.6 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00E - R0002 - Home Base Store - 11.28 m2							
No Asbestos							
B00E - R0003 - Withdrawal Space - 1hb - 10.96 m2							
No Asbestos							
B00E - R0004 - Movement - 23.82 m2							
Ceiling Structures/Linings	Flat AC Sheeting	24m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	2m2	South facing, Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00F - Pupil Facilities - 1981 - Brick/Block							
Exterior							
Underfloor Voids	No Asbestos Found						
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Interior							
B00F - R0001 - Canteen - 22.93 m2							
Ceiling Structures/Linings	Flat AC Sheeting	2m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Floor Coverings Res/Textile	Vinyl Tiles	2m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B00F - R0002 - General Storeroom - 1.96 m2							
Ceiling Structures/Linings	Flat AC Sheeting	2m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00F - R0003 - Staff Toilet - 2.3 m2							
Ceiling Structures/Linings	Flat AC Sheeting	3m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos

Plant / Equipment - Incinerator	Encapsulated Asbestos material within unit	1	All surfaces	Friable Asbestos (5)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00F - R0004 - General Storeroom - 3.08 m2							
Ceiling Structures/Linings	Flat AC Sheeting	4m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00F - R0005 - External Movement - 19.97 m2							
No Asbestos							
B00G - Pupil Facilities - 1969 - Brick/Block							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Interior							
B00G - R0001 - Disabled Toilet - 6.63 m2							
Wall Linings Internal	Flat AC Sheeting	15m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Ceiling Structures/Linings	Flat AC Sheeting	7m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00G - R0002 - Sports Store - 29.11 m2							
Ceiling Structures/Linings	Flat AC Sheeting	30m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00G - R0003 - Movement - 28.07 m2							
Ceiling Structures/Linings	Flat AC Sheeting	29m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00G - R0004 - Garden Store - 13.01 m2							
Ceiling Structures/Linings	Flat AC Sheeting	13m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00G - R0005 - General Storeroom - 13.16 m2							
Wall Linings Internal	Flat AC Sheeting	10m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Ceiling Structures/Linings	Flat AC Sheeting	14m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00G - R0006 - Toilets - Girls - 43.77 m2							
Ceiling Structures/Linings	Flat AC Sheeting	44m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	40m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Partition Walls (Cubicles)	Compressed AC Sheet	10m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00G - R0007 - Toilets - Boys - 53.75 m2							
Ceiling Structures/Linings	Flat AC Sheeting	54m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	40m2	Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Partition Walls (Cubicles)	Compressed AC Sheet	5m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00H - Music - 1920 - Timber							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Eaves Linings	Flat AC Sheeting	10m2	North facing, South facing, East facing, West facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Electrical - Mounting Board	Resinous Board	1	East facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos

Interior							
B00H - R0001 - Movement - 4.92 m2							
Wall Linings Internal	Flat AC Sheeting						
B00H - R0002 - Music Learning Space - 47.32 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00H - R0003 - Music Store - 14.99 m2							
Wall Linings Internal	Flat AC Sheeting						
B00I - General Learning - 1936 - Timber							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Eaves Linings	Flat AC Sheeting	6m2	North facing, South facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Interior							
B00I - R0001 - Movement - 31.3 m2							
Ceiling Structures/Linings	Flat AC Sheeting	32m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	2m2	West facing, Upper portion	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00I - R0002 - Home Base - 53.77 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00I - R0003 - Home Base - 53.84 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00J - General Learning - 1925 - Timber							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	Requires Inspection						
Eaves Linings	Flat AC Sheeting	40m2	North facing, South facing, East facing, West facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Underfloor Voids - Stored / Debris Material	AC Fragments/Debris	50	Throughout	Minimal Damage (2)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos) , Amosite (brown asbestos) , Crocidolite (blue asbestos)
Underfloor Voids - Stored / Debris Material	AC Fragments/Debris	50	Throughout	Minimal Damage (2)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos) , Amosite (brown asbestos)
Interior							
B00J - R0001 - General Storeroom - 10.25 m2							
No Asbestos							
B00J - R0002 - Staff Room Annexe - 15.61 m2							
No Asbestos							
B00J - R0003 - Computer Learning Space - 48.27 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00J - R0004 - General Learning Space - 46.13 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00J - R0005 - General Learning Space - 45.61 m2							
Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00J - R0006 - General Learning Space - 46.33 m2							

Wall Linings Internal	Flat AC Sheeting	2m2	Behind heater	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00J - R0007 - General Storeroom - 3.76 m2							
Floor Coverings Res/Textile	Vinyl Tiles	4m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B00J - R0008 - Staff Room Annexe - 18.16 m2							
Floor Coverings Res/Textile	Vinyl Tiles	19m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B00J - R0009 - Movement - 62.31 m2							
No Asbestos							
B00J - R0010 - General Storeroom - 3.14 m2							
No Asbestos							
B00K - Science - 1975 - Brick/Veneer							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Eaves Linings	Flat AC Sheeting	40m2	North facing, South facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Interior							
B00K - R0001 - Movement - 31.42 m2							
Ceiling Structures/Linings	Flat AC Sheeting	32m2	All surfaces	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00K - R0002 - Laboratory L.S. - 52.37 m2							
No Asbestos							
B00K - R0003 - Staff Study - 25.86 m2							
No Asbestos							
B00K - R0004 - Apparatus Store - 21.18 m2							
No Asbestos							
B00K - R0005 - General Storeroom - 2.88 m2							
Electrical - Mounting Board	Resinous Board	1	East facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00K - R0006 - Cleaning Supplies - 3.04 m2							
No Asbestos							
B00K - R0009 - Laboratory L.S. - 87.45 m2							
No Asbestos							
B00K - R0010 - Chemical Store - 4.14 m2							
No Asbestos							
B00K - R0011 - Preparation - 28.03 m2							
No Asbestos							
B00L - Shed - 1970 - Metal Shed							
Exterior							
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Interior							
B00L - R0001 - General Storeroom - 53.01 m2							
No Asbestos							
B00M - Shed - 1975 - Brick/Block							
Exterior							
Ceiling Voids - Flat Roof	No Asbestos Found						

Underfloor Voids - Slab on Ground	No Asbestos Found						
Interior							
B00M - R0001 - General Storeroom - 25.83 m2							
No Asbestos							
B00N - Shed - 1982 - Brick/Block							
Exterior							
Ceiling Voids - Flat Roof	No Asbestos Found						
Underfloor Voids - Slab on Ground	No Asbestos Found						
Eaves Linings	Flat AC Sheeting	6m2	North facing, South facing, East facing, West facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Electrical - Mounting Board	Resinous Board	1	West facing	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Interior							
B00N - R0001 - General Storeroom - 13.61 m2							
Ceiling Structures/Linings	Flat AC Sheeting	14m2	All surfaces	Some Damage - Unsealed (3)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B00N - R0003 - Toilets-Unisex - 4.6 m2							
No Asbestos							
B00O - Technological & Applied Studies - 2002 - Steel							
Exterior							
Ceiling Voids	No Asbestos Found						
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Underfloor Voids - Slab on Ground	No Asbestos Found						
Interior							
B00O - R0001 - Welding Area - 31.23 m2							
No Asbestos							
B00O - R0002 - External Movement - 8.55 m2							
No Asbestos							
B00P - Building Services - 2008 - Metal Shed							
Exterior							
Underfloor Voids - Slab on Ground	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Interior							
B00P - R0001 - Garden Store - 7.54 m2							
No Asbestos							
B00Q - Science Learning - 2010 - Brick/Veneer							
Exterior							
Underfloor Voids - Slab on Ground	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Ceiling Voids - Raked Ceiling	No Asbestos Found						
Interior							
B00Q - R0001 - General Learning Space - 59.94 m2							

No Asbestos		
B00Q - R0002 - Science Laboratory - 59.89 m2		
No Asbestos		
B00Q - R0003 - Preparation - 30.31 m2		
No Asbestos		
B00Q - R0004 - Staff Room - 20.93 m2		
No Asbestos		
B00Q - R0005 - Seminar - Type 2 - 21.11 m2		
No Asbestos		
B00Q - R0006 - Chemical Store - 12.13 m2		
No Asbestos		
B00Q - R0007 - Movement - 6.15 m2		
No Asbestos		
B00Q - R0008 - Apparatus Storage - 13.74 m2		
No Asbestos		
B00Q - R0009 - Main Switch Board - .47 m2		
No Asbestos		
B00Q - R0010 - Outdoor Learning Space - Type 4 - 84.31 m2		
No Asbestos		
B00R - Technological & Applied Studies - 2010 - Steel		
Exterior		
Underfloor Voids - Slab on Ground	No Asbestos Found	
Ceiling Voids	No Asbestos Found	
Ceiling Voids - Raked Ceiling	No Asbestos Found	
Interior		
B00R - R0001 - Covered Outdoor Learning Area - 42.56 m2		
No Asbestos		
B00R - R0002 - Covered Outdoor Learning Area - 41.95 m2		
No Asbestos		
B00R - R0003 - Metal Technology Bay - 12.12 m2		
No Asbestos		
B00R - R0004 - Materials Technology L.S. - 127.14 m2		
No Asbestos		
B00R - R0005 - Welding Area - 9.08 m2		
No Asbestos		
B00R - R0006 - Welding Area - 3.91 m2		
No Asbestos		
B00R - R0007 - Welding Area - 3.91 m2		
No Asbestos		
B00R - R0008 - Main Switch Board - 10.83 m2		
No Asbestos		
B00R - R0009 - Wood Technology Bay - 41.27 m2		
No Asbestos		
B00R - R0010 - External Movement - 90.09 m2		
No Asbestos		
B00S - Multi Purpose Facilities - 2011 - Brick/Veneer		
Exterior		
Underfloor Voids - Slab on Ground	No Asbestos Found	

Ceiling Voids	No Asbestos Found						
Ceiling Voids - Flat Roof	No Asbestos Found						
Interior							
B00S - R0001 - Communal Space - 792.34 m2							
No Asbestos							
B00T - Building Services - 2010 - Steel							
Exterior							
Ceiling Voids	No Asbestos Found						
Ceiling Voids - Flat Roof	No Asbestos Found						
Underfloor Voids - Slab on Ground	No Asbestos Found						
Interior							
B00T - R0001 - General Storeroom - 137.91 m2							
No Asbestos							
B00T - R0002 - Covered Area - 45.67 m2							
No Asbestos							
B00U - Technological & Applied Studies - 2015 - Steel							
Exterior							
Underfloor Voids	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Interior							
B00U - R0001 - External Movement - 12.32 m2							
No Asbestos							
B00U - R0002 - Computer Room - 45.67 m2							
No Asbestos							
B00U - R0003 - Computer Store - 17.07 m2							
No Asbestos							
B00V - Storage - 2010 - Metal Shed							
Exterior							
Underfloor Voids	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Interior							
B00V - R0001 - Other-Community Use - 53.89 m2							
No Asbestos							
B00V - R0002 - Materials Store - 27.29 m2							
No Asbestos							
B00W - Residential Facilities - 1960 - Timber							
Exterior							
Underfloor Voids	Requires Inspection						
Ceiling Voids	Requires Inspection						
Interior							
B00W - R0001 - Residence - Movement - 50.09 m2							
Requires Inspection							
B00W - R0002 - Residence - Kitchen - 27.33 m2							

Requires Inspection							
B00W - R0003 - Residence - Laundry - 6.07 m2							
Requires Inspection							
B00W - R0004 - Residence - Toilet - 1.33 m2							
Requires Inspection							
B00W - R0005 - Residence - Movement - 3.42 m2							
Requires Inspection							
B00W - R0006 - Residence - Toilet - 1.97 m2							
Requires Inspection							
B00W - R0007 - Residence - Bathroom - 6.24 m2							
Requires Inspection							
B00W - R0008 - Residence - Living - 19.69 m2							
Requires Inspection							
B00W - R0009 - Residence - Bedroom - 10.9 m2							
Requires Inspection							
B00W - R0010 - Residence - Movement - 16.46 m2							
Requires Inspection							
B00W - R0011 - Residence - Bedroom - 15.36 m2							
Requires Inspection							
B00W - R0012 - Residence - Movement - 4.43 m2							
Requires Inspection							
B00W - R0013 - Residence - Bedroom - 15.53 m2							
Requires Inspection							
B00W - R0014 - Residence - Bedroom - 15.88 m2							
Requires Inspection							
B0W1 - Residential Facilities - 2005 - Metal Shed							
Exterior							
Underfloor Voids	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Underfloor Voids	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Interior							
B0W1 - R0001 - Residence - Garage - 34.83 m2							
No Asbestos							

Demountables**OS 751 12074 - Learning Unit - ESL - Placement Date : 12-JAN-2006****Exterior**

Eaves Linings	Flat AC Sheeting	11.52m2	Assumed Asbestos
Landing	Compressed AC Sheet	1.2m2	Assumed Asbestos
Step Treads	Compressed AC Sheet	1.08m2	Assumed Asbestos

Interior**R1- Esl**

End Wall Panel	Flat AC Sheeting	18m2	Assumed Asbestos
Ceiling Structures/Linings	Flat AC Sheeting	36m2	Assumed Asbestos

R2- Esl

End Wall Panel	Flat AC Sheeting	18m2	Assumed Asbestos
Ceiling Structures/Linings	Flat AC Sheeting	36m2	Assumed Asbestos

OS 520 13288 - Staff Study - Placement Date : 02-JAN-2007**Exterior**

Eaves Linings	Flat AC Sheeting	8.64m2	Assumed Asbestos
Landing	Compressed AC Sheet	1.2m2	Assumed Asbestos
Step Treads	Compressed AC Sheet	1.08m2	Assumed Asbestos

Interior**R1- Staff Room**

End Wall Panel	Flat AC Sheeting	50m2	Assumed Asbestos
Ceiling Structures/Linings	Flat AC Sheeting	55m2	Assumed Asbestos