


Asbestos Register

(Hazardous Materials and Risk Assessment)

School:	Kelso Public School (2275)
Region:	North Western NSW AMU
State Electorate:	Bathurst
Local Government Area:	Bathurst

Last Reviewed By:	Greencap 17-APR-2015
Last Revised By:	

Historical Fibro In Grounds Investigations/Events	Yes
Please refer to the latest site specific Asbestos Management Plans available from the Department's website (Refer to Note 2).	



Preface to Asbestos Register

Limitations

Asbestos Registers established (first surveyed 2007/08) and maintained for the Department of Education (DoE) are limited in extent, in that:

1. All inspections and surveys of materials and finishes in DoE facilities are non-disturbance, with
2. Samples undertaken by hygienist to determine whether a sample is an Asbestos Containing Material (ACM),
3. The hygienist may apply a single sample to like materials within a space and adjoining spaces, but not normally between buildings,
4. Successive inspections have reduced any inconclusive records such as 'assumed asbestos' in difficult to access areas, by undertaking additional sampling with lifting devices.
5. In compliance with WHS Act 2011 and WHS Regulations 2017, additional inspections have been undertaken in ceiling spaces and sub-floor areas where access is possible.
 - o Where the ground floor is slab on ground, no inspection is made beneath the slab.
 - o Where fibro fragments (ACM taken for sampling) are located in ceiling spaces or sub floor voids air monitoring is normally undertaken at time of sampling, and clearance undertaken as soon as practicable.
6. No attempt has been made to identify any ACM that is hidden from view or encapsulated within
 - o Any wall cavity
 - o Sub floor area, particularly formwork for slabs in/on ground,
 - o Services (that may use ACM) such as: pipe lagging, asbestos cement pipes, flues.
7. All known ACM in Grounds (Fibro in Grounds) is made available in associated site specific asbestos management plans in DoE electronic files.
Notwithstanding information provided, ACM may be present in grounds from time to time and caution must be exercised prior to any grounds disturbance.

Use of the Asbestos Register

Prior to any disturbance works being undertaken in a building to which this asbestos register applies it will be necessary to confirm the extent of any ACM by a disturbance investigation:

- If the building was built prior to 2003
- If any ACM has been identified in the Asbestos Register for the building.

Update of Asbestos Registers

Asbestos Register Data is updated regularly by the DoE Hygienist Panel via the Online Asbestos Register Tool (Managed by Business Systems, School Infrastructure NSW). Internal users can view the latest edition of the Asbestos Register in the AMS.

Please note: The Department's external website may not contain the latest revision of the Asbestos Register.

Notes 1: Vermiculite

- During 2018/19, all vermiculite occurrences in DoE schools identified in 2007/08, were 'composite tested' in accordance with a safe work NSW agreed procedure. This required multiple testing of all vermiculite occurrences.
- During the period 2007/08 to 2018/19, some vermiculite has been over sheeted and a warning is indicated for schools where this has happened.

Note 2: DoE website link for information is here:

<https://www.schoolinfrastructure.nsw.gov.au/about-us/working-with-us/schools-asbestos-register.html>

<https://education.nsw.gov.au/about-us/strategies-and-reports/our-reports-and-reviews/schools-asbestos-register>

Note 3: Material Condition Assessment

The material condition assessment descriptors from Section 3 of the Asbestos Management Plan (AMP) is extracted below. Please read the AMP in its entirety for further information.

3.3.2.1 Material condition assessment

The OART records the material condition of identified ACM in the following format:

Rating	Description
Good condition (1)	For non-friable asbestos that is sealed and has no visible damage. This primarily related to asbestos cement (AC) sheet and vinyl tiles
Minimal damage (2)	For non-friable asbestos that has a very small amount of damage, eg hairline cracks.
Some damage / unsealed (3)	For non-friable asbestos with significant breakage or several small areas where material has been damaged, revealing loose asbestos fibres. Non-friable asbestos that is unsealed.
Poor condition (4)	For non-friable asbestos that has extensive damage. Visible asbestos debris
Friable asbestos (5)	Any occurrence of friable asbestos

Product	Material Description	Extent	Location	Material Condition	Risk Status	Remediation Priority	Result
B001 - General Learning/Administration - 1979 - Brick/Block							
Exterior							
Ceiling Voids	No Asbestos Found						
Underfloor Voids - Slab on Ground	Non Accessible Area						
Interior							
B001 - R0001 - Main Switch Board - 9.04 m2							
Electrical - Mounting Board	Resinous Board	1	West	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
Wall Linings Internal	Flat AC Sheeting	18m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0002 - Movement - 11.02 m2							
No Asbestos							
B001 - R0003 - Staff Toilet - 3.63 m2							
Wall Linings Internal	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0004 - Staff Toilet - 3.65 m2							
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	West	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Wall Linings Internal	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0005 - Cleaning Distributed Store - 3.58 m2							
Wall Linings Internal	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0006 - Library Office/Workroom - 8.22 m2							
No Asbestos							
B001 - R0007 - Reading Area - 269.35 m2							
No Asbestos							
B001 - R0008 - K.L.A. Store - 14.4 m2							
No Asbestos							
B001 - R0009 - Library Office/Workroom - 19.89 m2							
No Asbestos							
B001 - R0010 - Seminar/Study - 13.06 m2							
No Asbestos							
B001 - R0011 - Seminar/Study - 20.55 m2							
No Asbestos							
B001 - R0012 - Movement - 25.13 m2							
No Asbestos							
B001 - R0013 - Movement - 24.46 m2							
No Asbestos							
B001 - R0014 - Movement - 25.3 m2							
No Asbestos							
B001 - R0015 - Movement - 46.05 m2							
No Asbestos							
B001 - R0016 - Special Programs Room - 31.02 m2							
Non Accessible							
B001 - R0017 - Cleaning Distributed Store - 4.35 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0018 - Home Base Store - 7.39 m2							

No Asbestos							
B001 - R0019 - Movement - 24.67 m2							
No Asbestos							
B001 - R0020 - Home Base - 61.22 m2							
No Asbestos							
B001 - R0021 - Withdrawal Space - 1hb - 12.07 m2							
No Asbestos							
B001 - R0022 - Home Base - 61.17 m2							
No Asbestos							
B001 - R0023 - Movement - 24.64 m2							
No Asbestos							
B001 - R0024 - Home Base Store - 5.76 m2							
No Asbestos							
B001 - R0025 - Home Base Store - 4.68 m2							
No Asbestos							
B001 - R0026 - Distribution Board - .71 m2							
							Note: No inspection of live electrical installation
No Asbestos							
B001 - R0027 - Movement - 5.71 m2							
No Asbestos							
B001 - R0028 - Practical Activities - 1hb - 49.46 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0029 - Toilets - Girls - 4.85 m2							
Wall Linings Internal	Flat AC Sheeting	12m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	7m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0030 - Personal Effects Storage - 9.04 m2							
No Asbestos							
B001 - R0031 - Staff Room Annexe - 15.2 m2							
No Asbestos							
B001 - R0032 - Movement - 39.99 m2							
No Asbestos							
B001 - R0033 - Home Base - 62.78 m2							
No Asbestos							
B001 - R0034 - Movement - 31.91 m2							
No Asbestos							
B001 - R0035 - Withdrawal Space - 1hb - 12.07 m2							
No Asbestos							
B001 - R0036 - Movement - 17.46 m2							
No Asbestos							
B001 - R0037 - Practical Activities - 1hb - 50.82 m2							
No Asbestos							
B001 - R0038 - Personal Effects Storage - 4.83 m2							
No Asbestos							
B001 - R0039 - Staff Toilet - 4.18 m2							
Wall Linings Internal	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0040 - Toilets - Boys - 9.76 m2							
Wall Linings Internal	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)

Partition Walls (Cubicles)	Compressed AC Sheet	7m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0041 - Movement - 62.89 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0042 - Home Base - 61.24 m2							
No Asbestos							
B001 - R0043 - Movement - 5.8 m2							
No Asbestos							
B001 - R0044 - Home Base Store - 5.85 m2							
No Asbestos							
B001 - R0045 - Home Base Store - 5.86 m2							
No Asbestos							
B001 - R0046 - Movement - 24.74 m2							
No Asbestos							
B001 - R0047 - Home Base - 61.24 m2							
No Asbestos							
B001 - R0048 - Withdrawal Space - 1hb - 12.01 m2							
No Asbestos							
B001 - R0049 - Movement - 17.92 m2							
No Asbestos							
B001 - R0050 - Home Base - 61.33 m2							
No Asbestos							
B001 - R0051 - Home Base Store - 4.35 m2							
No Asbestos							
B001 - R0052 - Movement - 8.98 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0053 - Practical Activities - 1hb - 49.47 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0054 - Personal Effects Storage - 4.87 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0055 - Toilets - Boys - 9.06 m2							
Wall Linings Internal	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B001 - R0056 - Movement - 3.93 m2							
No Asbestos							
B001 - R0057 - Distribution Board - .58 m2							
Note: No inspection of live electrical installation							
No Asbestos							
B001 - R0058 - Movement - 10.45 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0059 - Cleaning Distributed Store - 4.33 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0060 - Home Base Store - 7.36 m2							
No Asbestos							
B001 - R0061 - Home Base - 62.78 m2							

No Asbestos							
B001 - R0062 - Withdrawal Space - 1hb - 12.04 m2							
No Asbestos							
B001 - R0063 - Home Base - 61.19 m2							
No Asbestos							
B001 - R0064 - Movement - 18.32 m2							
No Asbestos							
B001 - R0065 - Practical Activities - 1hb - 49.5 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0066 - Personal Effects Storage - 4.85 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0067 - Toilets - Girls - 9.09 m2							
Wall Linings Internal	Flat AC Sheeting	13m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	6m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0068 - Staff Room Annexe - 15.28 m2							
No Asbestos							
B001 - R0069 - Movement - 47.21 m2							
No Asbestos							
B001 - R0070 - Staff Toilet - 4.26 m2							
Wall Linings Internal	Flat AC Sheeting	6m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0071 - Home Base Store - 4.69 m2							
No Asbestos							
B001 - R0072 - Distribution Board - .51 m2							Note: No inspection of live electrical installation
No Asbestos							
B001 - R0073 - Uniform Shop - 6.38 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0074 - Canteen Office/Store - 3.52 m2							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
Floor Coverings Res/Textile	Vinyl Sheet						
B001 - R0075 - Canteen Office/Store - 6.41 m2							
Wall Linings Internal	Flat AC Sheeting	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0076 - Canteen - 43.3 m2							
Wall Linings Internal	Flat AC Sheeting	36m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0077 - General Storeroom - 1.49 m2							
No Asbestos							
B001 - R0078 - Communal Space - 245.17 m2							
No Asbestos							
B001 - R0079 - Raised Platform - 33.67 m2							
No Asbestos							
B001 - R0080 - P.E Store - 12.51 m2							
Floor Coverings Res/Textile	Vinyl Sheet						

Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0081 - Plant - .42 m2								
Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0082 - Movement - 2.69 m2								
No Asbestos								
B001 - R0083 - Movement - 2.69 m2								
No Asbestos								
B001 - R0084 - Movement - 2.69 m2								
No Asbestos								
B001 - R0085 - Movement - 2.69 m2								
No Asbestos								
B001 - R0086 - Movement - 110.37 m2								
No Asbestos								
B001 - R0087 - Movement - 2.57 m2								
No Asbestos								
B001 - R0088 - Movement - 2.57 m2								
No Asbestos								
B001 - R0089 - Movement - 2.46 m2								
No Asbestos								
B001 - R0090 - Movement - 2.59 m2								
No Asbestos								
B001 - R0091 - Movement - 42.13 m2								
No Asbestos								
B001 - R0092 - Special Programs Room - 43.54 m2								
No Asbestos								
B001 - R0093 - Toilets - Girls - 3.32 m2								
Wall Linings Internal	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
Partition Walls (Cubicles)	Compressed AC Sheet	3m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
B001 - R0094 - Toilets - Boys - 3.32 m2								
Partition Walls (Cubicles)	Compressed AC Sheet	3m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
Wall Linings Internal	Flat AC Sheeting	20m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
B001 - R0095 - Sports Store - 21.62 m2								
No Asbestos								
B001 - R0096 - Hall Chair Store - 6.27 m2								
No Asbestos								
B001 - R0097 - Home Base Store - 5.79 m2								
No Asbestos								
B001 - R0098 - Movement - 27.26 m2								
No Asbestos								
B001 - R0099 - Distribution Board - 2.28 m2								
						Note: No inspection of live electrical installation		
No Asbestos								
B001 - R0100 - General Assistant/Bulk Store - 12.14 m2								
Wall Linings Internal	Flat AC Sheeting	40m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
B001 - R0101 - Garden Store - 12.21 m2								
Wall Linings Internal	Flat AC Sheeting	40m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
B001 - R0102 - Home Base - 61.24 m2								

No Asbestos							
B001 - R0103 - Withdrawal Space - 1hb - 12.11 m2							
No Asbestos							
B001 - R0104 - Withdrawal Space - 1hb - 15.24 m2							
No Asbestos							
B001 - R0105 - Toilets - Boys - 9.04 m2							
Wall Linings Internal	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	West	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0106 - Practical Activities - 1hb - 49.21 m2							
No Asbestos							
B001 - R0107 - Home Base Store - 5.03 m2							
Wall Linings Internal	Flat AC Sheeting	5m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0108 - Home Base - 61.32 m2							
No Asbestos							
B001 - R0109 - Movement - 24.49 m2							
No Asbestos							
B001 - R0110 - Home Base Store - 5.84 m2							
No Asbestos							
B001 - R0111 - Movement - 39.86 m2							
No Asbestos							
B001 - R0112 - Movement - 5.83 m2							
No Asbestos							
B001 - R0113 - Home Base Store - 5.88 m2							
No Asbestos							
B001 - R0114 - Home Base - 62.78 m2							
No Asbestos							
B001 - R0115 - Movement - 31.85 m2							
No Asbestos							
B001 - R0116 - Withdrawal Space - 1hb - 12.11 m2							
No Asbestos							
B001 - R0117 - Movement - 18.34 m2							
No Asbestos							
B001 - R0118 - Home Base - 61.16 m2							
No Asbestos							
B001 - R0119 - Toilets - Girls - 9.55 m2							
Wall Linings Internal	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	6m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0120 - Staff Toilet - 4.18 m2							
Partition Walls (Cubicles)	Compressed AC Sheet	3m2	East	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Wall Linings Internal	Flat AC Sheeting	15m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0121 - Personal Effects Storage - 4.86 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0122 - Practical Activities - 1hb - 50.26 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0123 - Movement - 39.9 m2							

No Asbestos							
B001 - R0124 - Home Base Store - 4.87 m2							
No Asbestos							
B001 - R0125 - Distribution Board - .59 m2							Note: No inspection of live electrical installation
No Asbestos							
B001 - R0126 - Movement - 5.81 m2							
No Asbestos							
B001 - R0127 - Home Base Store - 5.81 m2							
No Asbestos							
B001 - R0128 - Movement - 24.68 m2							
No Asbestos							
B001 - R0129 - Home Base - 61.17 m2							
No Asbestos							
B001 - R0130 - Withdrawal Space - 1hb - 12.08 m2							
No Asbestos							
B001 - R0131 - Toilets - Boys - 9.13 m2							
Wall Linings Internal	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0132 - Personal Effects Storage - 4.83 m2							
Wall Linings Internal	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0133 - Practical Activities - 1hb - 49.24 m2							
No Asbestos							
B001 - R0134 - Staff Room Annexe - 15.28 m2							
No Asbestos							
B001 - R0135 - Home Base - 61.1 m2							
No Asbestos							
B001 - R0136 - Movement - 23.03 m2							
No Asbestos							
B001 - R0137 - Home Base Store - 5.93 m2							
No Asbestos							
B001 - R0138 - Movement - 13.62 m2							
No Asbestos							
B001 - R0140 - Withdrawal Space - 1hb - 11.9 m2							
Non Accessible							
B001 - R0141 - Home Base Store - 7.22 m2							
No Asbestos							
B001 - R0142 - Toilets - Boys/Girls - 3.94 m2							
Wall Linings Internal	Flat AC Sheeting	16m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0143 - Home Base Store - 3.88 m2							
Wall Linings Internal	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0145 - Withdrawal Space - 1hb - 12.51 m2							
No Asbestos							
B001 - R0147 - Home Base Store - 7.58 m2							
No Asbestos							
B001 - R0148 - Distribution Board - .59 m2							Note: No inspection of live electrical installation
Wall Linings Internal	Flat AC Sheeting	4m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Ceiling Structures/Linings	Flat AC Sheeting	1m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)

B001 - R0149 - Movement - 1.71 m2							
No Asbestos							
B001 - R0150 - Toilets - Boys/Girls - 3.3 m2							
Wall Linings Internal	Flat AC Sheeting	12m2	Variable positions	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0152 - Practical Activities - 1hb - 16.13 m2							
No Asbestos							
B001 - R0153 - Home Base Store - 5.04 m2							
No Asbestos							
B001 - R0154 - Special Programs Room - 44.6 m2							
No Asbestos							
B001 - R0155 - Practical Activities - 1hb - 31.27 m2							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
Floor Coverings Res/Textile	Vinyl Sheet						
B001 - R0156 - Staff Room Annexe - 15.85 m2							
No Asbestos							
B001 - R0157 - Cleaning Distributed Store - 5.47 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0158 - Home Base Store - 5.53 m2							
No Asbestos							
B001 - R0159 - Home Base - 61.22 m2							
No Asbestos							
B001 - R0160 - Movement - 18.31 m2							
No Asbestos							
B001 - R0161 - Withdrawal Space - 1hb - 12.01 m2							
No Asbestos							
B001 - R0162 - Movement - 31.95 m2							
No Asbestos							
B001 - R0163 - Home Base - 62.87 m2							
No Asbestos							
B001 - R0164 - Practical Activities - 1hb - 50.8 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0165 - Personal Effects Storage - 4.69 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0166 - Staff Toilet - 4.13 m2							
Partition Walls (Cubicles)	Compressed AC Sheet	2m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Wall Linings Internal	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0167 - Disabled Shower/Toilet - 9.72 m2							
Wall Linings Internal	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0168 - Movement - 71.57 m2							
No Asbestos							
B001 - R0169 - Home Base Store - 5.03 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0170 - Staff Room Annexe - 14.95 m2							
No Asbestos							
B001 - R0171 - General Storeroom - 18.98 m2							

Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0172 - General Storeroom - 6.86 m2								
Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0173 - Distribution Board - .45 m2								
Note: No inspection of live electrical installation								
No Asbestos								
B001 - R0174 - Home Base Store - 4.28 m2								
No Asbestos								
B001 - R0175 - Movement - 3.09 m2								
No Asbestos								
B001 - R0176 - Home Base - 57.29 m2								
No Asbestos								
B001 - R0177 - Withdrawal Space - 1hb - 14.06 m2								
No Asbestos								
B001 - R0178 - Home Base Store - 5.17 m2								
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
Floor Coverings Res/Textile	Vinyl Sheet							
B001 - R0179 - Home Base - 57.44 m2								
No Asbestos								
B001 - R0180 - Practical Activities - 1hb - 47.13 m2								
Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0181 - Personal Effects Storage - 1.04 m2								
No Asbestos								
B001 - R0182 - Staff Room Annexe - 20.36 m2								
No Asbestos								
B001 - R0183 - Staff Toilet - 2.38 m2								
No Asbestos								
B001 - R0184 - Movement - 26.97 m2								
No Asbestos								
B001 - R0185 - Movement - 169.94 m2								
No Asbestos								
B001 - R0186 - Interview - 12.43 m2								
No Asbestos								
B001 - R0187 - Deputy Principal - 12.46 m2								
No Asbestos								
B001 - R0188 - Cleaning Supplies - 8.28 m2								
Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0189 - Cleaning Distributed Store - 5.15 m2								
Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0190 - General Assistant/Bulk Store - 8.28 m2								
Floor Coverings Res/Textile	Vinyl Sheet							
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive							
B001 - R0191 - Staff Toilet - 5.92 m2								
Partition Walls (Cubicles)	Compressed AC Sheet	3m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	
B001 - R0192 - Staff Toilet - 5.93 m2								
Partition Walls (Cubicles)	Compressed AC Sheet	3m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)	

B001 - R0193 - General Assistant/Bulk Store - 62 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0194 - Staff Room - 69.29 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0195 - Duplicating Workroom - 40.34 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0196 - Sick Bay - 16.52 m2							
Floor Coverings Res/Textile	Vinyl Sheet						
Floor Coverings Res/Textile	Vinyl Sheet - Adhesive						
B001 - R0197 - Distribution Board - .67 m2							
							Note: No inspection of live electrical installation
No Asbestos							
B001 - R0198 - Clerical Office - 15.5 m2							
No Asbestos							
B001 - R0199 - Principal - 20.69 m2							
No Asbestos							
B001 - R0200 - Interview - 13.73 m2							
No Asbestos							
B001 - R0201 - Movement - 38.23 m2							
No Asbestos							
B001 - R0202 - Practical Activities - 1hb - 26.41 m2							
No Asbestos							
B001 - R0203 - Home Base - 46.22 m2							
No Asbestos							
B001 - R0204 - Movement - 63.89 m2							
No Asbestos							
B001 - R0205 - Home Base - 57 m2							
No Asbestos							
B001 - R0206 - Home Base Store - 7.65 m2							
No Asbestos							
B001 - R0207 - Other-Community Use - 13.13 m2							
Wall Linings Internal - Infill	Flat AC Sheeting	5m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B001 - R0208 - Other-Community Use - 51.09 m2							
Wall Linings Internal - Infill	Flat AC Sheeting	5m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - Pupil Facilities - 1979 - Brick/Block							
Exterior							
Eaves Linings	Flat AC Sheeting	20m2	East, West	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Underfloor Voids - Slab on Ground	No Asbestos Found						
Ceiling Voids	No Asbestos Found						
Interior							
B002 - R0001 - Movement - 12.76 m2							
Ceiling Structures/Linings	Flat AC Sheeting	13m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0002 - Drinking Facilities - 13.47 m2							
Ceiling Structures/Linings	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0003 - Toilets - Girls - 33.97 m2							

Ceiling Structures/Linings	Flat AC Sheeting	34m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	16m2	South	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0004 - Cleaning Distributed Store - 2.06 m2							
Ceiling Structures/Linings	Flat AC Sheeting	2.06m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0005 - General Storeroom - 2.92 m2							
Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Minimal Damage (2)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Plant / Equipment - Incinerator	Encapsulated Asbestos material within unit	1	West	Friable Asbestos (5)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B002 - R0006 - General Storeroom - 2.92 m2							
Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0007 - Cleaning Supplies - 2.07 m2							
Ceiling Structures/Linings	Flat AC Sheeting	3m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0008 - Plant - 9.04 m2							
Ceiling Structures/Linings	Flat AC Sheeting	10m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Furniture / Fixtures - Cistern	Fibre Cement Casting (Monocrete)	11	North, South	Good Condition (1)	Low (1)	Low Priority (2-3)	Assumed Asbestos
B002 - R0009 - Toilets - Boys - 33.97 m2							
Ceiling Structures/Linings	Flat AC Sheeting	34m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
Partition Walls (Cubicles)	Compressed AC Sheet	9m2	North	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0010 - Drinking Facilities - 13.47 m2							
Ceiling Structures/Linings	Flat AC Sheeting	14m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B002 - R0011 - Movement - 12.76 m2							
Ceiling Structures/Linings	Flat AC Sheeting	13m2	Throughout	Good Condition (1)	Low (1)	Low Priority (2-3)	Chrysotile (white asbestos)
B003 - Communal Facilities - 2011 - Brick/Veneer							
Exterior							
Ceiling Voids - Flat Roof	No Asbestos Found						
Underfloor Voids - Slab on Ground	No Asbestos Found						
Interior							
B003 - R0001 - Communal Space - 160.15 m2							
No Asbestos							
B003 - R0002 - Raised Platform - 51.96 m2							
No Asbestos							
B003 - R0003 - Movement - 4.16 m2							
No Asbestos							
B003 - R0004 - Covered Outdoor Learning Area - 153.93 m2							
No Asbestos							
B003 - R0005 - Ramp - 11.09 m2							
No Asbestos							
B003 - R0006 - Movement - 11.65 m2							
No Asbestos							
B003 - R0007 - Hall Chair Store - 9.53 m2							
No Asbestos							
B003 - R0008 - Communal/Performance Store - 9.84 m2							
No Asbestos							

B003 - R0009 - P.E. Store - 13.04 m2	
No Asbestos	
B003 - R0010 - Toilet - Lobby - 2.38 m2	
No Asbestos	
B003 - R0011 - Toilets - Girls - 7.35 m2	
No Asbestos	
B003 - R0012 - Sound Cupboard - 2.04 m2	
No Asbestos	
B003 - R0013 - Toilets - Boys - 5.9 m2	
No Asbestos	
B003 - R0014 - Toilet - Lobby - 3.33 m2	
No Asbestos	
B003 - R0015 - Cleaning Distributed Store - 3.54 m2	
No Asbestos	
B003 - R0016 - Other - 1.61 m2	
No Asbestos	
B003 - R0017 - Distribution Board - 3.24 m2	Note: No inspection of live electrical installation
No Asbestos	
B003 - R0018 - Access Shower/Toilet/Change - 6.81 m2	
No Asbestos	

Demountables

There are no Demountable(s) Located at this school as per the AMS records as of 09-Sep-2020