


Asbestos Register

(Hazardous Materials and Risk Assessment)

| | |
|------------------------|--------------------------------|
| School: | Ladysmith Public School (2353) |
| Region: | Southern NSW AMU |
| State Electorate: | Wagga Wagga |
| Local Government Area: | Wagga Wagga |

| | |
|-------------------|-----------------|
| Last Reviewed By: | WSP 07-FEB-2017 |
| Last Revised By: | |

| | |
|--|-----------|
| Historical Fibro In Grounds Investigations/Events | No |
| <p>No previous investigations have been recorded against the school. However, asbestos containing materials maybe present in grounds from time to time and caution must be exercised prior to any grounds disturbance.</p> | |



Preface to Asbestos Register

Limitations

Asbestos Registers established (first surveyed 2007/08) and maintained for the Department of Education (DoE) are limited in extent, in that:

1. All inspections and surveys of materials and finishes in DoE facilities are non-disturbance, with
2. Samples undertaken by hygienist to determine whether a sample is an Asbestos Containing Material (ACM),
3. The hygienist may apply a single sample to like materials within a space and adjoining spaces, but not normally between buildings,
4. Successive inspections have reduced any inconclusive records such as 'assumed asbestos' in difficult to access areas, by undertaking additional sampling with lifting devices.
5. In compliance with WHS Act 2011 and WHS Regulations 2017, additional inspections have been undertaken in ceiling spaces and sub-floor areas where access is possible.
 - o Where the ground floor is slab on ground, no inspection is made beneath the slab.
 - o Where fibro fragments (ACM taken for sampling) are located in ceiling spaces or sub floor voids air monitoring is normally undertaken at time of sampling, and clearance undertaken as soon as practicable.
6. No attempt has been made to identify any ACM that is hidden from view or encapsulated within
 - o Any wall cavity
 - o Sub floor area, particularly formwork for slabs in/on ground,
 - o Services (that may use ACM) such as: pipe lagging, asbestos cement pipes, flues.
7. All known ACM in Grounds (Fibro in Grounds) is made available in associated site specific asbestos management plans in DoE electronic files.
Notwithstanding information provided, ACM may be present in grounds from time to time and caution must be exercised prior to any grounds disturbance.

Use of the Asbestos Register

Prior to any disturbance works being undertaken in a building to which this asbestos register applies it will be necessary to confirm the extent of any ACM by a disturbance investigation:

- If the building was built prior to 2003
- If any ACM has been identified in the Asbestos Register for the building.

Update of Asbestos Registers

Asbestos Register Data is updated regularly by the DoE Hygienist Panel via the Online Asbestos Register Tool (Managed by Business Systems, School Infrastructure NSW). Internal users can view the latest edition of the Asbestos Register in the AMS.

Please note: The Department's external website may not contain the latest revision of the Asbestos Register.

Notes 1: Vermiculite

- During 2018/19, all vermiculite occurrences in DoE schools identified in 2007/08, were 'composite tested' in accordance with a safe work NSW agreed procedure. This required multiple testing of all vermiculite occurrences.
- During the period 2007/08 to 2018/19, some vermiculite has been over sheeted and a warning is indicated for schools where this has happened.

Note 2: DoE website link for information is here:

<https://www.schoolinfrastructure.nsw.gov.au/about-us/working-with-us/schools-asbestos-register.html>
<https://education.nsw.gov.au/about-us/strategies-and-reports/our-reports-and-reviews/schools-asbestos-register>

Note 3: Material Condition Assessment

The material condition assessment descriptors from Section 3 of the Asbestos Management Plan (AMP) is extracted below. Please read the AMP in its entirety for further information.

3.3.2.1 Material condition assessment

The OART records the material condition of identified ACM in the following format:

| Rating | Description |
|----------------------------|--|
| Good condition (1) | For non-friable asbestos that is sealed and has no visible damage. This primarily related to asbestos cement (AC) sheet and vinyl tiles |
| Minimal damage (2) | For non-friable asbestos that has a very small amount of damage, eg hairline cracks. |
| Some damage / unsealed (3) | For non-friable asbestos with significant breakage or several small areas where material has been damaged, revealing loose asbestos fibres. Non-friable asbestos that is unsealed. |
| Poor condition (4) | For non-friable asbestos that has extensive damage. Visible asbestos debris |
| Friable asbestos (5) | Any occurrence of friable asbestos |

| Product | Material Description | Extent | Location | Material Condition | Risk Status | Remediation Priority | Result |
|---|----------------------|--------|------------|----------------------------|-------------|-----------------------|-----------------------------|
| B00A - Administration/General Learning - 1917 - Timber | | | | | | | |
| Exterior | | | | | | | |
| Eaves Linings | Flat AC Sheeting | 6m2 | East, West | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) |
| Ceiling Voids | No Asbestos Found | | | | | | |
| Underfloor Voids | Packing | | Throughout | Some Damage - Unsealed (3) | Low (1) | Medium Priority (4-5) | Chrysotile (white asbestos) |
| Interior | | | | | | | |
| B00A - R0001 - Principal - 7.63 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00A - R0002 - Home Base - 74.5 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00A - R0003 - General Storeroom - 8.74 m2 | | | | | | | |
| Floor Coverings Res/Textile | Vinyl Sheet | | | | | | |
| B00A - R0004 - Sports Store - 10.08 m2 | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 11m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) |
| B00A - R0005 - External Movement - 5.69 m2 | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 6m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) |
| B00A - R0006 - Duplicating Workroom - 11.01 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00A - R0007 - Movement - 2.44 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00A - R0008 - Clerical Office - 9.57 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00A - R0009 - Entry Vestibule - 5.17 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00B - General Learning - 1926 - Timber | | | | | | | |
| Exterior | | | | | | | |
| Ceiling Voids | No Asbestos Found | | | | | | |
| Underfloor Voids | Packing | | Throughout | Some Damage - Unsealed (3) | Low (1) | Medium Priority (4-5) | Chrysotile (white asbestos) |
| Interior | | | | | | | |
| B00B - R0001 - Practical Activities - 1hb - 23.82 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00B - R0002 - Home Base - 33.4 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00B - R0003 - Craft Store - 7.58 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00B - R0004 - External Movement - 22.65 m2 | | | | | | | |
| No Asbestos | | | | | | | |
| B00C - Administration - 1950 - Timber | | | | | | | |
| Exterior | | | | | | | |
| Eaves Linings | Flat AC Sheeting | 6m2 | East | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) |
| Entry Steps | Flat AC Sheeting | | | | | | |
| Underfloor Voids | Packing | | Throughout | Some Damage - Unsealed (3) | Low (1) | Medium Priority (4-5) | Chrysotile (white asbestos) |

| | | | | | | | | |
|---|-------------------|------|------------|----------------------------|---------|-----------------------|-----------------------------|--|
| Ceiling Voids | No Asbestos Found | | | | | | | |
| Interior | | | | | | | | |
| B00C - R0001 - Staff Room - 21.71 m2 | | | | | | | | |
| No Asbestos | | | | | | | | |
| B00C - R0003 - External Movement - 24.78 m2 | | | | | | | | |
| No Asbestos | | | | | | | | |
| B00C - R0004 - Disabled Toilet - 8.33 m2 | | | | | | | | |
| No Asbestos | | | | | | | | |
| B00D - Special Purpose - 1950 - Timber | | | | | | | | |
| Exterior | | | | | | | | |
| Underfloor Voids | Packing | | Throughout | Some Damage - Unsealed (3) | Low (1) | Medium Priority (4-5) | Chrysotile (white asbestos) | |
| Ceiling Voids | No Asbestos Found | | | | | | | |
| Interior | | | | | | | | |
| B00D - R0001 - External Movement - 8.74 m2 | | | | | | | | |
| No Asbestos | | | | | | | | |
| B00D - R0003 - General Storeroom - 16.89 m2 | | | | | | | | |
| No Asbestos | | | | | | | | |
| B00D - R0004 - Toilet - Lobby - 4.46 m2 | | | | | | | | |
| No Asbestos | | | | | | | | |
| B00E - Pupil Facilities/Building Services - 1972 - Brick/Block | | | | | | | | |
| Exterior | | | | | | | | |
| Eaves Linings | Flat AC Sheeting | 20m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| Ceiling Voids | No Asbestos Found | | | | | | | |
| Underfloor Voids - Slab on Ground | No Asbestos Found | | | | | | | |
| Interior | | | | | | | | |
| B00E - R0001 - Toilets - Girls - 11.4 m2 | | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 12m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| B00E - R0002 - Cleaning Supplies - 3.11 m2 | | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 4m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| B00E - R0003 - Staff Toilet - 1.33 m2 | | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 2m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| B00E - R0004 - Toilets - Boys - 16.85 m2 | | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 17m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| B00E - R0005 - Staff Toilet - 1.33 m2 | | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 2m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| B00E - R0006 - General Storeroom - 3.11 m2 | | | | | | | | |
| Ceiling Structures/Linings | Flat AC Sheeting | 4m2 | Throughout | Good Condition (1) | Low (1) | Low Priority (2-3) | Chrysotile (white asbestos) | |
| B00F - Building Services - 2008 - Metal Shed | | | | | | | | |
| Exterior | | | | | | | | |
| Ceiling Voids | No Asbestos Found | | | | | | | |
| Underfloor Voids - Slab on Ground | No Asbestos Found | | | | | | | |

| | | |
|--|-------------------|--|
| Interior | | |
| B00F - R0001 - Garden Store - 60.83 m2 | | |
| No Asbestos | | |
| B00G - Other-Vacant - 2008 - Brick/Block | | |
| Exterior | | |
| Ceiling Voids | No Asbestos Found | |
| Underfloor Voids - Slab on Ground | No Asbestos Found | |
| Interior | | |
| B00G - R0001 - General Storeroom - 5.25 m2 | | |
| No Asbestos | | |
| B00H - Library - 2010 - Fibre Cement Clad | | |
| Exterior | | |
| Ceiling Voids | No Asbestos Found | |
| Underfloor Voids | No Asbestos Found | |
| Interior | | |
| B00H - R0001 - Reading Area - 59.85 m2 | | |
| No Asbestos | | |
| B00H - R0002 - K.L.A. Store - 6.18 m2 | | |
| No Asbestos | | |
| B00H - R0003 - Practical Activities - 3.13 m2 | | |
| No Asbestos | | |
| B00H - R0004 - External Movement - 18.14 m2 | | |
| No Asbestos | | |
| B00I - Pupil Facilities - 2014 - Brick/Block | | |
| Exterior | | |
| Underfloor Voids | No Asbestos Found | |
| Ceiling Voids | No Asbestos Found | |
| Underfloor Voids | No Asbestos Found | |
| Ceiling Voids | No Asbestos Found | |
| Interior | | |
| B00I - R0001 - External Movement - 12.19 m2 | | |
| No Asbestos | | |
| B00I - R0002 - Toilets - Boys - 11.74 m2 | | |
| No Asbestos | | |
| B00I - R0003 - Staff Toilet - 4.86 m2 | | |
| No Asbestos | | |
| B00I - R0004 - Toilets - Girls - 12.93 m2 | | |
| No Asbestos | | |
| B00J - Special Purpose - 2014 - Greenhouse | | |
| Exterior | | |
| Ceiling Voids | No Asbestos Found | |
| Underfloor Voids | No Asbestos Found | |

| | | |
|---|-------------------|--|
| Ceiling Voids | No Asbestos Found | |
| Underfloor Voids | No Asbestos Found | |
| Interior | | |
| B00J - R0001 - Plant Growing Space - 5.32 m2 | | |
| No Asbestos | | |

Demountables

There are no Demountable(s) Located at this school as per the AMS records as of 09-Sep-2020