


# Asbestos Register

(Hazardous Materials and Risk Assessment)

|                        |                                |
|------------------------|--------------------------------|
| School:                | Laurieton Public School (2377) |
| Region:                | North Coast AMU                |
| State Electorate:      | Port Macquarie                 |
| Local Government Area: | Port Macquarie-Hastings        |

|                   |                 |
|-------------------|-----------------|
| Last Reviewed By: | WSP 31-OCT-2016 |
| Last Revised By:  |                 |

|  |           |
|--|-----------|
| Historical Fibro In Grounds Investigations/Events  | <b>No</b> |
| <p>No previous investigations have been recorded against the school. However, asbestos containing materials maybe present in grounds from time to time and caution must be exercised prior to any grounds disturbance.</p> |           |



# Preface to Asbestos Register

## Limitations

Asbestos Registers established (first surveyed 2007/08) and maintained for the Department of Education (DoE) are limited in extent, in that:

1. All inspections and surveys of materials and finishes in DoE facilities are non-disturbance, with
2. Samples undertaken by hygienist to determine whether a sample is an Asbestos Containing Material (ACM),
3. The hygienist may apply a single sample to like materials within a space and adjoining spaces, but not normally between buildings,
4. Successive inspections have reduced any inconclusive records such as 'assumed asbestos' in difficult to access areas, by undertaking additional sampling with lifting devices.
5. In compliance with WHS Act 2011 and WHS Regulations 2017, additional inspections have been undertaken in ceiling spaces and sub-floor areas where access is possible.
  - o Where the ground floor is slab on ground, no inspection is made beneath the slab.
  - o Where fibro fragments (ACM taken for sampling) are located in ceiling spaces or sub floor voids air monitoring is normally undertaken at time of sampling, and clearance undertaken as soon as practicable.
6. No attempt has been made to identify any ACM that is hidden from view or encapsulated within
  - o Any wall cavity
  - o Sub floor area, particularly formwork for slabs in/on ground,
  - o Services (that may use ACM) such as: pipe lagging, asbestos cement pipes, flues.
7. All known ACM in Grounds (Fibro in Grounds) is made available in associated site specific asbestos management plans in DoE electronic files.  
Notwithstanding information provided, ACM may be present in grounds from time to time and caution must be exercised prior to any grounds disturbance.

## Use of the Asbestos Register

Prior to any disturbance works being undertaken in a building to which this asbestos register applies it will be necessary to confirm the extent of any ACM by a disturbance investigation:

- If the building was built prior to 2003
- If any ACM has been identified in the Asbestos Register for the building.

## Update of Asbestos Registers

Asbestos Register Data is updated regularly by the DoE Hygienist Panel via the Online Asbestos Register Tool (Managed by Business Systems, School Infrastructure NSW). Internal users can view the latest edition of the Asbestos Register in the AMS.

Please note: The Department's external website may not contain the latest revision of the Asbestos Register.

## Notes 1: Vermiculite

- During 2018/19, all vermiculite occurrences in DoE schools identified in 2007/08, were 'composite tested' in accordance with a safe work NSW agreed procedure. This required multiple testing of all vermiculite occurrences.
- During the period 2007/08 to 2018/19, some vermiculite has been over sheeted and a warning is indicated for schools where this has happened.

## Note 2: DoE website link for information is here:

<https://www.schoolinfrastructure.nsw.gov.au/about-us/working-with-us/schools-asbestos-register.html>

<https://education.nsw.gov.au/about-us/strategies-and-reports/our-reports-and-reviews/schools-asbestos-register>

## Note 3: Material Condition Assessment

The material condition assessment descriptors from Section 3 of the Asbestos Management Plan (AMP) is extracted below. Please read the AMP in its entirety for further information.

### 3.3.2.1 Material condition assessment

The OART records the material condition of identified ACM in the following format:

| Rating                     | Description  |
|----------------------------|--|
| Good condition (1)         | For non-friable asbestos that is sealed and has no visible damage. This primarily related to asbestos cement (AC) sheet and vinyl tiles  |
| Minimal damage (2)         | For non-friable asbestos that has a very small amount of damage, eg hairline cracks.   |
| Some damage / unsealed (3) | For non-friable asbestos with significant breakage or several small areas where material has been damaged, revealing loose asbestos fibres. Non-friable asbestos that is unsealed. |
| Poor condition (4)         | For non-friable asbestos that has extensive damage. Visible asbestos debris  |
| Friable asbestos (5)       | Any occurrence of friable asbestos   |

| Product  | Material Description | Extent | Location                    | Material Condition | Risk Status | Remediation Priority | Result                      |
|--|----------------------|--------|-----------------------------|--------------------|-------------|----------------------|-----------------------------|
| <b>B001 - Administration - 1970 - Brick/Veneer</b>       |                      |        |                             |                    |             |                      |                             |
| <b>Exterior</b>  |                      |        |                             |                    |             |                      |                             |
| Eaves Linings  | Flat AC Sheeting     | 20m2   | Variable positions          | Good Condition (1) | Low (1)     | Low Priority (2-3)   | Chrysotile (white asbestos) |
| Wall Cladding  | Flat AC Sheeting     |        |                             |                    |             |                      |                             |
| Gable Verge Lining                                       | Flat AC Sheeting     |        |                             |                    |             |                      |                             |
| Ceiling Voids  | No Asbestos Found    |        |                             |                    |             |                      |                             |
| Underfloor Voids   | No Asbestos Found    |        |                             |                    |             |                      |                             |
| <b>Interior</b>  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0001 - Cleaning Supplies - 1.95 m2</b>        |                      |        |                             |                    |             |                      |                             |
| Ceiling Structures/Linings - Access Hatch                | AC Fragments/Debris  |        |                             |                    |             |                      |                             |
| <b>B001 - R0002 - Staff Toilet - 3.68 m2</b>             |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0003 - Staff Toilet - 3.04 m2</b>             |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0004 - Entry Vestibule - 8.58 m2</b>          |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0006 - General Storeroom - 5.68 m2</b>        |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0007 - Cleaning Supplies - .78 m2</b>         |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0008 - Sick Bay - 5.8 m2</b>                  |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0009 - Clerical Office - 15.71 m2</b>         |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0010 - General Storeroom - 11.11 m2</b>       |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0011 - External Movement - 37.97 m2</b>       |                      |        |                             |                    |             |                      |                             |
| Wall Linings Internal                                    | Flat AC Sheeting     | 2m2    | South facing, Upper portion | Good Condition (1) | Low (1)     | Low Priority (2-3)   | Chrysotile (white asbestos) |
| Ceiling Structures/Linings                               | Flat AC Sheeting     | 38m2   | All surfaces                | Good Condition (1) | Low (1)     | Low Priority (2-3)   | Chrysotile (white asbestos) |
| <b>B001 - R0012 - Home Base - 56.27 m2</b>               |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0013 - Home Base Store - 5.48 m2</b>          |                      |        |                             |                    |             |                      |                             |
| Floor Coverings Res/Textile                              | Vinyl Sheet          |        |                             |                    |             |                      |                             |
| <b>B001 - R0014 - Personal Effects Storage - 7.33 m2</b> |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0015 - Movement - 3.65 m2</b>                 |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0016 - Movement - 5.76 m2</b>                 |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0017 - External Movement - 24.56 m2</b>       |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0018 - Sick Bay - 13.12 m2</b>                |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |
| <b>B001 - R0019 - Security Store - .52 m2</b>            |                      |        |                             |                    |             |                      |                             |
| No Asbestos  |                      |        |                             |                    |             |                      |                             |

|   |                     |      |                    |                                       |         |                       |                             |
|---|---------------------|------|--------------------|---------------------------------------|---------|-----------------------|-----------------------------|
| <b>B001 - R0020 - Security Store - .73 m2</b>               |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B001 - R0021 - Clerical Office - 18.82 m2</b>            |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B001 - R0022 - Entry Vestibule - 8.88 m2</b>             |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B001 - R0023 - Interview - 12.47 m2</b>                  |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B001 - R0024 - External Movement - 11.05 m2</b>          |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B002 - Library - 2011 - Fibre Cement Clad</b>            |                     |      |                    |                                       |         |                       |                             |
| <b>Exterior</b>   |                     |      |                    |                                       |         |                       |                             |
| Ceiling Voids   | No Asbestos Found   |      |                    |                                       |         |                       |                             |
| Underfloor Voids  | No Asbestos Found   |      |                    |                                       |         |                       |                             |
| <b>Interior</b>   |                     |      |                    |                                       |         |                       |                             |
| <b>B002 - R0001 - External Movement - 35.23 m2</b>          |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B002 - R0002 - Reading Area - 92.72 m2</b>               |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B002 - R0003 - Library Office/Workroom - 20.35 m2</b>    |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B002 - R0004 - Communications Room - 7.2 m2</b>          |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B002 - R0005 - K.L.A. Store - 7.55 m2</b>                |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - General Learning - 1970 - Brick/Block</b>         |                     |      |                    |                                       |         |                       |                             |
| <b>Exterior</b>   |                     |      |                    |                                       |         |                       |                             |
| Wall Cladding   | Flat AC Sheeting    |      |                    |                                       |         |                       |                             |
| Gable Verge Lining  | Flat AC Sheeting    | 20m2 | Variable positions | Minimal Damage (2)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos) |
| Ceiling Voids   | AC Fragments/Debris | 1    | North              | Poor Condition - Extensive Damage (4) | Low (1) | Medium Priority (4-5) | Chrysotile (white asbestos) |
| Underfloor Voids  | No Asbestos Found   |      |                    |                                       |         |                       |                             |
| <b>Interior</b>   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0001 - Home Base Store - 6.41 m2</b>             |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0002 - Personal Effects Storage - 6.48 m2</b>    |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0003 - Home Base - 53.29 m2</b>                  |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0004 - Personal Effects Storage - 5.94 m2</b>    |                     |      |                    |                                       |         |                       |                             |
| Ceiling Structures/Linings - Access Hatch                   | Flat AC Sheeting    |      |                    |                                       |         |                       |                             |
| <b>B003 - R0005 - Home Base Store - 3.23 m2</b>             |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0006 - Toilets - Boys/Girls - 3.3 m2</b>         |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0007 - Home Base - 67.59 m2</b>                  |                     |      |                    |                                       |         |                       |                             |
| No Asbestos   |                     |      |                    |                                       |         |                       |                             |
| <b>B003 - R0008 - Practical Activities - 1hb - 17.64 m2</b> |                     |      |                    |                                       |         |                       |                             |

|   |                     |      |                                   |                                       |         |                       |  |
|---|---------------------|------|-----------------------------------|---------------------------------------|---------|-----------------------|--|
| Floor Coverings Res/Textile                                   | Vinyl Sheet         |      |                                   |                                       |         |                       |  |
| <b>B003 - R0009 - Toilets - Girls - 27.44 m2</b>              |                     |      |                                   |                                       |         |                       |  |
| Ceiling Structures/Linings                                    | Flat AC Sheeting    | 28m2 | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| Partition Walls (Cubicles)                                    | Flat AC Sheeting    | 10m2 | All surfaces                      | Minimal Damage (2)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| <b>B003 - R0011 - Staff Room - 57.01 m2</b>                   |                     |      |                                   |                                       |         |                       |  |
| Ceiling Structures/Linings                                    | Flat AC Sheeting    | 58m2 | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| <b>B003 - R0015 - Staff Toilet - 1.18 m2</b>                  |                     |      |                                   |                                       |         |                       |  |
| No Asbestos   |                     |      |                                   |                                       |         |                       |  |
| <b>B003 - R0016 - P.E Store - 7.56 m2</b>                     |                     |      |                                   |                                       |         |                       |  |
| No Asbestos   |                     |      |                                   |                                       |         |                       |  |
| <b>B003 - R0017 - External Movement - 64.86 m2</b>            |                     |      |                                   |                                       |         |                       |  |
| Ceiling Structures/Linings                                    | Flat AC Sheeting    | 65m2 | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| Wall Linings Internal   | Flat AC Sheeting    | 2m2  | Upper portion, Variable positions | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| <b>B003 - R0018 - Toilets - Boys - 21.91 m2</b>               |                     |      |                                   |                                       |         |                       |  |
| Partition Walls (Cubicles)                                    | Flat AC Sheeting    | 10m2 | All surfaces                      | Minimal Damage (2)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| Ceiling Structures/Linings                                    | Flat AC Sheeting    | 22m2 | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| <b>B003 - R0019 - Toilets-Unisex - 5.17 m2</b>                |                     |      |                                   |                                       |         |                       |  |
| No Asbestos   |                     |      |                                   |                                       |         |                       |  |
| <b>B003 - R0020 - Canteen - 21.58 m2</b>                      |                     |      |                                   |                                       |         |                       |  |
| No Asbestos   |                     |      |                                   |                                       |         |                       |  |
| <b>B007 - Special Purpose - 1946 - Timber</b>                 |                     |      |                                   |                                       |         |                       |  |
| <b>Exterior</b>   |                     |      |                                   |                                       |         |                       |  |
| Eaves Linings   | Flat AC Sheeting    | 40m2 | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| Ceiling Voids   | AC Fragments/Debris | 1    | West                              | Poor Condition - Extensive Damage (4) | Low (1) | Medium Priority (4-5) | Chrysotile (white asbestos) , Amosite (brown asbestos) |
| Underfloor Voids  | No Asbestos Found   |      |                                   |                                       |         |                       |  |
| <b>Interior</b>   |                     |      |                                   |                                       |         |                       |  |
| <b>B007 - R0001 - External Movement - 10.46 m2</b>            |                     |      |                                   |                                       |         |                       |  |
| Ceiling Structures/Linings                                    | Flat AC Sheeting    | 11m2 | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| <b>B007 - R0002 - Withdrawal Space - 1hb - 44.02 m2</b>       |                     |      |                                   |                                       |         |                       |  |
| No Asbestos   |                     |      |                                   |                                       |         |                       |  |
| <b>B007 - R0003 - Kiln Room - 5.61 m2</b>                     |                     |      |                                   |                                       |         |                       |  |
| Ceiling Structures/Linings                                    | Flat AC Sheeting    | 6m2  | All surfaces                      | Good Condition (1)                    | Low (1) | Low Priority (2-3)    | Chrysotile (white asbestos)                            |
| <b>B008 - Administration - 1999 - Metal Shed</b>              |                     |      |                                   |                                       |         |                       |  |
| <b>Exterior</b>   |                     |      |                                   |                                       |         |                       |  |
| Ceiling Voids   | No Asbestos Found   |      |                                   |                                       |         |                       |  |
| Underfloor Voids  | No Asbestos Found   |      |                                   |                                       |         |                       |  |
| <b>Interior</b>   |                     |      |                                   |                                       |         |                       |  |
| <b>B008 - R0001 - General Assistant/Bulk Store - 13.08 m2</b> |                     |      |                                   |                                       |         |                       |  |
| No Asbestos   |                     |      |                                   |                                       |         |                       |  |
| <b>B009 - General Learning - 2004 - Fibre Cement Clad</b>     |                     |      |                                   |                                       |         |                       |  |

|  |                   |  |
|--|-------------------|--|
| <b>Exterior</b>  |                   |  |
| Ceiling Voids  | No Asbestos Found |  |
| Underfloor Voids   | No Asbestos Found |  |
| <b>Interior</b>  |                   |  |
| <b>B009 - R0001 - External Movement - 38.48 m2</b>                       |                   |  |
| No Asbestos  |                   |  |
| <b>B009 - R0002 - Practical Activities - 1hb - 19.39 m2</b>              |                   |  |
| No Asbestos  |                   |  |
| <b>B009 - R0003 - Home Base Store - 6.01 m2</b>                          |                   |  |
| Floor Coverings Res/Textile  | No Asbestos Found |  |
| <b>B009 - R0004 - Home Base - 59.2 m2</b>                                |                   |  |
| Floor Coverings Res/Textile  | No Asbestos Found |  |
| <b>B009 - R0005 - Withdrawal Space - 2hb - 11.36 m2</b>                  |                   |  |
| Floor Coverings Res/Textile  | No Asbestos Found |  |
| <b>B009 - R0006 - Home Base - 59.19 m2</b>                               |                   |  |
| Floor Coverings Res/Textile  | No Asbestos Found |  |
| <b>B009 - R0007 - Home Base Store - 6.02 m2</b>                          |                   |  |
| Floor Coverings Res/Textile  | No Asbestos Found |  |
| <b>B009 - R0008 - Practical Activities - 1hb - 19.4 m2</b>               |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - Communal Facilities/General Learning - 2010 - Brick/Veneer</b> |                   |  |
| <b>Exterior</b>  |                   |  |
| Underfloor Voids - Slab on Ground  | No Asbestos Found |  |
| Ceiling Voids  | No Asbestos Found |  |
| <b>Interior</b>  |                   |  |
| <b>B010 - R0001 - Communal Space - 145.26 m2</b>                         |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0002 - Raised Platform - 56.08 m2</b>                         |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0003 - Hall Chair Store - 9.48 m2</b>                         |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0004 - Communal/Performance Store - 9.32 m2</b>               |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0005 - P.E. Store - 13.09 m2</b>                              |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0006 - Toilet - Lobby - 2.37 m2</b>                           |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0007 - Toilets - Girls - 7.31 m2</b>                          |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0008 - Sound Cupboard - 2.06 m2</b>                           |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0009 - Toilet - Lobby - 3.3 m2</b>                            |                   |  |
| No Asbestos  |                   |  |
| <b>B010 - R0010 - Toilets - Boys - 5.71 m2</b>                           |                   |  |
| No Asbestos  |                   |  |

|   |                   |
|---|-------------------|
| <b>B010 - R0011 - Cleaning Distributed Store - 3.51 m2</b>      |                   |
| No Asbestos   |                   |
| <b>B010 - R0012 - Plant - 1.6 m2</b>                            |                   |
| No Asbestos   |                   |
| <b>B010 - R0013 - Main Switch Board - 3.23 m2</b>               |                   |
| No Asbestos   |                   |
| <b>B010 - R0014 - Access Shower/Toilet - 6.87 m2</b>            |                   |
| No Asbestos   |                   |
| <b>B010 - R0015 - Covered Outdoor Learning Area - 147.66 m2</b> |                   |
| No Asbestos   |                   |
| <b>B010 - R0016 - Movement - 7.14 m2</b>                        |                   |
| No Asbestos   |                   |
| <b>B010 - R0017 - Movement - 15.27 m2</b>                       |                   |
| No Asbestos   |                   |
| <b>B010 - R0018 - Movement - 11.84 m2</b>                       |                   |
| No Asbestos   |                   |
| <b>B011 - Administration - 2006 - Metal Shed</b>                |                   |
| <b>Exterior</b>   |                   |
| Underfloor Voids - Slab on Ground                               | No Asbestos Found |
| Ceiling Voids   | No Asbestos Found |
| <b>Interior</b>   |                   |
| <b>B011 - R0001 - General Storeroom - 7.58 m2</b>               |                   |
| No Asbestos   |                   |
| <b>B012 - Administration - 2006 - Metal Shed</b>                |                   |
| <b>Exterior</b>   |                   |
| Underfloor Voids - Slab on Ground                               | No Asbestos Found |
| Ceiling Voids   | No Asbestos Found |
| <b>Interior</b>   |                   |
| <b>B012 - R0001 - General Storeroom - 8.71 m2</b>               |                   |
| No Asbestos   |                   |

## Demountables

### OS 601 10209 - Learning Unit - Standard/Withdrawal - Placement Date : 30-JUN-1995

#### Exterior

|               |                     |         |                  |
|---------------|---------------------|---------|------------------|
| Eaves Linings | Flat AC Sheeting    | 11.52m2 | Assumed Asbestos |
| Landing       | Compressed AC Sheet | 1.2m2   | Assumed Asbestos |
| Step Treads   | Compressed AC Sheet | 1.08m2  | Assumed Asbestos |

#### Interior

##### R1- Entry

|                            |                  |      |                  |
|----------------------------|------------------|------|------------------|
| End Wall Panel             | Flat AC Sheeting | 18m2 | Assumed Asbestos |
| Ceiling Structures/Linings | Flat AC Sheeting | 8m2  | Assumed Asbestos |

##### R2- General Learning Space

|                            |                  |      |                  |
|----------------------------|------------------|------|------------------|
| End Wall Panel             | Flat AC Sheeting | 18m2 | Assumed Asbestos |
| Ceiling Structures/Linings | Flat AC Sheeting | 55m2 | Assumed Asbestos |

##### R3- Store

|                            |                  |      |                  |
|----------------------------|------------------|------|------------------|
| Ceiling Structures/Linings | Flat AC Sheeting | 10m2 | Assumed Asbestos |
|----------------------------|------------------|------|------------------|

### OS 602 16191 - Learning Unit - Standard With P.A.A. - Placement Date : 03-AUG-2010

**Note: This refurbished demountable may have asbestos present in remnant mastic in window frames.**

No Asbestos Found