



MEMO

TO: Phil Ho – Hutchinson Builders
FROM: Aleks Vasiloski
SUBJECT: Mainsbridge Public School – Flood Statement
OUR REF: 2304785T-CIV-WSP-CV-0001 to 0071 (Mainsbridge PS)
DATE: 24 May 2019

To Phil,

This statement is to confirm that the floor levels of all habitable rooms satisfy B28 and B29 of the relevant consent and are no lower than the 1% Annual Exceedance Probability flood level plus 500mm of freeboard in accordance with the following:

- Liverpool City Council Section 149(2)&(5) Certificate No. 4152, dated 31 January 2017, and
- Liverpool City Council Annexure to Section 149(5) Issue No. 2027198, dated 1 February 2017.

and as per our drawing set for MAINSBRIDGE SSP:

- WSP-CV-0001
- WSP-CV-0010
- WSP-CV-0011
- WSP-CV-0012
- WSP-CV-0020
- WSP-CV-0021
- WSP-CV-0040
- WSP-CV-0060
- WSP-CV-0070
- WSP-CV-0071

Kind regards,

Aleks Vasiloski
Engineer
Associate