

5 November 2018 Our Ref: 16SYA0024 L08_0 Design of Mech Plant & Equip Your Ref:

Attention: Jane McGarry

Conrad Gargett

Suite C3.18 / 22-36 Mountain Street Ultimo NSW 2007

Dear Jane, RE: Smalls Road Public School

Operational Noise - Design of Mechanical Plant and Equipment

TTM has reviewed the design of mechanical plant and equipment for the proposed Smalls Road Public School. The review includes the following:

- Specification and location of all mechanical plant and equipment
- Noise emission levels of all mechanical plant and equipment
- Comparison of emissions levels to the recommendations contained in the Noise Impact Report, prepared by TTM Consulting (Report Ref.: 16SYA0024 R06_0, dated 7 August 2017).



1. Specification and Location of Plant and Equipment

The specification of plant and equipment relevant to this review is summarised in Table 1.

	10	AC-GL-COM- 01/02	AC-L1-143-01	AC-L1-144-01	AC-L1-147-01	AC-L1-154-01
NUMBERS	5 OF	2				
CU UNIT I	NO	CU-GL-COM-01	CU-L1-143-01	CU-L1-144-01	CU-L1-147-01	CU-L1-154-01
LOCATION	N (Supplying)	GROUND LEVEL	LEVEL 1	LEVEL 1	LEVEL 1	LEVEL 1
SERVING		G-02	L1-41,42,43	L1-44	L1-47,49	L1-52,53,54
MANUFA	CTURER	DAIKIN	DAIKIN	DAIKIN	DAIKIN	DAIKIN
ТҮРЕ		Wall Mounted VRV IV S	Ducted Split	Ducted Split	Ducted Split	Ducted Split
MODEL	INDOOR	FXAQ63PVE	FDYQN200LBV1	FDYQN160LAV1	FDYQN200LBV1	FDYQN200LBV1
WODEL	OUTDOOR	RXYMQ6AV4A	RZQ200LY1	RZQ160LV1	RZQ200LY1	RZQ200LY1
SUPPLY A	IR (I/s)	317	750	500	750	750
OUTSIDE	AIR (l/s)	NA	225	220	225	225
EXTERNA	STATIC (Pa)	NA	200	200	200	200
TOTAL CO CAPACITY	OLING (kW)	7.2	17.5	13.6	17.5	17.5
SENSIBLE CAPACITY	COOLING (kW)	4.5	12.0	8.0	12.0	12.0
HEATING (kW)	CAPACITY	-	9.0	6.5	9.0	9.0
POWER IN	NPUT (kW)	4.1	7.0	4.7	7.0	7.0
APPLICAB CONTROL	LE S SECTION	COOLING ONLY				
NOTES/CO	DMMENTS		Unit to have provision for interlocking motion sensor e.g. Dry Contact T1/T2 Terminals.	Unit to have provision for interlocking motion sensor e.g. Dry Contact T1/T2 Terminals.	Unit to have provision for interlocking motion sensor e.g. Dry Contact T1/T2 Terminals.	Unit to have provision for interlocking motion sensor e.g. Dry Contact T1/T2 Terminals.

Table 1: Specification of plant and equipment



Outdoor condenser units are proposed as follows:

- Refer to Figure 1: One unit located on Ground floor, North section of the building, adjacent to Room G-02, referenced as follows:
 - CU-GL-COM-01
- 2. Refer to Figure 2: Four units located on the rooftop, West section of the building, referenced as follows:
 - CU-L1-143-01
 - CU-L1-144-01
 - CU-L1-147-01
 - CU-L1-154-01

Figure 1: Location of Condenser Units on Ground floor





Figure 2: Location of Condenser Units on rooftop





2. Comparison of Noise Emissions Levels and Criteria

The noise emissions levels of the condenser units have been compared to the applicable environmental noise criteria and are summarised in Table 2.

Table 2: Comparison of Noise Emissions Levels and Criteria

CU UNIT NO	CU-GL-COM-01	CU-L1-143-01	CU-L1-144-01	CU-L1-147-01	CU-L1-154-01
LOCATION (Refer to Figure 1 & Figure 2)	Ground Level	Rooftop	Rooftop	Rooftop	Rooftop
OUTDOOR SOUND PRESSURE LEVEL @1m*	57 dB(A)	57 dB(A)	59 dB(A)	57 dB(A)	57 dB(A)
NOISE LIMIT @1m#			72 dB(A) L _{eq}		
COMPLIANCE ACHIEVED?	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark
Note: *Refer to Appendix A - Specification Sheet # Refer to Section 7.3 of the Noise Impact Re	port prepared by TTM (Consulting, dated 7 th Ai	ugust 2017 (Report Ref	: 16SYA0024 R06 0)	

The noise emission levels are all less than the noise limit of 72 dB(A) by 13-15 dB. No additional noise mitigation measures are required in the design.

3. Conclusion

Based on the review of the proposed outdoor condenser units contained in this letter, noise emissions are not expected to exceed the noise criteria derived in the Noise Impact Report, prepared by TTM Consulting (Report Ref.: 16SYA0024 R06_0, dated 7 August 2017).

No additional noise mitigation measures are required in the design.

Yours sincerely,

Keshav Dhayam Lead Consultant TTM Consulting Pty Ltd



Appendix A Specification Sheet



MODEL			RXYMQ6AV4A
Power Supply			1-phase, 230-240 V, 50 Hz
		kcal/h	13,800
Cooling Capacity		Btu/h	54,600
		kW	16
		kcal/h	15,500
Heating Capacity		Btu/h	61,400
		kW	18
Dower Concumption	Cooling	LAM	4.14
Power Consumption	Heating	ĸvv	4.07
Capacity Control		%	16 to 100
Casing Colour			Ivory white (5Y7.5/1)
Comproseer	Туре		Hermetically sealed swing type
compressor	Motor Output	kW	3.5
Airflow Poto		l/s	1,767
Althow Rate		m³/min	106
Dimensions (HxWxD)		mm	1,345 x 900 x 320
Machine Weight		kg	104
Sound level (Cooling/H	leating)	dB(A)	55/56
Sound power		dB(A)	73
Operation Range	Cooling	°CDB	-5 to 46
Operation Range	Heating	°CWB	-20 to 15.5
Pofrigorant	Туре		R-410A
Kemgerant	Charge	kg	3.6
Diping consections	Liquid		ø9.5 (Flare)
Piping connections	Gas	mm	ø19.1 (Flare)
Connectable Units			Up to 9



PRODUCT SPECIFICATION

PRODUCT SPECIFICATION



FBO50E FBO50E FBO71E FB071E

INDOOR UNIT		FBOSOEVE	FBOGEVE	FB071EVE	FB0100EVE	FBO100EVE
and the second se	Cool (kW)	50	5.8	1.7	10.0	10.0
nated capacity	Heat (KW)	6.0	7.0	80	11.2	11.2
	Cool (kW)	32-5.6	3.2-6.0	3.2.8.0	5.0-11,2	5.0-11.2
capacity hange	Heat (kW)	35-7.0	35-8.0	35-9.0	5.1-12.8	5.1-12.8
Power Input	Cool (KW)	1.35	1.59	1.98	273	273
(Rated)	Heat (kW)	1.43	1,83	1.38	2.82	2.82
E.E.R./C.O.P	Cool/Heat	3.70/4.20	3.65/3.83	3.57/4.04	3.66/3.97	3.66/3.97
Airflow Rate (Rated)	l/s	300	300	383	233	203
Indoor Sound Level (H) @ 1.5m	dBA	SS.	35	38	8	38
Piping Length	(m)		65			12
Indoor Fan Speeds				H/M/L		
an	Indoor (mm)		245x1000x800		245x*	1400×800
Dimensions (HXWXD)	Outdoor (mm)	270x9	00/320	990x940x320	1430	(940x320
and the second se	Indoor (kg)	37	37	37	47	47
meign	Outdoor (kg)	15	25	22	108	108
Power Supply	V/Hz		1 Phase, 22	0-240V, 50Hz		3 Phase, 380-415V, 50Hz
Compressor Type		Ŧ	ermetically Sealed Swing Ty	be	Hermetically S	Sealed Scroll Type
Refrigerant				R410A		
	Liquid (mm)			9.5 (Flared)		
Pipe Sizes	Gas (mm)			15.3 (Flared)		
	Drain (mm)			10 25/00 32		
Supply Air Opening	mm (HxW, Flange)		176x792		17	341192
Return Air Opening	mm (HxW, Flange)		2084562		20	3x1352
	Cool (°CDB)			-5 to 46		
Outdoor Uperating Range	Heat (°CWB)			- 15 to 16		
EPA Sound Power Level	dBA	99	98	8	69	88
Outdoor Sound Level (H) @ 1m	Pressure dBA (C/H)	48	/50	50/52	53/55	23/22

1. Network Schwart Hart and Turning Currer an respected in conclusion with AS/NOS 2023 1.2 1. Network Schwart Hart and Turning Currer and respected in a conclusion with AS/NOS 2023 1.2 2. Network Internet 2013 (1975 CNI) Allowater and 2013 (2975 CNI) Bearing Mark and Peorls and Detraining Hart and Active Currer 2013 (1975 CNI) Bearing Mark and Peorls and Detraining Hart and Active Currer 2013 (1975 CNI) 1. Network of Active 1. Network Active A

<u>0</u>



		FDYON100LBV1			FDYONNEOLAV1	FDY0M180LBV1	TVB/002M0Y0F	
							N002028	
Cool (kW)	1.1	10.0	12.5	14.0	15.5	18.0	20.0	23.5
Heat (kW)	32	12.5	15.0	16.5	18.0	20.0	22.4	26.8
Cool (kW)	3.2-7.1	5.0-10.0	5.7-12.5	6.2-14.0	7.3-15.5	10.8-18.0	12.0-20.0	15.0-23.5
Heat (kW)	35-75	5.1-12.5	6.0-15.0	6.2-16.5	7.3-18.0	12.0-20.0	13.4-22.4	16.8-26.8
Cool (kW)	2.25	3.12	4.14	4.65	4.97	5.88	644	7.85
Heat (kW)	2.29	3.58	4.48	4.48	4.83	6.15	7.00	8.47
Cool/Heat	3.15/3.27	3.21/3.48	3.02/3.35	3:01/3.68	3.12/3.73	3.06/3.25	3.11/3.20	2.99/3.16
1/S	566	800	840	1000	1120	1180	1200	1400
dBA	41	44	45	48.5	505	45.5	44	49.5
(m)	20			- T			8	
				Η	-T/M			
Indoor (mm)	300x1090x863	360x1157x699		360x1498x899		500412305470	500x14	30x970
Outdoor (mm)	770x900x320	990x940x320	11720x900x320	143049	10x320		1680x930x765	
Indoor (kg)	40	44	61	19	61	78	98	32
Outdoor (kg)	84	75	88	108	108	192	192	193
V/Hz		1.9	hase, 220-240V, 5	0Hz			3 Phase, 415v, 50H	
	Hermetically Sealed Swing Type			Нетте	tically Sealed Sor	oli Type		
				R	18A			
Liquid (mm)			9.5 (Flared)				9.5 (Brazed)	
Gas (mm)			15.9 (Flared)			19.1 (B	razed)	22.2 (Brazed)
Drain (mm)			10 25 / 00 32			BSP	3/4 inch Internal TI	rread
mm (HxW, Flange)	185x852	245x852		243x1152		376	827	376×938
mm (0val)	1x400 (0val)		2x400	(Dvail)		350x918 (Flange)	350x1118	(Flange)
Cool (°CDB)			-5 to 46				-5 10 43	
Heat ("CWB)			-15 to 16				-20 to 16	
dBA	99	8						
Pressure dBA (C/H)	49/51	51/	22	54/56	57/58	23/	23	85/28
	Cost (MM) Heat (MM) Heat (MM) Heat (MM) Heat (MM) Heat (MM) Cost(Heat Heat (MM) Heat (Heat Heat (Heat Heat (Heat Heat (Heat) Heat (Heat) H	Continuit Continuit Cont (NV) 7.1 Cont (NV) 32.75 Heat (NV) 2.72 Heat (NV) 2.73 Heat (NV) 30.01 Outhor (nm) 00.000 Heat (NV) 30.01 Outhor (nm) 2.70 Outhor (nm) 2.70 Uthick (nm) 9.70 Data (nm) 2.60 Protein (nm) 2.60 Protein (nm) 10.01 Outhor (nm) 10.01 Data (nm)	Referentian Referentian Reference Reference 71 100 Reference 73 255 Cele (WW) 3755 251 Reference 3755 312 Reference 319,110 32 Reference 319,120 312 Reference 319,120 310,150 Reference 310,150 310,150 Reference 30,150 31,150 <	ACCOLIDIO: ACCOLID	Antionalizatio alla diselexiomalizationalizationalizationalizationalizationaliz	International (Controlling) International (Controling) International (Controlling) <th< td=""><td>International and productant formational productant productant productant formational productant formational produ</td><td>OTOCULERI ROTINGTAMIN ROTINGTAMIN</td></th<>	International and productant formational productant productant productant formational productant formational produ	OTOCULERI ROTINGTAMIN ROTINGTAMIN

Mone: 1. The Neutrol Capacity, Proved Years of Rurring Current are measured in a pacedonour with AS/NGS 3022 1.2 children yooks memor 27 "CORIN" YONE, Oxobiom memor 29" CORING 707" YONE Housing process means 27" CORING TOWN control memory. 2020; RURG Housing and Proceeding Core of the Core Housing and Accord Devices and determined in an antichic children and my differ rows for on the core is functioned.

30