


Wee Waa High School

Monthly Noise Monitoring Sept'23


Monitoring Devices

Date Range 01 Sep 2023 - 09 Sep 2023

| Device Serial | Monitoring Points |
|---------------|-------------------|
| HEX-000168 | 41 George St |



Noise Monitoring Statistics



Site Activities within proximity to 41 George St

- George Street civil works
- Truck movements and deliveries
- Structural steel installation around building E
- Roof installation around building E
- Balustrade installation around building E
- George Street pit pour

Machinery Used

- Excavator
- Water Cart
- Franna
- Trucks

Noise Monitoring Statistics

Average daily L_{Aeq} monitored for the month was 49dB.
 No exceedance of Day Noise Limit (DNL) of 75dB.

| dB | ▼ 41 George St | | |
|---------|----------------|------------|------------|
| | L_{A90} | L_{Amax} | L_{Amin} |
| Day | 45 | 98 | 29 |
| Evening | 37 | 78 | 28 |
| Night | 34 | 75 | 26 |


Noise Monitoring Graphs

15 min averages

Settings

L_{Aeq}

01 Sep 2023 - 09 Sep 2023




15 min averages

Settings

L_{Aeq}

10 Sep 2023 - 16 Sep 2023




15 min averages


Settings

L_{Aeq}

17 Sep 2023 - 23 Sep 2023



dB



Devices

— 41 George St

Thresholds

---- 49 Site Hours NML

---- 75 Day Noise Limit

Other

■ Potentially weather affected periods

▨ Out of Hours