

<b>SCHOOL:</b>	<b>Airds High School (8493)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Campbelltown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Welding Area - (10.3 SQM)	Not Applicable	Circulation or storage space.
B001 - R0015 - Metal Technology L.S. - (71.66 SQM) - Teaching Space: 1	● Student Space (44)	
B001 - R0016 - Metal Technology L.S. - (71.23 SQM) - Teaching Space: 1	● Student Space (44)	
B001 - R0017 - Metal Technology Bay - (43.38 SQM)	Not Applicable	Circulation or storage space.
B001 - R0021 - Metal Technology Bay - (84.63 SQM)	Not Applicable	Circulation or storage space.
B001 - R0022 - Art Learning Space - (85.91 SQM) - Teaching Space: 1	● Student Space (108)	
B001 - R1001 - Wood Technology L.S. - (83.2 SQM) - Teaching Space: 1	● Student Space (58)	
B001 - R1004 - Design L.S. - (52.35 SQM) - Teaching Space: 1	● Student Space (47)	
B001 - R1005 - Staff Study - (25.74 SQM)	○ Office (6)	
B001 - R1006 - Design L.S. - (52.65 SQM) - Teaching Space: 1	● Student Space (47)	
B001 - R1009 - Wood Technology L.S. - (82.92 SQM) - Teaching Space: 1	● Student Space (58)	
B001 - R1013 - Movement - (52.13 SQM)	Not Applicable	Circulation or storage space.
B002 - R0031 - Movement - (53.1 SQM)	Not Applicable	Circulation or storage space.
B002 - R0032 - Movement - (85.05 SQM)	Not Applicable	Circulation or storage space.
B002 - R0036 - Materials Technology L.S. - (147.66 SQM) - Teaching Space: 1	● Student Space (82)	
B002 - R0041 - Multi-Purpose Space - (148.27 SQM)	● Student Space (68)	
B002 - R0043 - Student Canteen - (54.68 SQM)	Not Applicable	Circulation or storage space.
B002 - R1009 - Movement - (66.01 SQM)	Not Applicable	Circulation or storage space.
B003 - R0002 - Food Technology L.S. - (82.38 SQM) - Teaching Space: 1	● Student Space (54)	
B003 - R0008 - Textiles Technology L.S. - (65.74 SQM) - Teaching Space: 1	● Student Space (54)	
B003 - R0011 - Staff Study - (32.16 SQM)	○ Office (8)	
B003 - R0016 - Movement - (73.66 SQM)	Not Applicable	Circulation or storage space.
B003 - R0017 - Food/Research Space - (43.41 SQM)	Not Applicable	Circulation or storage space.
B003 - R0018 - Food Technology L.S. - (81.74 SQM) - Teaching Space: 1	● Student Space (37)	
B003 - R0019 - Preparation - Materials - (21.96 SQM)	Not Applicable	Circulation or storage space.
B003 - R1001 - Textiles Technology L.S. - (65.31 SQM) - Teaching Space: 1	● Student Space (54)	
B003 - R1002 - Music Learning Space - (131.01 SQM) - Teaching Space: 1	● Student Space (107)	
B003 - R1003 - Staff Study - (32.66 SQM)	○ Office (8)	
B003 - R1004 - Music Learning Space - (65.58 SQM) - Teaching Space: 1	● Student Space (54)	
B003 - R1005 - Dark Room - (13.43 SQM)	○ Office (3)	
B003 - R1006 - Art Learning Space - (65.76 SQM) - Teaching Space: 1	● Student Space (70)	
B003 - R1007 - Art Learning Space - (65.76 SQM) - Teaching Space: 1	● Student Space (70)	
B003 - R1009 - Movement - (77.17 SQM)	Not Applicable	Circulation or storage space.
B004 - M1001 - Multi Media Workshop - (64.03 SQM)	Not Applicable	Circulation or storage space.
B004 - M1002 - Study Space - (85.4 SQM)	Not Applicable	Circulation or storage space.
B004 - M1003 - Staff Study - (21.32 SQM)	○ Office (5)	
B004 - R0001 - Laboratory L.S. - (89.31 SQM) - Teaching Space: 1	● Student Space (56)	
B004 - R0002 - Staff Study - (91.2 SQM)	○ Office (22)	
B004 - R0003 - Preparation - Science - (49.42 SQM)	Not Applicable	Circulation or storage space.
B004 - R0006 - Laboratory L.S. - (89.41 SQM) - Teaching Space: 1	● Student Space (52)	
B004 - R0007 - Preparation - Science - (49.28 SQM)	Not Applicable	Circulation or storage space.
B004 - R0008 - Movement - (58.22 SQM)	Not Applicable	Circulation or storage space.
B004 - R0019 - Laboratory L.S. - (90.85 SQM) - Teaching Space: 1	● Student Space (62)	
B004 - R1002 - Tea Room - (14.32 SQM)	Not Applicable	Circulation or storage space.
B004 - R1013 - Staff Study - (27.67 SQM)	○ Office (6)	
B004 - R1015 - Main Entry - (29.21 SQM)	Not Applicable	Circulation or storage space.
B004 - R1016 - Main Area - (344.84 SQM)	Not Applicable	Circulation or storage space.
B004 - R1018 - Interview/Office - Type 1 - (13.09 SQM)	○ Office (3)	
B005 - R0012 - Principal Office - (22.97 SQM)	○ Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B005 - R0015 - Deputy Principal Office - (20.14 SQM)	Office (5)	
B005 - R0016 - Deputy Principal Office - (16.07 SQM)	Office (4)	
B005 - R0025 - Commonroom - (80.08 SQM)	Office (20)	
B005 - R0026 - Tea Room - (11.6 SQM)	Not Applicable	Circulation or storage space.
B005 - R0033 - Deputy Principal Office - (18.18 SQM)	Office (4)	
B005 - R0034 - Principal Office - (16.87 SQM)	Office (4)	
B005 - R0035 - Deputy Principal Office - (18.39 SQM)	Office (4)	
B005 - R0037 - Movement - (19.69 SQM)	Not Applicable	Circulation or storage space.
B005 - R0039 - Movement - (61.71 SQM)	Not Applicable	Circulation or storage space.
B005 - R0040 - Administration - Clerical - (64.8 SQM)	Office (16)	
B005 - R0041 - Movement - (18.39 SQM)	Not Applicable	Circulation or storage space.
B005 - R1001 - General Learning Space - (53.74 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1002 - Computer Learning Space - (53.52 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1005 - General Learning Space - (59.71 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1007 - General Learning Space - (59.93 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1008 - General Learning Space - (53.96 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1009 - General Learning Space - (40.58 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1010 - Staff Study - (41.01 SQM)	Office (10)	
B005 - R1012 - Tea Room - (17.93 SQM)	Not Applicable	Circulation or storage space.
B005 - R1013 - General Learning Space - (40.75 SQM) - Teaching Space: 1	Student Space (36)	
B005 - R1014 - Movement - (53.63 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - General Assistants - (22.48 SQM)	Office (5)	
B006 - R0003 - Laboratory L.S. - (90.52 SQM) - Teaching Space: 1	Student Space (61)	
B006 - R0004 - Preparation - Science - (49.34 SQM)	Not Applicable	Circulation or storage space.
B006 - R0005 - Seminar/Technology Space - (90.71 SQM)	Office (22)	
B006 - R1004 - General Learning Space - (90.71 SQM) - Teaching Space: 1	Student Space (61)	
B006 - R1006 - Seminar/Technology Space - (90.71 SQM)	Office (22)	
B006 - R1013 - Craft Room - (29.71 SQM)	Office (7)	
B007 - R0001 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (61)	
B007 - R0002 - General Learning Space - (52.42 SQM) - Teaching Space: 1	Student Space (61)	
B007 - R0003 - Staff Study - (26.28 SQM)	Office (6)	
B007 - R0004 - Performance Workspace - (53.89 SQM) - Teaching Space: 1	Student Space (63)	
B007 - R0006 - Interview/Office - Type 1 - (10.98 SQM)	Office (2)	
B007 - R0012 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (63)	
B007 - R0013 - General Learning Space - (53.74 SQM) - Teaching Space: 1	Student Space (63)	
B007 - R0015 - General Learning Space - (52.21 SQM) - Teaching Space: 1	Student Space (51)	
B007 - R0016 - Movement - (40.3 SQM)	Not Applicable	Circulation or storage space.
B007 - R0017 - Movement - (29.66 SQM)	Not Applicable	Circulation or storage space.
B007 - R1001 - Computer Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (20)	
B007 - R1002 - General Learning Space - (53.88 SQM) - Teaching Space: 1	Student Space (20)	
B007 - R1003 - General Learning Space - (54.55 SQM) - Teaching Space: 1	Student Space (20)	
B007 - R1004 - General Learning Space - (54.55 SQM) - Teaching Space: 1	Student Space (35)	
B007 - R1009 - General Learning Space - (53.3 SQM) - Teaching Space: 1	Student Space (35)	
B007 - R1011 - General Learning Space - (53.6 SQM) - Teaching Space: 1	Student Space (35)	
B007 - R1012 - General Learning Space - (53.82 SQM) - Teaching Space: 1	Student Space (20)	
B007 - R1014 - Movement - (18.33 SQM)	Not Applicable	Circulation or storage space.
B007 - R1015 - Movement - (26.4 SQM)	Not Applicable	Circulation or storage space.
B007 - R1016 - Staff Study - (52.15 SQM)	Office (13)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B008 - R0002 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (35)	
B008 - R0003 - Staff Study - (24.83 SQM)	● Office (6)	
B008 - R0004 - General Learning Space - (53.67 SQM) - Teaching Space: 1	● Student Space (59)	
B008 - R0006 - General Learning Space - (53.74 SQM) - Teaching Space: 1	● Student Space (59)	
B008 - R0007 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (59)	
B008 - R0013 - Tea Room - (10.88 SQM)	Not Applicable	Circulation or storage space.
B008 - R0016 - Special Learning Space - (27.34 SQM) - Teaching Space: 1	● Student Space (48)	
B008 - R0019 - Movement - (78.72 SQM)	Not Applicable	Circulation or storage space.
B008 - R1001 - General Learning Space - (53.88 SQM) - Teaching Space: 1	● Student Space (20)	
B008 - R1002 - Computer Learning Space - (53.08 SQM) - Teaching Space: 1	● Student Space (20)	
B008 - R1003 - Staff Study - (18.39 SQM)	● Office (4)	
B008 - R1004 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (21)	
B008 - R1005 - General Learning Space - (53.74 SQM) - Teaching Space: 1	● Student Space (36)	
B008 - R1007 - General Learning Space - (53.38 SQM) - Teaching Space: 1	● Student Space (35)	
B008 - R1012 - General Learning Space - (54.63 SQM) - Teaching Space: 1	● Student Space (36)	
B008 - R1013 - General Learning Space - (54.7 SQM) - Teaching Space: 1	● Student Space (21)	
B008 - R1014 - Movement - (18.3 SQM)	Not Applicable	Circulation or storage space.
B008 - R1015 - Movement - (27.58 SQM)	Not Applicable	Circulation or storage space.
B008 - R1017 - Staff Study - (50.91 SQM)	● Office (12)	
B009 - R0006 - Movement - (7.19 SQM)	Not Applicable	Circulation or storage space.
B009 - R0009 - Stage - (59.57 SQM)	Not Applicable	Circulation or storage space.
B009 - R0010 - Movement - (25.23 SQM)	Not Applicable	Circulation or storage space.
B009 - R0013 - Staff Kitchen - (13.62 SQM)	● Office (3)	
B009 - R0017 - Multi-Purpose Space - (486.89 SQM)	● Student Space (1244)	