


SCHOOL:	Alexandria Park Community School (8556)
AMU REGION:	Sydney
STATE ELECTORATE:	Heffron
LOCAL GOVERNMENT AREA:	Sydney

8556 - Alexandria Park Community School
Site Plan (12244)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0011 - Study Space - (15 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Movement - (5.98 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Movement - (8.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Raised Platform - (94.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Movement - (8.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (5.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Movement - (5.07 SQM)	Not Applicable	Circulation or storage space.
B00C - R0032 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Communal Space - (421.34 SQM)	● Student Space (195)	
B00C - R0054 - Movement - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R0057 - Movement - (23.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0062 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - General Assistants - (35.06 SQM)	● Office (8)	
BOB1 - R0002 - Public Entry - (79.18 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0004 - Movement - (16.28 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0005 - Kitchen - Type 1 - (118.79 SQM)	● Student Space (55)	
BOB1 - R0006 - Food/Research Space - (35.79 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0007 - Food/Research Space - (25.49 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0008 - Movement - (17.01 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0009 - Home Base - (67.52 SQM) - Teaching Space: 1	● Student Space (37)	
BOB1 - R0011 - Seminar - (21.94 SQM)	● Office (5)	
BOB1 - R0012 - Staff Study - (10.63 SQM)	● Office (2)	
BOB1 - R0016 - Presentation Area - (55.92 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0017 - Kitchen - Type 1 - (97.1 SQM)	● Student Space (45)	
BOB1 - R0018 - Preparation - (38.74 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0029 - Movement - (9.01 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0031 - Canteen - (96.89 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0033 - Movement - (27.44 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0034 - Movement - (20.66 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0039 - Main Entry - (74.14 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0040 - Interview/Meeting - (15.98 SQM)	● Office (3)	
BOB1 - R0041 - Tiered Learning Area - (28.51 SQM)	● Student Space (13)	
BOB1 - R0042 - Practical Activities - (24.43 SQM)	● Student Space (11)	
BOB1 - R0043 - Reading Area - (164.57 SQM)	● Student Space (76)	
BOB1 - R0049 - Interview/Office - Type 1 - (12.71 SQM)	● Office (3)	
BOB1 - R0051 - Seminar - (12.42 SQM)	● Office (3)	
BOB1 - R0052 - Movement - (5.23 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R0070 - Home Base - (69.27 SQM) - Teaching Space: 1	● Student Space (38)	
BOB1 - R0072 - Tiered Learning Area - (27.27 SQM)	● Student Space (12)	
BOB1 - R0075 - Movement - (12.78 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1002 - General Learning Space-I.E.C. - (10.26 SQM) - Teaching Space: 1	● Student Space (5)	
BOB1 - R1003 - General Learning Space-I.E.C. - (15.21 SQM) - Teaching Space: 1	● Student Space (8)	
BOB1 - R1004 - Breakout Area - (35.27 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1005 - Performance Workshop - (94.67 SQM)	● Student Space (43)	
BOB1 - R1006 - Practical Activities - (60.54 SQM)	● Student Space (28)	
BOB1 - R1007 - Outdoor Learning Area - (20.18 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1008 - Performance Workshop - (89.97 SQM)	● Student Space (41)	
BOB1 - R1010 - General Learning Space-I.E.C. - (87.57 SQM) - Teaching Space: 1	● Student Space (48)	
BOB1 - R1011 - Music Learning Space - (57.95 SQM) - Teaching Space: 1	● Student Space (31)	
BOB1 - R1013 - Music Learning Space - (11.99 SQM) - Teaching Space: 1	● Student Space (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOB1 - R1014 - Music Learning Space - (13.24 SQM) - Teaching Space: 1	● Student Space (7)	
BOB1 - R1015 - Study Space - (13.49 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1016 - Seminar - Type 1 - (22.03 SQM)	● Office (5)	
BOB1 - R1019 - Movement - (59.33 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1023 - Staff Study - (11.64 SQM)	● Office (2)	
BOB1 - R1024 - Breakout Area - (23.23 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1028 - Movement - (84.71 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1031 - Outdoor Learning Area - (29.97 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1033 - Entry - (25.15 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1038 - Study Space - (20.71 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1040 - Interview/Meeting - (10.82 SQM)	● Office (2)	
BOB1 - R1041 - Seminar - (9.59 SQM)	● Office (2)	
BOB1 - R1042 - Entry - (32.22 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1044 - Tiered Learning Area - (12.93 SQM)	● Student Space (5)	
BOB1 - R1045 - Practical Activities - (75.84 SQM)	● Student Space (35)	
BOB1 - R1046 - Senior Study - (46.98 SQM)	● Office (11)	
BOB1 - R1047 - Computer Learning Space - (38.23 SQM) - Teaching Space: 1	● Student Space (20)	
BOB1 - R1055 - Reading Area - (283.75 SQM)	● Student Space (131)	
BOB1 - R1057 - Movement - (21.83 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R1060 - Movement - (17.71 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2002 - Staff Study - (55.58 SQM)	● Office (13)	
BOB1 - R2007 - Outdoor Learning Area - (94.38 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2008 - Outdoor Learning Area - (92.88 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2009 - Welding Area - (6.25 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2010 - Wood Technology Bay - (119.47 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2012 - Workshop Area - (88.03 SQM)	● Student Space (40)	
BOB1 - R2013 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2015 - Clerical Office/Workroom - (10.15 SQM)	● Office (2)	
BOB1 - R2016 - Computer Learning Space - (57.63 SQM) - Teaching Space: 1	● Student Space (31)	
BOB1 - R2017 - Staff Study - (5.89 SQM)	● Office (1)	
BOB1 - R2018 - Study Space - (10.36 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2019 - General Learning Space - (54.38 SQM) - Teaching Space: 1	● Student Space (30)	
BOB1 - R2020 - Clerical Office/Workroom - (10.86 SQM)	● Office (2)	
BOB1 - R2021 - Movement - (212.19 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2022 - Clerical Office/Workroom - (9.37 SQM)	● Office (2)	
BOB1 - R2024 - Movement - (8.74 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2027 - Movement - (73.35 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2029 - Practical Activity Area - (35.83 SQM)	● Student Space (16)	
BOB1 - R2030 - Art Learning Space-I.E.C. - (57.29 SQM) - Teaching Space: 1	● Student Space (31)	
BOB1 - R2031 - Interview - (6.57 SQM)	● Office (1)	
BOB1 - R2033 - Movement - (36.9 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2034 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2039 - General Learning Space - (188.05 SQM) - Teaching Space: 1	● Student Space (104)	
BOB1 - R2041 - Seminar - Type 1 - (23.45 SQM)	● Office (5)	
BOB1 - R2042 - Interview/Meeting - (11.01 SQM)	● Office (2)	
BOB1 - R2049 - Seminar/Study - (21.12 SQM)	● Office (5)	
BOB1 - R2050 - Interview/Meeting - (8.96 SQM)	● Office (2)	
BOB1 - R2051 - Outdoor Learning Area - (39.56 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2052 - General Learning Space - Type 1 - (182.51 SQM) - Teaching Space: 1	● Student Space (101)	
BOB1 - R2053 - Practical Activity Area - (54.57 SQM)	● Student Space (25)	
BOB1 - R2057 - Presentation Area - (54.34 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOB1 - R2058 - Presentation Area - (60.62 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R2066 - Art Learning Space - (55.12 SQM) - Teaching Space: 1	● Student Space (30)	
BOB1 - R2067 - Interview/Meeting - (7.3 SQM)	○ Office (1)	
BOB1 - R3002 - Staff Room - (55.62 SQM)	○ Office (13)	
BOB1 - R3003 - Movement - (9.39 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3006 - Isolation Space - (10.02 SQM)	○ Office (2)	
BOB1 - R3007 - General Learning Space-I.E.C. - (56.67 SQM) - Teaching Space: 1	● Student Space (31)	
BOB1 - R3008 - Outdoor Learning Area - (117.64 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3009 - Presentation Area - (58.73 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3011 - Practical Activity Area - (7.03 SQM)	● Student Space (3)	
BOB1 - R3013 - Movement - (7.58 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3015 - Science Laboratory - (85.45 SQM)	● Student Space (39)	
BOB1 - R3016 - Science Laboratory - (98.21 SQM)	● Student Space (45)	
BOB1 - R3023 - General Learning Space - (52.62 SQM) - Teaching Space: 1	● Student Space (29)	
BOB1 - R3024 - Clerical Office/Workroom - (16.65 SQM)	○ Office (4)	
BOB1 - R3027 - Clerical Office/Workroom - (10.05 SQM)	○ Office (2)	
BOB1 - R3028 - Movement - (283.03 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3031 - Staff Study - (40.61 SQM)	○ Office (10)	
BOB1 - R3034 - Movement - (13.4 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3035 - General Learning Space - (47.15 SQM) - Teaching Space: 1	● Student Space (25)	
BOB1 - R3039 - General Learning Space - (36.11 SQM) - Teaching Space: 1	● Student Space (19)	
BOB1 - R3041 - General Learning Space - (48.83 SQM) - Teaching Space: 1	● Student Space (26)	
BOB1 - R3042 - Isolation Space - (8.76 SQM)	○ Office (2)	
BOB1 - R3043 - Outdoor Learning Area - (51.6 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3044 - Outdoor Learning Area - (59.29 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3045 - Study Space - (12.79 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3048 - Science Laboratory - (104.53 SQM)	● Student Space (48)	
BOB1 - R3050 - Seminar - (19.46 SQM)	○ Office (4)	
BOB1 - R3051 - Preparation - Science - (66 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3052 - Presentation Area - (57.64 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3053 - Staff Room - (67.04 SQM)	○ Office (16)	
BOB1 - R3054 - Movement - (51.26 SQM)	Not Applicable	Circulation or storage space.
BOB1 - R3058 - Interview/Meeting - (10.03 SQM)	○ Office (2)	
BOC1 - R0003 - Home Base - (59.66 SQM) - Teaching Space: 1	● Student Space (32)	
BOC1 - R0004 - Practical Activities - 2hb - (48.71 SQM)	● Student Space (22)	
BOC1 - R0007 - Home Base - (64.76 SQM) - Teaching Space: 1	● Student Space (36)	
BOC1 - R0010 - Home Base X2 - (55.56 SQM) - Teaching Space: 2	● Student Space (30)	
BOC1 - R0011 - Practical Activities - 2hb - (55.99 SQM)	● Student Space (25)	
BOC1 - R0012 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (32)	
BOC1 - R0014 - Home Base - (46.45 SQM) - Teaching Space: 1	● Student Space (25)	
BOC1 - R0015 - Withdrawal Space - 1hb - (11.33 SQM)	● Student Space (5)	
BOC1 - R0016 - Presentation Area - (48.31 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0019 - Staff Study - (21.81 SQM)	○ Office (5)	
BOC1 - R0020 - Collaboration Space - (55.05 SQM)	● Student Space (25)	
BOC1 - R0022 - Withdrawal Space - 1hb - (12.59 SQM)	● Student Space (5)	
BOC1 - R0027 - Withdrawal Space - 1hb - (11.6 SQM)	● Student Space (5)	
BOC1 - R0028 - Home Base - (55.26 SQM) - Teaching Space: 1	● Student Space (30)	
BOC1 - R0029 - Presentation Area - (50.51 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0031 - Staff Study - (21.46 SQM)	○ Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC1 - R0032 - Home Base - (51.47 SQM) - Teaching Space: 1	Student Space (28)	
BOC1 - R0033 - Withdrawal Space - 1hb - (15.14 SQM)	Student Space (7)	
BOC1 - R1002 - Staff Study - (12.43 SQM)	Office (3)	
BOC1 - R1004 - Collaboration Space - (54.1 SQM)	Student Space (25)	
BOC1 - R1007 - Collaboration Space - (71.74 SQM)	Student Space (33)	
BOC1 - R1010 - Practical Activities - (42.87 SQM)	Student Space (19)	
BOC1 - R1011 - Practical Activities - (61.97 SQM)	Student Space (28)	
BOC1 - R1012 - Collaboration Space - (73.36 SQM)	Student Space (34)	
BOC1 - R1015 - Staff Study - (14.07 SQM)	Office (3)	
BOC1 - R1016 - Collaboration Space - (54.9 SQM)	Student Space (25)	
BOC1 - R1017 - Withdrawal - M - (11.99 SQM)	Student Space (5)	
BOC1 - R1018 - Withdrawal - M - (11.6 SQM)	Student Space (5)	
BOC1 - R1023 - Presentation Area - (64.83 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1025 - Presentation Area - (61.7 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1028 - Collaboration Space - (55.93 SQM)	Student Space (25)	
BOC1 - R1029 - Withdrawal Space - 1hb - (11.31 SQM)	Student Space (5)	
BOC1 - R1030 - Staff Study - (13.68 SQM)	Office (3)	
BOC1 - R1031 - Withdrawal Space - 1hb - (13.35 SQM)	Student Space (6)	
BOC1 - R1033 - Presentation Area - (57.26 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1035 - Withdrawal Space - 1hb - (11.57 SQM)	Student Space (5)	
BOC1 - R1036 - Withdrawal Space - 1hb - (12.79 SQM)	Student Space (5)	
BOC1 - R1037 - Home Base X2 - (68.3 SQM) - Teaching Space: 2	Student Space (37)	
BOC1 - R2002 - Home Base X2 - (159.42 SQM) - Teaching Space: 2	Student Space (88)	
BOC1 - R2004 - Practical Activities - 2hb - (51.88 SQM)	Student Space (24)	
BOC1 - R2007 - Collaboration Space - (66.68 SQM)	Student Space (30)	
BOC1 - R2011 - Home Base X2 - (161.66 SQM) - Teaching Space: 2	Student Space (90)	
BOC1 - R2014 - Practical Activities - 2hb - (55.54 SQM)	Student Space (25)	
BOC1 - R2015 - Collaboration Space - (60.38 SQM)	Student Space (28)	
BOC1 - R2016 - Withdrawal Space - 1hb - (12.34 SQM)	Student Space (5)	
BOC1 - R2017 - Presentation Area - (47.21 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R2020 - Withdrawal Space - 1hb - (12.85 SQM)	Student Space (5)	
BOC1 - R2021 - Staff Study - (14.45 SQM)	Office (3)	
BOC1 - R2025 - Withdrawal Space - 1hb - (11.47 SQM)	Student Space (5)	
BOC1 - R2026 - Staff Study - (24.67 SQM)	Office (6)	
BOC1 - R2029 - Withdrawal Space - 1hb - (12.37 SQM)	Student Space (5)	
BOC1 - R2030 - Presentation Area - (51.72 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R3018 - Outdoor Learning Area - (705.44 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0005 - Collaboration Space - (52.11 SQM)	Student Space (24)	
BOD1 - R0006 - Practical Activities - 4hb - (47.93 SQM)	Student Space (22)	
BOD1 - R0007 - Collaboration Space - (53.33 SQM)	Student Space (24)	
BOD1 - R0008 - Staff Study - (17.98 SQM)	Office (4)	
BOD1 - R0010 - Home Base - (48.02 SQM) - Teaching Space: 1	Student Space (26)	
BOD1 - R0011 - Withdrawal Space - 2hb - (10.93 SQM)	Student Space (5)	
BOD1 - R0012 - Presentation Area - (46.44 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0013 - Withdrawal Space - 2hb - (9.14 SQM)	Student Space (4)	
BOD1 - R0014 - Home Base - (59.4 SQM) - Teaching Space: 1	Student Space (32)	
BOD1 - R0019 - Home Base X4 - (259.69 SQM) - Teaching Space: 4	Student Space (144)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0D1 - R0023 - Practical Activities Area - 2 G.L.S. - (47.3 SQM)	● Student Space (21)	
B0D1 - R0025 - Interview/Meeting - (8.83 SQM)	● Office (2)	
B0D1 - R0026 - Interview/Meeting - (8.99 SQM)	● Office (2)	
B0D1 - R0037 - Staff Study - (13.06 SQM)	● Office (3)	
B0D1 - R0038 - Interview/Meeting - (8.65 SQM)	● Office (2)	
B0D1 - R1003 - Outdoor Learning Area - (239.47 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R1005 - Collaboration Space - (69.19 SQM)	● Student Space (32)	
B0D1 - R1006 - Staff Study - (25.76 SQM)	● Office (6)	
B0D1 - R1007 - Practical Activities - S - 2hb - (42.35 SQM)	● Student Space (19)	
B0D1 - R1010 - Withdrawal Space - 1hb - (12.17 SQM)	● Student Space (5)	
B0D1 - R1011 - Home Base - (56.21 SQM) - Teaching Space: 1	● Student Space (31)	
B0D1 - R1014 - Presentation Area - (44.18 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R1015 - Withdrawal Space - 1hb - (8.15 SQM)	● Student Space (3)	
B0D1 - R1017 - Collaboration Space - (69.3 SQM)	● Student Space (32)	
B0D1 - R1021 - Practical Activities - S - 2hb - (48.74 SQM)	● Student Space (22)	
B0D1 - R1024 - Home Base X2 - (178 SQM) - Teaching Space: 2	● Student Space (98)	
B0D1 - R1027 - Withdrawal Space - 1hb - (17.96 SQM)	● Student Space (8)	
B0D1 - R1028 - Staff Study - (16.13 SQM)	● Office (4)	
B0D1 - R1029 - Withdrawal Space - 1hb - (13.13 SQM)	● Student Space (6)	
B0D1 - R1030 - Presentation Area - (51.16 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R2006 - Collaboration Space - (54.98 SQM)	● Student Space (25)	
B0D1 - R2007 - Practical Activities - 2hb - (63.16 SQM)	● Student Space (29)	
B0D1 - R2008 - Home Base X3 - (159.51 SQM) - Teaching Space: 3	● Student Space (89)	
B0D1 - R2010 - Withdrawal Space - 1hb - (11.4 SQM)	● Student Space (5)	
B0D1 - R2011 - Staff Study - (21.11 SQM)	● Office (5)	
B0D1 - R2015 - Withdrawal Space - 1hb - (9.54 SQM)	● Student Space (4)	
B0D1 - R2017 - Presentation Area - (48.54 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R2018 - Collaboration Space - (63.44 SQM)	● Student Space (29)	
B0D1 - R2023 - Practical Activities - S - 2hb - (59.45 SQM)	● Student Space (27)	
B0D1 - R2025 - Special Programs Room - Type 1 - (7.86 SQM)	● Student Space (3)	
B0D1 - R2026 - Home Base X3 - (166.7 SQM) - Teaching Space: 3	● Student Space (92)	
B0D1 - R2027 - Withdrawal Space - 1hb - (18.42 SQM)	● Student Space (8)	
B0D1 - R2028 - Staff Study - (16.29 SQM)	● Office (4)	
B0D1 - R2029 - Withdrawal Space - 1hb - (12.13 SQM)	● Student Space (5)	
B0D1 - R2030 - Presentation Area - (51.32 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R3001 - Outdoor Learning Area - (851.77 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0001 - Movement - (21.56 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0002 - Home Base - (50.9 SQM)	● Student Space (23)	
B0DD - R0003 - Practical Activities - 1hb - (16.3 SQM)	● Student Space (7)	
B0DD - R0004 - Home Base - (51.79 SQM)	● Student Space (24)	
B0DD - R0008 - Home Base - (46.32 SQM)	● Student Space (21)	
B0DD - R0018 - Movement - (25.07 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0022 - Movement - (28.97 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0023 - Movement - (68.27 SQM)	Not Applicable	Circulation or storage space.
B0DD - R0024 - General Learning Space - (57.02 SQM)	● Student Space (26)	
B0DD - R0025 - General Learning Space - (42.65 SQM)	● Student Space (19)	
B0DD - R0026 - Computer Learning Space - (49.71 SQM)	● Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BODD - R0027 - Computer Learning Space - (50.13 SQM)	● Student Space (23)	
BODD - R0028 - Movement - (15.8 SQM)	Not Applicable	Circulation or storage space.
BODD - R0029 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
BODD - R0030 - Movement - (5 SQM)	Not Applicable	Circulation or storage space.
BODD - R1001 - Movement - (21.7 SQM)	Not Applicable	Circulation or storage space.
BODD - R1002 - Home Base - (53.65 SQM)	● Student Space (24)	
BODD - R1020 - Practice/Seminar - (15.04 SQM)	Not Applicable	Circulation or storage space.
BODD - R1021 - Performance Workspace - (87.76 SQM)	● Student Space (40)	
BODD - R1022 - Movement - (80.05 SQM)	Not Applicable	Circulation or storage space.
BODD - R1023 - General Learning Space - (56.86 SQM)	● Student Space (26)	
BODD - R1024 - General Learning Space - (42.71 SQM)	● Student Space (19)	
BODD - R1026 - Staff Study - (100.92 SQM)	● Office (25)	
BODD - R1027 - Interview/Office - Type 1 - (13.41 SQM)	● Office (3)	
BODD - R1028 - Duplicating Workroom - (7.92 SQM)	● Office (1)	
BODD - R1032 - Movement - (26.15 SQM)	Not Applicable	Circulation or storage space.
BODD - R1033 - Movement - (5 SQM)	Not Applicable	Circulation or storage space.
BODD - R9003 - Movement - (8.94 SQM)	Not Applicable	Circulation or storage space.
BODD - R9013 - Gymnasium - (86.83 SQM)	● Student Space (40)	
BODD - R9014 - Movement - (29.7 SQM)	Not Applicable	Circulation or storage space.
BODD - R9015 - Student Canteen - (44.88 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0004 - Entry Vestibule - (43.98 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0005 - Administration - Executive - (102.56 SQM)	● Office (25)	
BOE1 - R0006 - Clerical Office - (36.92 SQM)	● Office (9)	
BOE1 - R0007 - Clerical/Printing - (21.29 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0008 - Staff Study - (50.37 SQM)	● Office (12)	
BOE1 - R0011 - Clinic - (12.57 SQM)	● Office (3)	
BOE1 - R0013 - Clinic - (12.19 SQM)	● Office (3)	
BOE1 - R0014 - Sick Bay - (8.37 SQM)	● Student Space (3)	
BOE1 - R0015 - Movement - (19.66 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0018 - Clerical Office - (14.47 SQM)	● Office (3)	
BOE1 - R0019 - Clerical Office - (13.9 SQM)	● Office (3)	
BOE1 - R0021 - Clerical Office - (13.13 SQM)	● Office (3)	
BOE1 - R0022 - Clerical Office - (13.36 SQM)	● Office (3)	
BOE1 - R0023 - Interview/Meeting - (16.55 SQM)	● Office (4)	
BOE1 - R0025 - Movement - (87.06 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0026 - Student Waiting - (13.47 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0027 - Interview/Meeting - (15.43 SQM)	● Office (3)	
BOE1 - R0029 - Movement - (56.12 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R0030 - Administration - Clerical - (13.39 SQM)	● Office (3)	
BOE1 - R0031 - Administration - Clerical - (13.91 SQM)	● Office (3)	
BOE1 - R0032 - Interview/Meeting - (25.95 SQM)	● Office (6)	
BOE1 - R0033 - Sick Bay - (11.84 SQM)	● Student Space (5)	
BOE1 - R0034 - Clinic-Waiting - (10.28 SQM)	● Office (2)	
BOE1 - R0035 - Sick Bay - (12.49 SQM)	● Student Space (5)	
BOE1 - R0036 - Special Programs Room - Type 1 - (45.72 SQM)	● Student Space (21)	
BOE1 - R0037 - Special Programs Room - Type 1 - (38.94 SQM)	● Student Space (18)	
BOE1 - R0041 - Special Programs Room - Type 1 - (40.78 SQM)	● Student Space (18)	
BOE1 - R0042 - Special Programs Room - Type 1 - (41.5 SQM)	● Student Space (19)	
BOE1 - R0051 - Staff Kitchen - (11.12 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOE1 - R0052 - Clerical Office - (8.62 SQM)	Office (2)	
BOE1 - R0053 - Movement - (33.03 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1002 - Student Reception - (43.02 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1003 - Movement - (75.26 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1004 - Staff Study - (23.32 SQM)	Office (5)	
BOE1 - R1005 - Staff Lounge - (180.37 SQM)	Office (45)	
BOE1 - R1006 - Staff Study - (46.03 SQM)	Office (11)	
BOE1 - R1009 - Staff Room Annexe - (49.33 SQM)	Office (12)	
BOE1 - R1013 - Clerical Office - (14.83 SQM)	Office (3)	
BOE1 - R1014 - Clerical Office - (14.38 SQM)	Office (3)	
BOE1 - R1015 - Deputy Principal - (17.4 SQM)	Office (4)	
BOE1 - R1018 - Interview/Meeting - (12.43 SQM)	Office (3)	
BOE1 - R1019 - Deputy Principal Office - (17.89 SQM)	Office (4)	
BOE1 - R1020 - Interview/Meeting - (24.85 SQM)	Office (6)	
BOE1 - R1021 - Movement - (7.58 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1022 - Movement - (28.15 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1025 - Staff Kitchen - (18.15 SQM)	Office (4)	
BOE1 - R1030 - Staff Kitchen - (14.7 SQM)	Office (3)	
BOE1 - R1032 - Movement - (56.78 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R1054 - Outdoor Learning Area - (139.93 SQM)	Not Applicable	Circulation or storage space.
BOE1 - R2001 - Special Programs Room - Type 1 - (30.14 SQM)	Student Space (13)	
BOE1 - R2002 - Special Programs Room - Type 1 - (33.13 SQM)	Student Space (15)	
BOE1 - R2010 - Outdoor Learning Area - (552.82 SQM)	Not Applicable	Circulation or storage space.
OS 500 30005 - OS 500 30005 - Admin - Library - (133 SQM)	Office (33)	
OS 508 11544 - OS 508 11544 - Administration - (114 SQM)	Office (28)	
OS 508 30000 - OS 508 30000 - Administration - (114 SQM)	Office (28)	
OS 508 30006 - OS 508 30006 - Administration - (114 SQM)	Office (28)	
OS 520 10423 - OS 520 10423 - Staff Study - (57 SQM)	Office (14)	
OS 520 10963 - OS 520 10963 - Staff Study - (57 SQM)	Office (14)	
OS 520 12779 - OS 520 12779 - Staff Study - (57 SQM)	Office (14)	
OS 520 18217 - OS 520 18217 - Staff Study - (57 SQM)	Office (14)	
OS 520 30004 - OS 520 30004 - Staff Study - (57 SQM)	Office (14)	
OS 523 13108 - OS 523 13108 - Staff Study With Toilets - (76 SQM)	Office (19)	
OS 523 19477 - OS 523 19477 - Staff Study With Toilets - (76 SQM)	Office (19)	
OS 534 11919 - OS 534 11919 - Library/Group Study/Office/A V Store - (152 SQM)	Student Space (70)	
OS 600 10526 - OS 600 10526 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 10804 - OS 600 10804 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 11440 - OS 600 11440 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 12954 - OS 600 12954 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 13942 - OS 600 13942 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 14664 - OS 600 14664 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 15016 - OS 600 15016 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 17947 - OS 600 17947 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18156 - OS 600 18156 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18157 - OS 600 18157 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18249 - OS 600 18249 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18250 - OS 600 18250 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 18251 - OS 600 18251 - Learning Unit - Small - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 18252 - OS 600 18252 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18253 - OS 600 18253 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18254 - OS 600 18254 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 30007 - OS 600 30007 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 30003 - OS 601 30003 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 30018 - OS 601 30018 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 30029 - OS 601 30029 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 30038 - OS 601 30038 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 30039 - OS 601 30039 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 30040 - OS 601 30040 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 30010 - OS 602 30010 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30011 - OS 602 30011 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30012 - OS 602 30012 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30013 - OS 602 30013 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30023 - OS 602 30023 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30024 - OS 602 30024 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30025 - OS 602 30025 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30026 - OS 602 30026 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30030 - OS 602 30030 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30031 - OS 602 30031 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30032 - OS 602 30032 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30033 - OS 602 30033 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 30034 - OS 602 30034 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 612 30008 - OS 612 30008 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 30009 - OS 612 30009 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 30021 - OS 612 30021 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 612 30022 - OS 612 30022 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 621 19475 - OS 621 19475 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 19476 - OS 621 19476 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 700 16888 - OS 700 16888 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 710 16838 - OS 710 16838 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	
OS 710 19105 - OS 710 19105 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	
OS 711 10918 - OS 711 10918 - Home Science/Art/Science Dem/Computer - (95 SQM)	● Student Space (44)	
OS 720 10894 - OS 720 10894 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 15935 - OS 720 15935 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 720 19104 - OS 720 19104 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 750 30036 - OS 750 30036 - Learning Unit - ESL - (38 SQM)	● Student Space (17)	
OS 780 19103 - OS 780 19103 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 801 10856 - OS 801 10856 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.