

VENTILATION AUDIT REPORT Version 2

SCHOOL:	Ashcroft High School (8397)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Music Learning Space - (86.32 SQM) - Teaching Space: 1	Student Space (121)	
B00A - R0003 - Music Learning Space - (85.94 SQM) - Teaching Space: 1	Student Space (75)	
B00A - R0008 - General Assistants - (19.43 SQM)	Office (4)	
B00A - R0010 - Art Learning Space - (79.63 SQM) - Teaching Space: 1	Student Space (154)	
B00A - R0014 - Art Learning Space - (65.38 SQM) - Teaching Space: 1	Student Space (149)	
B00A - R0023 - Staff Study - (37.81 SQM)	Office (9)	
B00A - R0024 - Tea Room - (7.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Dark Room - (23.44 SQM)	Office (5)	
B00A - R0033 - Movement - (106.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (53.44 SQM) - Teaching Space: 1	Student Space (144)	
B00A - R1002 - General Learning Space - (66.83 SQM) - Teaching Space: 1	Student Space (179)	
B00A - R1005 - Computer Learning Space - (80.39 SQM) - Teaching Space: 1	Student Space (92)	
B00A - R1006 - Audio Visual Workroom - (26.39 SQM)	Student Space (12)	
B00A - R1011 - General Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (89)	
B00A - R1012 - General Learning Space - (53.53 SQM) - Teaching Space: 1	Student Space (89)	
B00A - R1013 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (89)	
B00A - R1015 - Movement - (107.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Staff Study - (50.41 SQM)	Office (12)	
B00B - R0003 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Fitness Laboratory - (153.48 SQM)	Student Space (71)	
B00B - R0014 - Movement - (7.23 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Student Canteen - (43.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0023 - Multi-Purpose Space - (304.98 SQM)	Student Space (141)	
B00C - R0003 - Staff Study - (52.8 SQM)	Office (13)	
B00C - R0017 - Computer Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (117)	
B00C - R0026 - Design L.S. - (59.23 SQM) - Teaching Space: 1	Student Space (123)	
B00C - R0027 - Design L.S. - (66.77 SQM) - Teaching Space: 1	Student Space (116)	
B00C - R0034 - Staff Study - (43.71 SQM)	Office (10)	
B00C - R0040 - Movement - (103.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0041 - Kitchen - Type 1 - (114.38 SQM)	Student Space (53)	
B00C - R0043 - General Learning Space - (58.76 SQM) - Teaching Space: 1	Student Space (130)	
B00C - R1001 - Staff Study - (26.32 SQM)	Office (6)	
B00C - R1012 - Wood Technology L.S. - (80.5 SQM) - Teaching Space: 1	Student Space (103)	
B00C - R1017 - Wood Technology L.S. - (95.51 SQM) - Teaching Space: 1	Student Space (131)	
B00C - R1018 - Wood Technology Bay - (26.32 SQM)	Not Applicable	Circulation or storage space.
B00C - R1019 - Wood Technology L.S. - (73.24 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R1020 - Metal Technology L.S. - (87.75 SQM) - Teaching Space: 1	Student Space (121)	
B00C - R1021 - Welding Area - (6.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R1024 - Movement - (87.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1025 - Movement - (17.88 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Public Reception - (70.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Administration - Clerical - (14.32 SQM)	Office (3)	
B00D - R0007 - Principal Office - (19 SQM)	Office (4)	
B00D - R0011 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (117)	
B00D - R0012 - General Learning Space - (66.11 SQM) - Teaching Space: 1	Student Space (146)	
B00D - R0015 - Senior Study - (25.89 SQM)	Office (6)	
B00D - R0016 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (117)	
B00D - R0019 - Administration - Clerical - (7.52 SQM)	Office (1)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0021 - Administration - Clerical - (27.12 SQM)	Office (6)	
B00D - R0023 - Deputy Principal Office - (19.05 SQM)	Office (4)	
B00D - R0024 - Deputy Principal Office - (14.07 SQM)	Office (3)	
B00D - R0025 - Interview/Office - Type 1 - (14.21 SQM)	Office (3)	
B00D - R0032 - Movement - (31.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0045 - Movement - (73.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (69)	
B00D - R1002 - General Learning Space - (53.67 SQM) - Teaching Space: 1	Student Space (69)	
B00D - R1005 - General Learning Space - (53.15 SQM) - Teaching Space: 1	Student Space (69)	
B00D - R1009 - General Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (69)	
B00D - R1011 - Seminar - (26.32 SQM)	Office (6)	
B00D - R1012 - Computer Learning Space - (53.3 SQM) - Teaching Space: 1	Student Space (69)	
B00D - R1018 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R1019 - Commonroom - (124.05 SQM)	Office (31)	
B00D - R1020 - Tea Room - (10.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Staff Study - (25.3 SQM)	Office (6)	
B00D - R1023 - Movement - (146.45 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (117)	
B00E - R0003 - Laboratory L.S. - (86.2 SQM) - Teaching Space: 1	Student Space (237)	
B00E - R0005 - Laboratory L.S. - (86.34 SQM) - Teaching Space: 1	Student Space (170)	
B00E - R0009 - Computer Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (117)	
B00E - R0010 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (117)	
B00E - R0014 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (117)	
B00E - R0015 - General Learning Space - (66.09 SQM) - Teaching Space: 1	Student Space (104)	
B00E - R0016 - Movement - (126.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0024 - Preparation - Science - (29.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0026 - Staff Study - (23.38 SQM)	Office (5)	
B00E - R1001 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1002 - General Learning Space - (53.08 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1003 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1004 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1005 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1007 - Computer Room - (25.85 SQM)	Student Space (11)	
B00E - R1008 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1012 - Staff Study - (33.09 SQM)	Office (8)	
B00E - R1013 - Computer Learning Space - (66.65 SQM) - Teaching Space: 1	Student Space (152)	
B00E - R1016 - Movement - (26.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R1018 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (89)	
B00E - R1021 - Movement - (117 SQM)	Not Applicable	Circulation or storage space.
B00F - M1003 - Seminar - (37.63 SQM)	Office (9)	
B00F - M1006 - Interview/Office - Type 1 - (15.11 SQM)	Office (3)	
B00F - M1008 - Movement - (69.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Staff Study - (33.04 SQM)	Office (8)	
B00F - R0010 - Preparation - Science - (44.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0013 - Laboratory L.S. - (91.15 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0015 - Preparation - Science - (44.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0016 - Laboratory L.S. - (91.34 SQM) - Teaching Space: 1	Student Space (42)	
B00F - R0017 - Movement - (67.99 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1004 - Computer Room - (12.41 SQM)	● Student Space (5)	
B00F - R1007 - Audio Visual Workroom - (69.78 SQM)	● Student Space (32)	
B00F - R1008 - Main Area - (320.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R1023 - Seminar Space - (24.7 SQM)	● Office (6)	
B00G - R0001 - Movement Studio - (109.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (20.06 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - General Learning Space - (47.01 SQM) - Teaching Space: 1	● Student Space (56)	
B00H - R0003 - Performance Workspace - (46.95 SQM) - Teaching Space: 1	● Student Space (56)	
B00K - R0011 - Entry - (22.59 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Staff Kitchen - (16.64 SQM)	● Office (4)	
B00K - R0022 - Multi-Purpose Space - (433.56 SQM)	● Student Space (201)	
B00K - R0023 - Stage - (98.79 SQM)	Not Applicable	Circulation or storage space.
B00K - R0025 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B00K - R0027 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.
B00K - R9004 - Movement - (24.48 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Computer Learning Space - (92.17 SQM) - Teaching Space: 1	● Student Space (36)	
B00M - R0002 - Seminar - (18.92 SQM)	● Office (4)	
B00N - R0001 - Workshop Area - (127.03 SQM)	● Student Space (58)	