

<b>SCHOOL:</b>	<b>Baulkham Hills North Public School (4377)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Baulkham Hills</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>The Hills</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (57.53 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R0004 - Home Base - (57.62 SQM) - Teaching Space: 1	Student Space (47)	
B00B - R0002 - Home Base - (69.49 SQM) - Teaching Space: 1	Student Space (53)	
B00B - R0003 - Home Base - (69.49 SQM) - Teaching Space: 1	Student Space (53)	
B00B - R0004 - Home Base - (69.48 SQM) - Teaching Space: 1	Student Space (53)	
B00C - R0004 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (47)	
B00C - R0005 - Home Base - (56.98 SQM) - Teaching Space: 1	Student Space (47)	
B00C - R0008 - Home Base - (57.15 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0003 - Principal - (23.48 SQM)	Office (5)	
B00D - R0004 - Interview - (15.32 SQM)	Office (3)	
B00D - R0006 - Entry Vestibule - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (37.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Deputy Principal - (14.14 SQM)	Office (3)	
B00D - R0009 - Interview - (8.06 SQM)	Office (2)	
B00D - R0010 - Clerical Office - (12.93 SQM)	Office (3)	
B00D - R0018 - Sick Bay - (6.42 SQM)	Student Space (7)	
B00D - R0020 - Duplicating Workroom - (10.87 SQM)	Office (2)	
B00D - R0021 - Clerical Office - (16.18 SQM)	Office (4)	
B00E - R0003 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (47)	
B00E - R0004 - Home Base - (57.06 SQM) - Teaching Space: 1	Student Space (47)	
B00E - R0007 - Home Base - (71.46 SQM) - Teaching Space: 1	Student Space (41)	
B00E - R0008 - Movement - (13.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Special Programs Room - (57.85 SQM)	Student Space (47)	
B00F - R0006 - Staff Room - (70.47 SQM)	Office (17)	
B00F - R0008 - Movement - (25.28 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Canteen - (39.95 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Home Base - (74.65 SQM) - Teaching Space: 1	Student Space (71)	
B00G - R0006 - Practical Activities - 1hb - (9.79 SQM)	Student Space (4)	
B00G - R0007 - Home Base - (57.53 SQM) - Teaching Space: 1	Student Space (47)	
B00H - R0002 - Practical Activities - 1hb - (14.96 SQM)	Student Space (6)	
B00H - R0003 - Home Base - (75.58 SQM) - Teaching Space: 1	Student Space (155)	
B00H - R0004 - Home Base - (54.29 SQM) - Teaching Space: 1	Student Space (191)	
B00H - R0005 - Practical Activities - 1hb - (17.79 SQM)	Student Space (8)	
B00H - R0006 - Home Base - (57.14 SQM) - Teaching Space: 1	Student Space (191)	
B00H - R0008 - Practical Activities - 1hb - (14.63 SQM)	Student Space (6)	
B00H - R0010 - Home Base - (57.3 SQM) - Teaching Space: 1	Student Space (191)	
B00J - R0001 - Movement - (74.33 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Home Base - (87.93 SQM) - Teaching Space: 1	Student Space (117)	
B00J - R0004 - Home Base - (56.75 SQM) - Teaching Space: 1	Student Space (214)	
B00J - R0007 - Home Base - (56.99 SQM) - Teaching Space: 1	Student Space (191)	
B00J - R0008 - Movement - (10.55 SQM)	Not Applicable	Circulation or storage space.
B00J - R0009 - Interview - (15.82 SQM)	Office (3)	
B00J - R0014 - Staff Room Annexe - (31.64 SQM)	Office (7)	
B00J - R0024 - Movement - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Communal Space - (198.23 SQM)	Student Space (91)	
B00K - R0002 - Movement - (16.95 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (6.1 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0004 - Raised Platform - (59.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Movement - (12.57 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Seminar/Study - (29.84 SQM)	Office (7)	
B00L - R0006 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Reading Area - (166.77 SQM)	Student Space (77)	
B00L - R9007 - Home Base - (52.49 SQM) - Teaching Space: 1	Student Space (24)	
B00L - R9008 - Home Base - (52.5 SQM) - Teaching Space: 1	Student Space (26)	
B00L - R9009 - Practical Activities - 1hb - (27.88 SQM)	Student Space (12)	
B00L - R9010 - Practical Activities - 1hb - (27.88 SQM)	Student Space (12)	
B00L - R9013 - Movement - (15.3 SQM)	Not Applicable	Circulation or storage space.
OH 060 17017 - OH 060 17017 - OSHC Hub 60 - ( SQM)	Student Space (163)	
OS 601 15936 - OS 601 15936 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (72)	
OS 602 10291 - OS 602 10291 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (72)	
OS 602 12004 - OS 602 12004 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 12509 - OS 602 12509 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 13398 - OS 602 13398 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 13545 - OS 602 13545 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 14922 - OS 602 14922 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 14950 - OS 602 14950 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 15815 - OS 602 15815 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 17129 - OS 602 17129 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (84)	
OS 602 19699 - OS 602 19699 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (72)	
OS 603 10093 - OS 603 10093 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (84)	
OS 603 11265 - OS 603 11265 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (84)	
OS 603 12767 - OS 603 12767 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (84)	
OS 603 13035 - OS 603 13035 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (85)	
OS 606 19563 - OS 606 19563 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (97)	
OS 750 17702 - OS 750 17702 - Learning Unit - ESL - (38 SQM)	Student Space (36)	