

SCHOOL:	Boggabri Public School (1276)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Narrabri

1276 - Boggabri Public School
Site Plan (12352)



1:686

Printed: 20-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (47.76 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0002 - Home Base - (47.75 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0003 - Special Programs Room - (25.29 SQM)	● Student Space (11)	
B00A - R0005 - Home Base - (47.75 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0006 - Home Base - (47.49 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R0008 - Movement - (17.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Outdoor Learning Area - (51.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Reading Area - (84.58 SQM)	● Student Space (39)	
B00A - R0013 - Interview - (10.37 SQM)	● Office (2)	
B00A - R0015 - Entry Vestibule - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Clerical Office - (20.25 SQM)	● Office (5)	
B00A - R0017 - Sick Bay - (8.76 SQM)	● Student Space (4)	
B00A - R0018 - Principal - (10.19 SQM)	● Office (2)	
B00A - R0019 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Staff Room - (32.64 SQM)	● Office (8)	
B00A - R0022 - Movement - (36.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (99.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (12.84 SQM)	● Student Space (5)	
B00B - R0006 - Movement - (77.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Home Base - (109.53 SQM) - Teaching Space: 1	● Student Space (60)	
B00B - R0008 - Home Base - (64.03 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0001 - Movement - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Withdrawal Space - 1hb - (17.67 SQM)	● Student Space (8)	
B00I - R0003 - Communal Space - (183.16 SQM)	● Student Space (84)	
B00I - R0004 - Canteen - (29.69 SQM)	Not Applicable	Circulation or storage space.