

SCHOOL:	Buninyong Public School (4616)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Dubbo
LOCAL GOVERNMENT AREA:	Dubbo

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.


























Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (162.29 SQM)	Office (40)	
B00A - R0004 - Staff Room Annexe - (14.9 SQM)	Office (3)	
B00A - R0005 - Staff Room Annexe - (13.14 SQM)	Office (3)	
B00A - R0006 - Duplicating Workroom - (12.83 SQM)	Office (3)	
B00A - R0007 - Staff Room Annexe - (12.86 SQM)	Office (3)	
B00A - R0008 - Staff Room Annexe - (13.01 SQM)	Office (3)	
B00A - R0009 - Principal - (20.46 SQM)	Office (5)	
B00A - R0014 - Entry Vestibule - (36.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (75.86 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Sick Bay - (14.33 SQM)	Student Space (56)	
B00A - R0026 - Clerical Office/Workroom - (81.47 SQM)	Office (20)	
B00C - R0007 - Special Programs Room - (65.69 SQM)	Student Space (30)	
B00C - R0031 - Seminar/Study - (26.12 SQM)	Office (6)	
B00C - R0032 - Reading Area - (332.3 SQM)	Student Space (97)	
B00D - R0002 - Practical Activities - S - 1hb - (25.47 SQM)	Student Space (28)	
B00D - R0004 - Staff Room Annexe - (5.85 SQM)	Office (1)	
B00D - R0005 - Home Base - S - (50.45 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0006 - Practical Activities - S - 1hb - (26.78 SQM)	Student Space (12)	
B00D - R0007 - Practical Activities - (50.68 SQM)	Student Space (28)	
B00D - R0009 - Withdrawal - S - (6.02 SQM)	Student Space (9)	
B00D - R0010 - Home Base - (60.16 SQM) - Teaching Space: 1	Student Space (54)	
B00D - R0012 - Practical Activities - 2hb - (42.02 SQM)	Student Space (19)	
B00D - R0015 - Withdrawal Space - 1hb - (26.13 SQM)	Student Space (28)	
B00D - R0016 - Home Base - (60.25 SQM) - Teaching Space: 1	Student Space (56)	
B00D - R0019 - Withdrawal Space - 1hb - (27.86 SQM)	Student Space (28)	
B00H - R0038 - Staff Kitchen - (7.17 SQM)	Office (1)	
B00H - R0045 - Practical Activities - 1hb - (62.06 SQM) - Teaching Space: 1	Student Space (27)	
B00H - R0046 - Withdrawal Space - 1hb - (8.97 SQM)	Student Space (7)	
B00H - R0048 - Practical Activities - 1hb - (11.37 SQM)	Student Space (28)	
B00J - R0009 - Communal Space - (212.23 SQM)	Student Space (74)	
B00J - R0010 - Raised Platform - (48.19 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Special Programs Room - (22.52 SQM)	Student Space (14)	
B00N - R0002 - Practical Activities - 1hb - (11.21 SQM)	Student Space (7)	
B00N - R0007 - Special Programs Room - (8.92 SQM)	Student Space (9)	
B00N - R0008 - Special Programs Room - (12.76 SQM)	Student Space (19)	
BOEE - R0001 - Canteen - (42.36 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0004 - Withdrawal Space - 1hb - (5.75 SQM)	Student Space (9)	
BOEE - R0006 - Home Base - (52.98 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0007 - Home Base - (52.98 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0008 - Practical Activities - 1hb - (26.16 SQM)	Student Space (28)	
BOEE - R0009 - Practical Activities - 1hb - (26.16 SQM)	Student Space (28)	
BOEE - R0010 - Withdrawal Space - 1hb - (5.85 SQM)	Student Space (9)	
BOEE - R0013 - Withdrawal - M - (11.65 SQM)	Student Space (9)	
BOEE - R0015 - Home Base - Bd/Cd/Ed - (41.07 SQM) - Teaching Space: 1	Student Space (27)	
BOEE - R0016 - Practical Activities - M - 1hb - (18.98 SQM)	Student Space (14)	
BOEE - R0019 - Breakout Area - (24.74 SQM)	Not Applicable	Circulation or storage space.
BOEE - R0020 - Breakout Area - (24.74 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
BOEE - R0021 - Home Base - Bd/Cd/Ed - (40.94 SQM) - Teaching Space: 1	 Student Space (27)	
BOEE - R0022 - Practical Activities - M - 1hb - (18.84 SQM)	 Student Space (14)	
BOEE - R0023 - Withdrawal - M - (11.62 SQM)	 Student Space (5)	
BOFF - R0003 - Home Base - (55.67 SQM) - Teaching Space: 1	 Student Space (27)	
BOFF - R0004 - Practical Activities - 1hb - (24.45 SQM)	 Student Space (28)	
BOFF - R0005 - Withdrawal Space - 2hb - (10.07 SQM)	 Student Space (14)	
BOFF - R0006 - Home Base - (55.68 SQM) - Teaching Space: 1	 Student Space (27)	
BOFF - R0007 - Practical Activities - 1hb - (24.45 SQM)	 Student Space (28)	
BOFF - R0012 - Home Base - (55.68 SQM) - Teaching Space: 1	 Student Space (27)	
BOFF - R0013 - Practical Activities - 1hb - (24.45 SQM)	 Student Space (28)	
BOFF - R0014 - Withdrawal Space - 2hb - (10.07 SQM)	 Student Space (14)	
BOFF - R0015 - Home Base - (55.68 SQM) - Teaching Space: 1	 Student Space (27)	
BOFF - R0016 - Practical Activities - 1hb - (24.45 SQM)	 Student Space (28)	
BOFF - R0020 - Home Base - (55.68 SQM) - Teaching Space: 1	 Student Space (27)	
BOFF - R0021 - Practical Activities - 1hb - (24.45 SQM)	 Student Space (28)	
BOFF - R0022 - Withdrawal Space - 2hb - (10.07 SQM)	 Student Space (14)	
BOFF - R0023 - Home Base - (55.67 SQM) - Teaching Space: 1	 Student Space (27)	
BOFF - R0024 - Practical Activities - 1hb - (24.45 SQM)	 Student Space (28)	
OS 534 14381 - OS 534 14381 - Library/Group Study/Office/A V Store - (152 SQM)	 Student Space (130)	
OS 601 13600 - OS 601 13600 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (84)	
OS 601 15142 - OS 601 15142 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (84)	
OS 602 12202 - OS 602 12202 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (97)	
OS 602 12360 - OS 602 12360 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (97)	
OS 602 12517 - OS 602 12517 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (97)	
OS 606 11803 - OS 606 11803 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (97)	