

VENTILATION AUDIT REPORT Version 2

SCHOOL:	Caringbah Public School (1508)
AMU REGION:	Sydney
STATE ELECTORATE:	Cronulla
LOCAL GOVERNMENT AREA:	Sutherland

1508 - Caringbah Public School
Site Plan (11638)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Special Programs Room - (53.3 SQM)	● Student Space (24)	
B00A - R0017 - Movement - (66.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Practical Activities - 1hb - (5.78 SQM)	● Student Space (2)	
B00A - R0025 - Movement - (43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Home Base - (46.23 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0027 - Practical Activities - 1hb - (5.15 SQM)	● Student Space (2)	
B00A - R0028 - Home Base - (52.2 SQM) - Teaching Space: 1	● Student Space (37)	
B00A - R0030 - Staff Room Annexe - (13.62 SQM)	● Office (3)	
B00A - R0031 - Movement - (60.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Interview - (13.92 SQM)	● Office (3)	
B00A - R0036 - Principal - (19.42 SQM)	● Office (4)	
B00A - R0037 - Movement - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Deputy Principal - (19.02 SQM)	● Office (4)	
B00A - R0040 - Clerical Office - (11.58 SQM)	● Office (2)	
B00A - R0041 - Clerical/Printing - (42.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Sick Bay - (9.07 SQM)	● Student Space (4)	
B00A - R0045 - Staff Room Annexe - (28.73 SQM)	● Office (7)	
B00A - R0046 - Staff Room - (34.47 SQM)	● Office (8)	
B00A - R0051 - Staff Kitchen - (9.8 SQM)	● Office (2)	
B00A - R0052 - Withdrawal - M - (18.79 SQM)	● Student Space (8)	
B00A - R0053 - Home Base - (69.55 SQM) - Teaching Space: 1	● Student Space (52)	
B00E - R0006 - Movement - (27.26 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Practical Activities - 1hb - (5.34 SQM)	● Student Space (2)	
B00E - R0010 - Home Base - (52.43 SQM) - Teaching Space: 1	● Student Space (37)	
B00F - R0001 - Home Base - (60.43 SQM) - Teaching Space: 1	● Student Space (45)	
B00F - R0002 - Movement - (25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Practical Activities - 1hb - (17.98 SQM)	● Student Space (8)	
B00G - R0001 - Home Base - (51 SQM) - Teaching Space: 1	● Student Space (37)	
B00G - R0003 - Home Base - (51.07 SQM) - Teaching Space: 1	● Student Space (37)	
B00H - R0001 - Home Base - (50.86 SQM) - Teaching Space: 1	● Student Space (37)	
B00H - R0003 - Home Base - (50.85 SQM) - Teaching Space: 1	● Student Space (37)	
B00J - R0003 - Reading Area - (164 SQM)	● Student Space (76)	
B00M - R0008 - Canteen - (12.38 SQM)	Not Applicable	Circulation or storage space.
B00M - R0009 - Movement - (36.91 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (38)	
B00M - R0013 - Home Base - (75.5 SQM) - Teaching Space: 1	● Student Space (48)	
B00N - R0001 - Communal Space - (223.1 SQM)	● Student Space (103)	
B00N - R0002 - Raised Platform - (23.62 SQM)	Not Applicable	Circulation or storage space.
OS 602 10020 - OS 602 10020 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14054 - OS 602 14054 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14815 - OS 602 14815 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19501 - OS 602 19501 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 14290 - OS 603 14290 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 18369 - OS 606 18369 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 801 10485 - OS 801 10485 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.