

SCHOOL:	Castle Hill High School (8382)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Castle Hill
LOCAL GOVERNMENT AREA:	The Hills

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.



















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Food Technology L.S. - (65.01 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R0003 - Preparation - (9.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Kitchen - Type 1 - (65.48 SQM)	● Student Space (46)	
B00A - R0013 - Movement - (117.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Materials Technology L.S. - (85.67 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R0020 - Computer Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R0024 - Seminar/Technology Space - (26.9 SQM)	● Office (6)	
B00A - R0026 - Seminar - Type 3 - (20.69 SQM)	● Office (5)	
B00A - R0029 - Dark Room - (29.57 SQM)	● Office (7)	
B00A - R1001 - Practice/Seminar - (26.2 SQM)	● Student Space (9)	
B00A - R1004 - Practice/Seminar - (26.17 SQM)	● Student Space (12)	
B00A - R1005 - Performance Workshop - (52.99 SQM)	● Student Space (37)	
B00A - R1006 - General Learning Space - (52.92 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R1011 - General Learning Space - (52.55 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R1012 - Movement - (109.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R1013 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R1016 - Music Learning Space - (66.37 SQM) - Teaching Space: 1	● Student Space (47)	
B00A - R1017 - Music Learning Space - (79.82 SQM) - Teaching Space: 1	● Student Space (56)	
B00A - R1024 - Senior Seminar - (8.96 SQM)	● Office (2)	
B00A - R9003 - Movement - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - General Assistants - (20.39 SQM)	● Office (5)	
B00B - R0004 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Student Canteen - (48.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Gymnasium - (565.14 SQM)	● Student Space (262)	
B00C - R0005 - Staff Study - (25.7 SQM)	● Office (6)	
B00C - R0006 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0009 - General Learning Space - (52.71 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0010 - General Learning Space - (39.2 SQM) - Teaching Space: 1	● Student Space (19)	
B00C - R0011 - General Learning Space - (52.71 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0012 - Metal Technology L.S. - (95.9 SQM) - Teaching Space: 1	● Student Space (44)	
B00C - R0016 - Design L.S. - (65.7 SQM) - Teaching Space: 1	● Student Space (47)	
B00C - R0017 - Staff Study - (39.6 SQM)	● Office (9)	
B00C - R0019 - Movement - (116.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Materials Technology L.S. - (79.78 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R1010 - Wood Technology Bay - (80.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Movement - (104.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R1022 - Computer Learning Space - (66.57 SQM) - Teaching Space: 1	● Student Space (65)	
B00C - R1024 - Art Learning Space - (106.87 SQM) - Teaching Space: 1	● Student Space (75)	
B00C - R9001 - Tea Room - (17.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R9004 - Movement - (11.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Art Learning Space - (65.85 SQM) - Teaching Space: 1	● Student Space (75)	
B00D - R0004 - Administration - Clerical - (39.27 SQM)	● Office (9)	
B00D - R0006 - Administration - Clerical - (21.46 SQM)	● Office (5)	
B00D - R0009 - Deputy Principal Office - (11.81 SQM)	● Office (2)	
B00D - R0011 - Deputy Principal Office - (16.11 SQM)	● Office (4)	
B00D - R0012 - Administration - Executive - (11.83 SQM)	● Office (2)	
B00D - R0015 - Administration - Executive - (11.83 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0018 - Principal Office - (19.7 SQM)	Office (4)	
B00D - R0023 - Computer Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (75)	
B00D - R0027 - Computer Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (75)	
B00D - R0028 - Staff Study - (25.7 SQM)	Office (6)	
B00D - R0033 - Movement - (46.22 SQM)	Not Applicable	Circulation or storage space.
B00D - R0034 - Movement - (64.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0035 - Movement - (5.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Public Reception - (70.19 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Clinic - (5.34 SQM)	Office (1)	
B00D - R0042 - Administration - Clerical - (24.92 SQM)	Office (6)	
B00D - R1001 - Seminar - (39.78 SQM)	Office (9)	
B00D - R1002 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (75)	
B00D - R1006 - General Learning Space - (51.58 SQM) - Teaching Space: 1	Student Space (75)	
B00D - R1009 - General Learning Space - (66.28 SQM) - Teaching Space: 1	Student Space (65)	
B00D - R1011 - Staff Study - (39.49 SQM)	Office (9)	
B00D - R1014 - Interview/Office - Type 1 - (11.73 SQM)	Office (2)	
B00D - R1017 - General Learning Space - (66.44 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R1020 - Movement - (35.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Movement - (87.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R1023 - Commonroom - (116.57 SQM)	Office (29)	
B00D - R1024 - Tea Room - (16.42 SQM)	Not Applicable	Circulation or storage space.
B00D - R1026 - Movement - (128.12 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Laboratory L.S. - (85.95 SQM) - Teaching Space: 1	Student Space (56)	
B00E - R0002 - Preparation - Science - (29.21 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Laboratory L.S. - (86.02 SQM) - Teaching Space: 1	Student Space (47)	
B00E - R0005 - General Learning Space - (52.56 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0008 - Movement - (151.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - General Learning Space - (52.63 SQM)	Student Space (37)	
B00E - R0016 - General Learning Space - (52.49 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0017 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R0019 - Movement - (8.72 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Staff Study - (74.46 SQM)	Office (18)	
B00E - R1001 - General Learning Space - (52.77 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1002 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1003 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1004 - General Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1005 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1006 - Seminar - Type 3 - (26.16 SQM)	Office (6)	
B00E - R1007 - Movement - (138.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1012 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (38)	
B00E - R1022 - General Learning Space - (40.29 SQM)	Student Space (28)	
B00E - R1023 - Staff Study - (114.16 SQM)	Office (28)	
B00E - R1024 - Tea Room - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R1026 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Gymnasium - (697.04 SQM)	Student Space (74)	
B00F - R0002 - Ancillary Staff - (17.66 SQM)	Office (4)	
B00F - R0004 - Movement - (11.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0016 - Staff Study - (49.98 SQM)	Office (12)	
B00F - R0017 - Tea Room - (7.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R9001 - General Learning Space - (59.5 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R9002 - General Learning Space - (59.06 SQM) - Teaching Space: 1	Student Space (27)	
B00F - R9003 - General Learning Space - (58.01 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0005 - Stage - (117.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Multi-Purpose Space - (445.52 SQM)	Student Space (206)	
B00H - R0010 - Staff Kitchen - (17.39 SQM)	Office (4)	
B00H - R0011 - Entry - (70.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R1007 - Staff Lounge - (9.57 SQM)	Office (2)	
B00H - R9004 - Movement Studio - (104.95 SQM)	Not Applicable	Circulation or storage space.
BOLL - M1003 - Seminar/Study - (20.02 SQM)	Office (5)	
BOLL - M1007 - Study Space - (66.38 SQM)	Not Applicable	Circulation or storage space.
BOLL - M1008 - Study Space - (75.18 SQM)	Not Applicable	Circulation or storage space.
BOLL - R0001 - Laboratory L.S. - (91.3 SQM) - Teaching Space: 1	Student Space (50)	
BOLL - R0002 - Preparation - Science - (47.36 SQM)	Not Applicable	Circulation or storage space.
BOLL - R0004 - Laboratory L.S. - (91.02 SQM) - Teaching Space: 1	Student Space (56)	
BOLL - R0006 - Laboratory L.S. - (91.3 SQM) - Teaching Space: 1	Student Space (56)	
BOLL - R0007 - Preparation - Science - (47.9 SQM)	Not Applicable	Circulation or storage space.
BOLL - R0008 - Laboratory L.S. - (91.29 SQM) - Teaching Space: 1	Student Space (56)	
BOLL - R0010 - Movement - (40.36 SQM)	Not Applicable	Circulation or storage space.
BOLL - R1008 - Main Area - (387.66 SQM)	Not Applicable	Circulation or storage space.
BOLL - R1014 - Senior Study - (11.86 SQM)	Office (2)	
BOLL - R1015 - Seminar - Type 3 - (11.52 SQM)	Office (2)	
BOLL - R1016 - Seminar - Type 3 - (11.56 SQM)	Office (2)	
BOLL - R1018 - Senior Study - (25.83 SQM)	Office (6)	
NS 220 14698 - NS 220 14698 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 10976 - OS 600 10976 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 11566 - OS 600 11566 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 12073 - OS 600 12073 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 13216 - OS 600 13216 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 13223 - OS 600 13223 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 13455 - OS 600 13455 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 13497 - OS 600 13497 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 14246 - OS 600 14246 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 14742 - OS 600 14742 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 14968 - OS 600 14968 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 15044 - OS 600 15044 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 15115 - OS 600 15115 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 15270 - OS 600 15270 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 18216 - OS 600 18216 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 19612 - OS 600 19612 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 19613 - OS 600 19613 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 19641 - OS 600 19641 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 19753 - OS 600 19753 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 19757 - OS 600 19757 - Learning Unit - Small - (57 SQM)	Student Space (74)	
OS 600 19759 - OS 600 19759 - Learning Unit - Small - (57 SQM)	Student Space (74)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 600 19762 - OS 600 19762 - Learning Unit - Small - (57 SQM)	 Student Space (74)	
OS 600 19876 - OS 600 19876 - Learning Unit - Small - (SQM)	 Student Space (74)	
OS 601 10371 - OS 601 10371 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 10686 - OS 601 10686 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 10732 - OS 601 10732 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 11401 - OS 601 11401 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 11829 - OS 601 11829 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 13245 - OS 601 13245 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 13271 - OS 601 13271 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 13849 - OS 601 13849 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 13978 - OS 601 13978 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 14221 - OS 601 14221 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 14909 - OS 601 14909 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 15411 - OS 601 15411 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 15924 - OS 601 15924 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 601 17668 - OS 601 17668 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (74)	
OS 700 15185 - OS 700 15185 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 710 12354 - OS 710 12354 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	
OS 710 16838 - OS 710 16838 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	
OS 720 14704 - OS 720 14704 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.
OS 760 10534 - OS 760 10534 - Woodwork/Store - (114 SQM)	Not Applicable	Circulation or storage space.