

SCHOOL:	Casula High School (8476)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Holsworthy
LOCAL GOVERNMENT AREA:	Liverpool

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.














Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0006 - Tiered Learning Area - (10.84 SQM)	Student Space (59)	
B00L - R0009 - Seminar/Study - (192.02 SQM)	Office (48)	
B00L - R0012 - Main Entry - (13.69 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Movement - (30.7 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Senior Seminar - (99.57 SQM)	Office (24)	
B00L - R1004 - Main Area - (111.72 SQM)	Not Applicable	Circulation or storage space.
B00L - R1005 - Seminar - (15.1 SQM)	Office (3)	
B00L - R1006 - Seminar - (15.37 SQM)	Office (3)	
B00L - R1007 - Senior Study - (15.49 SQM)	Office (3)	
B00L - R1008 - Senior Study - (15.29 SQM)	Office (3)	
B00L - R1009 - Senior Study - (15.02 SQM)	Office (3)	
B00S - R0007 - Laboratory L.S. - (93.89 SQM) - Teaching Space: 1	Student Space (56)	
B00S - R0010 - Laboratory L.S. - (93.8 SQM) - Teaching Space: 1	Student Space (56)	
B00S - R0012 - Staff Study - (93.98 SQM)	Office (23)	
B00S - R0015 - Computer Learning Space - (94.26 SQM) - Teaching Space: 1	Student Space (56)	
B00S - R0020 - Preparation - Science - (50.55 SQM)	Not Applicable	Circulation or storage space.
B00S - R1008 - Laboratory L.S. - (92.87 SQM) - Teaching Space: 1	Student Space (56)	
B00S - R1009 - Preparation - Science - (49.63 SQM)	Not Applicable	Circulation or storage space.
B00S - R1012 - Laboratory L.S. - (92.78 SQM) - Teaching Space: 1	Student Space (56)	
B00S - R1013 - Laboratory L.S. - (92.68 SQM) - Teaching Space: 1	Student Space (56)	
B00S - R1014 - Preparation - Science - (45.69 SQM)	Not Applicable	Circulation or storage space.
B00S - R1016 - Laboratory L.S. - (92.77 SQM) - Teaching Space: 1	Student Space (56)	
B0AM - R0002 - Administration - Clerical - (29.06 SQM)	Office (7)	
B0AM - R0003 - Principal Office - (22.1 SQM)	Office (5)	
B0AM - R0010 - Commonroom - (115.82 SQM)	Office (28)	
B0AM - R0011 - Staff Kitchen - (10.73 SQM)	Office (2)	
B0AM - R0015 - Leading Teacher - (12.25 SQM)	Office (3)	
B0AM - R0019 - Multi Media Workshop - (96.29 SQM)	Not Applicable	Circulation or storage space.
B0AM - R0021 - Administration - Executive - (13.47 SQM)	Office (3)	
B0AM - R0025 - Movement - (55.08 SQM)	Not Applicable	Circulation or storage space.
B0AM - R0028 - Clinic - (25.89 SQM)	Office (6)	
B0AM - R0030 - Deputy Principal Office - (22.32 SQM)	Office (5)	
B0AM - R0036 - Pupil Entry - (47.4 SQM)	Not Applicable	Circulation or storage space.
B0AM - R0037 - Interview/Office - Type 2 - (25.44 SQM)	Office (6)	
B0AM - R0038 - Administration - Clerical - (12.77 SQM)	Office (3)	
B0AM - R0039 - Public Reception - (16.2 SQM)	Not Applicable	Circulation or storage space.
B0AM - R1002 - Staff Study - (52.58 SQM)	Office (13)	
B0AM - R1003 - General Learning Space - (52.17 SQM) - Teaching Space: 1	Student Space (44)	
B0AM - R1004 - General Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (44)	
B0AM - R1006 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (44)	
B0AM - R1007 - General Learning Space - (64.4 SQM) - Teaching Space: 1	Student Space (44)	
B0AM - R1008 - General Learning Space - (64.3 SQM) - Teaching Space: 1	Student Space (44)	
B0AM - R1009 - General Learning Space - (53.45 SQM) - Teaching Space: 1	Student Space (44)	
B0AM - R1010 - Movement - (20.98 SQM)	Not Applicable	Circulation or storage space.
B0AM - R1016 - Tea Room - (12.54 SQM)	Not Applicable	Circulation or storage space.
B0AM - R1017 - General Assistants - (16.58 SQM)	Office (4)	
B0AM - R1019 - Seminar - Type 1 - (16.64 SQM)	Office (4)	
B0AM - R1021 - Movement - (74.64 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0003 - Art Learning Space - (67.59 SQM) - Teaching Space: 1	Student Space (37)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOC1 - R0004 - Dark Room - (11.27 SQM)	Office (2)	
BOC1 - R0006 - Workshop - (33.55 SQM)	Student Space (15)	
BOC1 - R0008 - Art Learning Space - (44.02 SQM) - Teaching Space: 1	Student Space (24)	
BOC1 - R0009 - Art Learning Space - (58.17 SQM) - Teaching Space: 1	Student Space (23)	
BOC1 - R1002 - Staff Study - (13.42 SQM)	Office (3)	
BOC1 - R1003 - Staff Study - (19.66 SQM)	Office (4)	
BOC1 - R1004 - Textiles Technology L.S. - (69.81 SQM) - Teaching Space: 1	Student Space (29)	
BOC1 - R1007 - Textiles Technology L.S. - (69.45 SQM) - Teaching Space: 1	Student Space (34)	
BOC2 - R0001 - Art Learning Space - (65.5 SQM) - Teaching Space: 1	Student Space (22)	
BOC2 - R0003 - Wood Technology L.S. - (111 SQM) - Teaching Space: 1	Student Space (19)	
BOC2 - R0004 - Wood Technology L.S. - (113.01 SQM) - Teaching Space: 1	Student Space (22)	
BOC2 - R1005 - Kitchen - Type 2 - (95.52 SQM)	Student Space (26)	
BOC2 - R1009 - Food Technology L.S. - (94.25 SQM) - Teaching Space: 1	Student Space (26)	
BOC2 - R1010 - Preparation - Materials - (32.52 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1013 - General Learning Space - (48.41 SQM) - Teaching Space: 1	Student Space (22)	
BOC3 - R0001 - Metal Technology L.S. - (63.72 SQM) - Teaching Space: 1	Student Space (35)	
BOC3 - R0002 - Metal Technology Bay - (38.42 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R0005 - Metal Technology L.S. - (89.85 SQM) - Teaching Space: 1	Student Space (49)	
BOC3 - R1001 - Design/Technology L.S. - (67.13 SQM) - Teaching Space: 1	Student Space (26)	
BOC3 - R1002 - Movement - (6.78 SQM)	Not Applicable	Circulation or storage space.
BOC3 - R1003 - Computer Learning Space - (90.27 SQM) - Teaching Space: 1	Student Space (26)	
BOC3 - R1004 - Staff Study - (56.12 SQM)	Office (14)	
BOEL - R0001 - General Learning Space - (53.97 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R0002 - General Learning Space - (51.28 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R0003 - General Learning Space - (67.04 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R0004 - Special Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R0005 - Staff Study - (45.92 SQM)	Office (11)	
BOEL - R0009 - Leading Teacher - (25.5 SQM)	Office (6)	
BOEL - R0010 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R0011 - Movement Studio - (53.89 SQM)	Not Applicable	Circulation or storage space.
BOEL - R0015 - Computer Learning Space - (53.82 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1001 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1002 - General Learning Space - (51.46 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1003 - General Learning Space - (65.5 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1004 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1010 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1011 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1012 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1013 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (56)	
BOEL - R1015 - Staff Study - (68.87 SQM)	Office (17)	
BOHC - R0003 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (56)	
BOHC - R0004 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (56)	
BOHC - R0010 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (56)	
BOHC - R0011 - General Learning Space - (66.54 SQM) - Teaching Space: 1	Student Space (56)	
BOHC - R0012 - General Learning Space - (67.24 SQM) - Teaching Space: 1	Student Space (56)	
BOHC - R0016 - Staff Study - (65.9 SQM)	Office (16)	
BOHC - R1003 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (56)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOHC - R1004 - General Learning Space - (73.14 SQM) - Teaching Space: 1	 Student Space (77)	
BOHC - R1010 - General Learning Space - (53.02 SQM) - Teaching Space: 1	 Student Space (56)	
BOHC - R1011 - General Learning Space - (66.06 SQM) - Teaching Space: 1	 Student Space (56)	
BOHC - R1012 - General Learning Space - (65.76 SQM) - Teaching Space: 1	 Student Space (56)	
BOSC - R0001 - Multi-Purpose Space - (457.18 SQM)	 Student Space (415)	
BOSC - R0002 - Movement - (12.04 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0023 - Student Canteen - (61 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0029 - Performance Workshop - (101.2 SQM)	 Student Space (46)	
BOSC - R0030 - Movement - (7.82 SQM)	Not Applicable	Circulation or storage space.
BOSC - R0033 - Movement - (7.82 SQM)	Not Applicable	Circulation or storage space.
BOSC - R1001 - Music Learning Space - (78.7 SQM) - Teaching Space: 1	 Student Space (43)	
BOSC - R1002 - Music Learning Space - (82.6 SQM) - Teaching Space: 1	 Student Space (46)	
BOSC - R1010 - Fitness Laboratory - (42.57 SQM)	 Student Space (19)	
BOSC - R1020 - Movement - (25.21 SQM)	Not Applicable	Circulation or storage space.
OS 601 12653 - OS 601 12653 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (139)	
OS 601 12886 - OS 601 12886 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (139)	
OS 601 13714 - OS 601 13714 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (139)	
OS 601 14782 - OS 601 14782 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (139)	