


SCHOOL:	Central Sydney Intensive English High School (8288)
AMU REGION:	Sydney
STATE ELECTORATE:	Heffron
LOCAL GOVERNMENT AREA:	Sydney

8288 - Central Sydney Intensive English High School
Site Plan (12361)




















Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B0AA - R0101 - Entry - (16.53 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0103 - Public Reception - (37.89 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0104 - Administration - Clerical - (58.97 SQM)	Office (14)	
B0AA - R0105 - Movement - (39.6 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0106 - Visitors Office - (10.15 SQM)	Office (2)	
B0AA - R0107 - Tea Room - (5.88 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0110 - Interview/Meeting - (11.8 SQM)	Office (2)	
B0AA - R0111 - Interview/Meeting - (12.18 SQM)	Office (3)	
B0AA - R0112 - Interview/Meeting - (12.18 SQM)	Office (3)	
B0AA - R0113 - Deputy Principal Office - (12.1 SQM)	Office (3)	
B0AA - R0114 - Principal Office - (18.5 SQM)	Office (4)	
B0AA - R0118 - Clinic - (11.85 SQM)	Office (2)	
B0AA - R0119 - Student Reception - (61.3 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0121 - Interview/Office - Type 1 - (15.08 SQM)	Office (3)	
B0AA - R0122 - Movement - (36.41 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0123 - Movement - (23.77 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0130 - Interview/Meeting - (48.7 SQM)	Office (12)	
B0AA - R0131 - General Learning Space - Type 13 - (47.3 SQM) - Teaching Space: 1	Student Space (25)	
B0AA - R0132 - General Learning Space - Type 13 - (46.93 SQM) - Teaching Space: 1	Student Space (25)	
B0AA - R0133 - Movement - (12.31 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0137 - Movement - (28.1 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0141 - Student Canteen - (14.67 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0142 - Gymnasium - (263.26 SQM)	Student Space (122)	
B0AA - R1201 - Movement - (13.44 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1202 - Movement - (154.02 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1205 - General Learning Space - (47.21 SQM) - Teaching Space: 1	Student Space (25)	
B0AA - R1206 - General Learning Space - (48.71 SQM) - Teaching Space: 1	Student Space (26)	
B0AA - R1207 - Computer Room - (48.47 SQM)	Student Space (22)	
B0AA - R1208 - Main Area - (99.58 SQM)	Not Applicable	Circulation or storage space.
B0AA - R1211 - Interview/Meeting - (12.03 SQM)	Office (3)	
B0AA - R1212 - Interview/Meeting - (12.2 SQM)	Office (3)	
B0AA - R1214 - General Learning Space - (49.98 SQM) - Teaching Space: 1	Student Space (28)	
B0AA - R1215 - General Learning Space - (51.23 SQM) - Teaching Space: 1	Student Space (28)	
B0AA - R1225 - General Learning Space - (48.03 SQM) - Teaching Space: 1	Student Space (26)	
B0AA - R1226 - General Learning Space - (48.37 SQM) - Teaching Space: 1	Student Space (26)	
B0AA - R2301 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2302 - Movement - (147.39 SQM)	Not Applicable	Circulation or storage space.
B0AA - R2306 - General Learning Space - (46.35 SQM) - Teaching Space: 1	Student Space (25)	
B0AA - R2307 - General Learning Space - (49.33 SQM) - Teaching Space: 1	Student Space (26)	
B0AA - R2308 - General Learning Space - (51.47 SQM) - Teaching Space: 1	Student Space (28)	
B0AA - R2309 - General Learning Space - (46.44 SQM) - Teaching Space: 1	Student Space (25)	
B0AA - R2310 - General Learning Space - (52.34 SQM) - Teaching Space: 1	Student Space (29)	
B0AA - R2311 - General Learning Space - (46.72 SQM) - Teaching Space: 1	Student Space (25)	
B0AA - R2313 - General Learning Space - Type 10 - (72.11 SQM) - Teaching Space: 0.5	Student Space (40)	
B0AA - R2314 - Science Laboratory - (28.56 SQM)	Student Space (13)	
B0AA - R2325 - General Learning Space - Type 10 - (50.09 SQM) - Teaching Space: 0.5	Student Space (28)	
B0AA - R2326 - General Learning Space - (47.69 SQM) - Teaching Space: 1	Student Space (26)	
BOBB - R0106 - Movement - (25.71 SQM)	Not Applicable	Circulation or storage space.
BOBB - R0108 - General Learning Space - (44.81 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOBB - R0109 - General Learning Space - (40.62 SQM) - Teaching Space: 1	 Student Space (22)	
BOBB - R1201 - Movement - (8.63 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1202 - Movement - (48.59 SQM)	Not Applicable	Circulation or storage space.
BOBB - R1204 - Food Technology L.S. - (69.78 SQM) - Teaching Space: 1	 Student Space (38)	
BOBB - R1205 - Kitchen - Type 1 - (15.73 SQM)	 Student Space (7)	
BOBB - R1208 - Kitchen - Type 2 - (36.95 SQM)	 Student Space (17)	
BOBB - R1211 - Computer Room - (48.45 SQM)	 Student Space (22)	
BOBB - R1212 - Staff Study - (66.23 SQM)	 Office (16)	
BOBB - R1214 - Staff Lounge - (34.87 SQM)	 Office (8)	
BOBB - R1215 - Interview/Meeting - (7.9 SQM)	 Office (1)	
BOBB - R1216 - Staff Lounge - (40.1 SQM)	 Office (10)	
BOBB - R1217 - Staff Study - (59.03 SQM)	 Office (14)	
BOBB - R1218 - Movement - (14.59 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2301 - Movement - (7.49 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2302 - Movement - (67.01 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2304 - General Learning Space - Type 12 - (48.37 SQM) - Teaching Space: 1	 Student Space (26)	
BOBB - R2305 - General Learning Space - Type 12 - (49.09 SQM) - Teaching Space: 1	 Student Space (26)	
BOBB - R2307 - Visual Arts Workshop - (36.98 SQM)	 Student Space (17)	
BOBB - R2308 - Computer Room - (46.59 SQM)	 Student Space (21)	
BOBB - R2309 - General Learning Space - (45.95 SQM) - Teaching Space: 1	 Student Space (25)	
BOBB - R2310 - Staff Study - (25.1 SQM)	 Office (6)	
BOBB - R2314 - Music Learning Space - (79.14 SQM) - Teaching Space: 1	 Student Space (43)	
BOBB - R2315 - Practice/Seminar - (7.8 SQM)	Not Applicable	Circulation or storage space.
BOBB - R2317 - Practice/Seminar - (7.79 SQM)	Not Applicable	Circulation or storage space.