

<b>SCHOOL:</b>	<b>E A Southee Public School (4383)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Cootamundra</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Cootamundra-Gundagai</b>

4383 - E A Southee Public School  
Site Plan (10348)



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (13.8 SQM)	Office (3)	
B00A - R0002 - Deputy Principal - (11.31 SQM)	Office (2)	
B00A - R0003 - Principal - (20.76 SQM)	Office (5)	
B00A - R0007 - Movement - (63.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Sick Bay - (7.66 SQM)	Student Space (3)	
B00A - R0013 - Staff Room Annexe - (11.71 SQM)	Office (2)	
B00A - R0014 - Duplicating Workroom - (12.42 SQM)	Office (3)	
B00A - R0016 - Movement - (18.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (25.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Clerical Office - (19.62 SQM)	Office (4)	
B00A - R0019 - Staff Kitchen - (8.55 SQM)	Office (2)	
B00A - R0020 - Staff Room - (54.19 SQM)	Office (13)	
B00B - R0003 - Canteen - (25.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Raised Platform - (26.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Communal Space - (210.43 SQM)	Student Space (97)	
B00B - R1001 - Movement - (43.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Reading Area - (205.61 SQM)	Student Space (95)	
B00B - R1004 - Movement - (32.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Practical Activities - 1hb - (13.35 SQM)	Student Space (6)	
B00C - R0002 - Home Base - (59.43 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0003 - Home Base - (59.3 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0004 - Practical Activities - 1hb - (13.16 SQM)	Student Space (6)	
B00C - R0008 - Practical Activities - 1hb - (13.84 SQM)	Student Space (6)	
B00C - R0009 - Home Base - (59.56 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0010 - Home Base - (59.04 SQM) - Teaching Space: 1	Student Space (32)	
B00C - R0011 - Practical Activities - 1hb - (13.54 SQM)	Student Space (6)	
B00C - R0015 - Withdrawal Space - 1hb - (9.61 SQM)	Student Space (4)	
B00C - R0016 - Withdrawal Space - 1hb - (9.48 SQM)	Student Space (4)	
B00D - R0001 - Home Base - (57.71 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0004 - Home Base - (58.67 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0005 - Home Base - (84.85 SQM) - Teaching Space: 1	Student Space (47)	
B00D - R0009 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (18.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Home Base - (57.41 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0004 - Practical Activities - 1hb - (18.54 SQM)	Student Space (8)	
B00E - R0014 - Interview - (30.84 SQM)	Office (7)	
B00F - R0001 - Home Base - (58.11 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0005 - Home Base - (57.99 SQM) - Teaching Space: 1	Student Space (31)	
B00G - R0007 - Special Programs Room - (38.8 SQM)	Student Space (18)	
B00H - R0002 - Home Base - (57.28 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R0003 - Home Base - (86.24 SQM) - Teaching Space: 1	Student Space (48)	
B00H - R0006 - Movement - (6.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.