


SCHOOL:	Elands Public School (1824)
AMU REGION:	North Coast
STATE ELECTORATE:	Myall Lakes
LOCAL GOVERNMENT AREA:	Mid-Coast

1824 - Elands Public School
Site Plan (12496)



1:569

Printed: 20-Mar-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Withdrawal Space - 1hb - (8.61 SQM)	● Student Space (3)	
B00A - R0009 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Home Base - (41.12 SQM) - Teaching Space: 1	● Student Space (84)	
B00D - R0001 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Canteen - (12.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (5.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Staff Kitchen - (8.27 SQM)	● Office (2)	
B00E - R0007 - Duplicating Workroom - (11.37 SQM)	● Office (2)	
B00E - R0008 - Staff Room - (18.43 SQM)	● Office (4)	
B00E - R0009 - Clerical Office - (11.62 SQM)	● Office (2)	
B00E - R0010 - Movement - (16.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (29.92 SQM)	● Student Space (13)	
B00G - R0001 - Movement - (17.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (59.95 SQM) - Teaching Space: 1	● Student Space (47)	