
VENTILATION AUDIT REPORT Version 2



SCHOOL:	Five Islands School (5723)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Lake Macquarie
LOCAL GOVERNMENT AREA:	Lake Macquarie



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <u>COVID safe school operations</u> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
•	Category B This space should be occupied at 1 person per 4m ² to comply with <u>COVID safe school operations and the guided use of spaces</u> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0001 - Hydrotherapy - Spa - (22.68 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Special Programs Room - Type 1 - (64.66 SQM)	Student Space (29)	
B00I - R0001 - Home Base - (68.58 SQM) - Teaching Space: 1	Student Space (38)	
B00I - R0002 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00I - R0006 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00I - R0007 - Home Base - (68.58 SQM) - Teaching Space: 1	Student Space (42)	
B00J - R0001 - Home Base - (68.58 SQM) - Teaching Space: 1	Student Space (39)	
B00J - R0002 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00J - R0006 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00J - R0007 - Home Base - (68.58 SQM) - Teaching Space: 1	Student Space (39)	
B00K - R0001 - Home Base - (68.58 SQM) - Teaching Space: 1	Student Space (39)	
B00K - R0002 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00K - R0006 - Practical Activities - 1hb - (9.77 SQM)	Student Space (4)	
B00K - R0007 - Home Base - (68.58 SQM) - Teaching Space: 1	Student Space (39)	
OS 505 15099 - OS 505 15099 - Admin Staff/Principal/Secure Store - (76 SQM)	Office (19)	
OS 621 12966 - OS 621 12966 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	