


VENTILATION AUDIT REPORT Version 2

SCHOOL:	Grahamstown Public School (4609)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Port Stephens
LOCAL GOVERNMENT AREA:	Port Stephens

4609 - Grahamstown Public School
Site Plan (13493)



1:955

Printed: 08-May-2020

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (17.41 SQM)	Office (4)	
B00A - R0003 - Entry Vestibule - (21.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (33.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Duplicating Workroom - (19.72 SQM)	Office (4)	
B00A - R0006 - Principal - (16.48 SQM)	Office (4)	
B00A - R0011 - Staff Room Annexe - (19.28 SQM)	Office (4)	
B00A - R0012 - Staff Room - (44.49 SQM)	Office (11)	
B00A - R0014 - Deputy Principal - (13.01 SQM)	Office (3)	
B00A - R0015 - Staff Room Annexe - (12.94 SQM)	Office (3)	
B00A - R0016 - Interview - (12.98 SQM)	Office (3)	
B00A - R0018 - Sick Bay - (8.46 SQM)	Student Space (3)	
B00B - R0004 - Raised Platform - (46.31 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Communal Space - (159.08 SQM)	Student Space (73)	
B00C - R0003 - Home Base - (54.82 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0004 - Practical Activities - 1hb - (23.83 SQM)	Student Space (11)	
B00C - R0005 - Withdrawal Space - 1hb - (11.05 SQM)	Student Space (5)	
B00C - R0006 - Home Base - (54.88 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0007 - Practical Activities - 1hb - (23.88 SQM)	Student Space (11)	
B00C - R0013 - Special Programs Room - (31.84 SQM)	Student Space (14)	
B00C - R0022 - Home Base - (55.01 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0023 - Practical Activities - 1hb - (23.95 SQM)	Student Space (11)	
B00C - R0024 - Withdrawal Space - 1hb - (11.05 SQM)	Student Space (5)	
B00C - R0025 - Home Base - (55.04 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R0026 - Practical Activities - 1hb - (23.88 SQM)	Student Space (11)	
B00C - R0029 - Reading Area - (133.68 SQM)	Student Space (62)	
B00C - R0030 - Special Programs Room - (29.2 SQM)	Student Space (13)	
B00D - R0005 - Practical Activities - 1hb - (23.89 SQM)	Student Space (11)	
B00D - R0007 - Home Base - (54.85 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0008 - Withdrawal Space - 1hb - (11.06 SQM)	Student Space (5)	
B00D - R0009 - Home Base - (54.86 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0010 - Practical Activities - 1hb - (23.91 SQM)	Student Space (11)	
B00D - R0012 - Practical Activities - 1hb - (23.84 SQM)	Student Space (11)	
B00D - R0014 - Home Base - (54.89 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0015 - Withdrawal Space - 1hb - (11.09 SQM)	Student Space (5)	
B00D - R0016 - Home Base - (54.86 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0017 - Practical Activities - 1hb - (23.93 SQM)	Student Space (11)	
B00D - R0019 - Practical Activities - 1hb - (23.9 SQM)	Student Space (11)	
B00D - R0021 - Home Base - (54.98 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0022 - Withdrawal Space - 1hb - (11.08 SQM)	Student Space (5)	
B00D - R0023 - Home Base - (54.82 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0024 - Practical Activities - 1hb - (23.87 SQM)	Student Space (11)	
B00E - R0002 - Canteen - (25.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Practical Activities - 1hb - (18.91 SQM)	Student Space (8)	
B00G - R0004 - Home Base - (61.3 SQM) - Teaching Space: 1	Student Space (34)	
B00G - R0005 - Withdrawal Space - 2hb - (11.14 SQM)	Student Space (5)	
B00G - R0006 - Home Base - (61.3 SQM) - Teaching Space: 1	Student Space (34)	
B00G - R0008 - Practical Activities - 1hb - (19.19 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0009 - Practical Activities - 1hb - (18.74 SQM)	● Student Space (8)	
B00G - R0011 - Home Base - (60.25 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0012 - Withdrawal Space - 2hb - (11.14 SQM)	● Student Space (5)	
B00G - R0013 - Home Base - (60.25 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R0015 - Practical Activities - 1hb - (18.62 SQM)	● Student Space (8)	
B00G - R0016 - Movement - (6.58 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Special Programs Room - (33.01 SQM)	● Student Space (15)	