

VENTILATION AUDIT REPORT Version 2

| | |
|-------------------------------|------------------------------------|
| SCHOOL: | Karuah Public School (2263) |
| AMU REGION: | Hunter/Central Coast |
| STATE ELECTORATE: | Port Stephens |
| LOCAL GOVERNMENT AREA: | Port Stephens |



















2263 - Karuah Public School
Site Plan (12564)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - R0007 - Practical Activities - 1hb - (9.76 SQM) |  Student Space (4) | |
| B00A - R0008 - Communal Space - (83.69 SQM) |  Student Space (38) | |
| B00A - R0009 - Movement - (74.24 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0010 - Communal Space - (59.13 SQM) |  Student Space (27) | |
| B00A - R0011 - Practical Activities - 1hb - (10.96 SQM) |  Student Space (5) | |
| B00A - R0013 - Staff Room - (25.09 SQM) |  Office (6) | |
| B00A - R0019 - Home Base - (57.52 SQM) - Teaching Space: 1 |  Student Space (64) | |
| B00A - R0022 - Clerical Office/Workroom - (11.08 SQM) |  Office (2) | |
| B00A - R0023 - Principal - (15.1 SQM) |  Office (3) | |
| B00B - R0004 - Reading Area - (89.82 SQM) |  Student Space (41) | |
| B00C - R0002 - Canteen - (37.02 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0005 - Home Base - (41.09 SQM) - Teaching Space: 1 |  Student Space (61) | |
| B00D - R0006 - Special Programs Room - (40.7 SQM) |  Student Space (18) | |
| B00E - R0001 - Home Base - (91.05 SQM) - Teaching Space: 1 |  Student Space (29) | |
| B00F - R0002 - Practical Activities - 1hb - (19.84 SQM) |  Student Space (9) | |
| B00F - R0004 - Home Base - (58.11 SQM) - Teaching Space: 1 |  Student Space (34) | |
| B00F - R0005 - Withdrawal Space - 2hb - (10.67 SQM) |  Student Space (4) | |
| B00F - R0006 - Home Base - (58.11 SQM) - Teaching Space: 1 |  Student Space (34) | |
| B00F - R0008 - Practical Activities - 1hb - (19.84 SQM) |  Student Space (9) | |
| OS 602 14608 - OS 602 14608 - Learning Unit - Standard With P.A.A. - (76 SQM) |  Student Space (35) | |