

SCHOOL:	Leichhardt Public School (7423)
AMU REGION:	Sydney
STATE ELECTORATE:	Balmain
LOCAL GOVERNMENT AREA:	Inner West

7423 - Leichhardt Public School
Site Plan (12761)



Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0002 - Seminar/Study - (64.4 SQM)	Office (16)	
B00A - R0003 - Movement - (18.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Movement - (10.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (79.72 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room - (75.57 SQM)	Office (18)	
B00A - R0008 - Movement - (19.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Staff Room Annexe - (14.68 SQM)	Office (3)	
B00A - R0010 - Deputy Principal - (14.8 SQM)	Office (3)	
B00A - R0011 - Interview - (14.73 SQM)	Office (3)	
B00A - R0012 - Principal - (27.13 SQM)	Office (6)	
B00A - R0017 - Movement - (15.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Entry Vestibule - (17.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Clerical Office - (24.12 SQM)	Office (6)	
B00A - R0029 - Movement - (7.76 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Sick Bay - (9.38 SQM)	Student Space (4)	
B00A - R0031 - Duplicating Workroom - (29.74 SQM)	Office (7)	
B00A - R0035 - Special Programs Room - (47.54 SQM)	Student Space (22)	
B00A - R0037 - Home Base - (46.99 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0038 - Home Base - (40.84 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0039 - Movement - (41.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (46.57 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1002 - Home Base X2 - (92.63 SQM) - Teaching Space: 2	Student Space (50)	
B00A - R1003 - Home Base - (45.76 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R1005 - Home Base - (49.5 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1006 - Home Base - (49.16 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1007 - Home Base - (49.92 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1009 - Movement - (59.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Movement - (89.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Home Base - (50.85 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1013 - Home Base - (51.71 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0013 - Movement - (72.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Home Base - (72.03 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0015 - Practical Activities - (11.3 SQM)	Student Space (5)	
B00D - R0003 - Movement - (21.07 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (24.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Communal Space - (216.95 SQM)	Student Space (100)	
B00D - R0013 - Movement - (31.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Canteen - (38.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Raised Platform - (74.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0023 - Movement - (94.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (54.48 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0007 - Practical Activities - M - 1hb - (18.68 SQM)	Student Space (8)	
B00E - R0008 - Home Base - M - (50.79 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0010 - Movement - (11.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (57.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Home Base - M - (50.5 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0015 - Practical Activities - M - 1hb - (53.16 SQM)	Student Space (24)	
B00E - R0017 - Duplicating Workroom - (26.05 SQM)	Office (6)	
B00E - R0022 - Practical Activities - M - 1hb - (51.33 SQM)	Student Space (23)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0023 - Movement - (7.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0025 - Home Base - (47.18 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0026 - Home Base - (38.24 SQM) - Teaching Space: 1	● Student Space (20)	
B00E - R0027 - Movement - (34.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Home Base - (64.77 SQM) - Teaching Space: 1	● Student Space (36)	
B00E - R0029 - Home Base - (55.4 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0030 - Movement - (23.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R0033 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0034 - Home Base - (54.9 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0035 - Home Base - (54.72 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R0036 - Movement - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0040 - Home Base - M - (52.69 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R1002 - Withdrawal Space - 1hb - (10.03 SQM)	● Student Space (4)	
B00E - R1003 - Home Base - (53.9 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1004 - Home Base - (51.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1005 - Home Base - (51.24 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R1010 - Practical Activities - 1hb - (39.14 SQM)	● Student Space (18)	
B00E - R1011 - Movement - (61.19 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (56.67 SQM) - Teaching Space: 1	● Student Space (31)	
B00F - R0002 - Withdrawal Space - 1hb - (8.22 SQM)	● Student Space (3)	
B00F - R0003 - Practical Activities - 1hb - (22.58 SQM)	● Student Space (10)	
B00F - R0004 - Movement - (7.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Home Base - (55.11 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R0007 - Movement - (17.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (22.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Practical Activities - 1hb - (15.17 SQM)	● Student Space (7)	
B00F - R0015 - Withdrawal Space - 1hb - (7.65 SQM)	● Student Space (3)	
B00F - R0016 - Home Base - (61.16 SQM) - Teaching Space: 1	● Student Space (34)	
B00F - R1004 - Practical Activities - 1hb - (14.85 SQM)	● Student Space (6)	
B00F - R1005 - Withdrawal Space - 1hb - (12.71 SQM)	● Student Space (5)	
B00F - R1006 - Home Base - (63.63 SQM) - Teaching Space: 1	● Student Space (35)	
B00J - R0008 - Reading Area - (232.07 SQM)	● Student Space (107)	
B00J - R1001 - Home Base - (59.1 SQM) - Teaching Space: 1	● Student Space (32)	
B00J - R1003 - Practical Activities - 1hb - (19.35 SQM)	● Student Space (8)	
B00J - R1004 - Withdrawal Space - 1hb - (9.15 SQM)	● Student Space (4)	
B00J - R1005 - Home Base - (60.23 SQM) - Teaching Space: 1	● Student Space (32)	
B00J - R1007 - Practical Activities - 1hb - (19.23 SQM)	● Student Space (8)	
B00J - R1008 - Withdrawal Space - 2hb - (11.74 SQM)	● Student Space (5)	
B00J - R1009 - Home Base - (60.69 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R1011 - Practical Activities - 1hb - (19.35 SQM)	● Student Space (8)	