

SCHOOL:	Lightning Ridge Central School (2395)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Walgett

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.





Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (9.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Practical Activities - 1hb - (5.04 SQM)	● Student Space (45)	
B00A - R0005 - Home Base - (51.56 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0006 - Home Base - (51.59 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0009 - Movement - (8.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Interview - (15.46 SQM)	● Office (3)	
B00B - R0002 - Home Base - M - (72.39 SQM) - Teaching Space: 1	● Student Space (113)	
B00B - R0003 - Staff Room Annexe - (14.35 SQM)	● Office (3)	
B00C - R0003 - Practical Activities - 1hb - (11.65 SQM)	● Student Space (5)	
B00C - R0005 - Home Base - (87.69 SQM) - Teaching Space: 1	● Student Space (92)	
B00C - R0006 - Home Base - (51.78 SQM) - Teaching Space: 1	● Student Space (41)	
B00C - R0007 - Practical Activities - 1hb - (22.01 SQM)	● Student Space (10)	
B00C - R0008 - Staff Kitchen - (26.74 SQM)	● Office (6)	
B00C - R0017 - Movement - (17.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Communal Space - (113.74 SQM)	● Student Space (50)	
B00C - R0023 - Raised Platform - (37.3 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (60.07 SQM) - Teaching Space: 1	● Student Space (32)	
B00D - R0003 - Practical Activities - 1hb - (16.44 SQM)	● Student Space (7)	
B00D - R0004 - Outdoor Learning Area - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Practical Activities - 1hb - (15.87 SQM)	● Student Space (7)	
B00D - R0007 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (35)	
B00D - R0009 - Outdoor Learning Area - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Withdrawal Space - 1hb - (11.89 SQM)	● Student Space (17)	
B00E - R0002 - Home Base - (59.95 SQM) - Teaching Space: 1	● Student Space (41)	
B00E - R0003 - Practical Activities - 1hb - (16.3 SQM)	● Student Space (42)	
B00E - R0004 - Outdoor Learning Area - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Practical Activities - 1hb - (16.3 SQM)	● Student Space (42)	
B00E - R0007 - Home Base - (60.04 SQM) - Teaching Space: 1	● Student Space (61)	
B00E - R0009 - Outdoor Learning Area - (13.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Withdrawal Space - 1hb - (11.86 SQM)	● Student Space (21)	
B00F - R0002 - Home Base - (59.94 SQM) - Teaching Space: 1	● Student Space (51)	
B00F - R0003 - Practical Activities - 1hb - (16.31 SQM)	● Student Space (7)	
B00F - R0004 - Outdoor Learning Area - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Practical Activities - 1hb - (16.3 SQM)	● Student Space (7)	
B00F - R0007 - Home Base - (59.85 SQM) - Teaching Space: 1	● Student Space (51)	
B00F - R0009 - Outdoor Learning Area - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Withdrawal Space - 1hb - (11.86 SQM)	● Student Space (13)	
B00J - R0001 - Interview - (12.94 SQM)	● Office (3)	
B00J - R0002 - Deputy Principal - (12.91 SQM)	● Office (3)	
B00J - R0003 - Movement - (37.53 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Clerical Office - (84.36 SQM)	● Office (21)	
B00J - R0005 - Principal - (17.57 SQM)	● Office (4)	
B00J - R0009 - Interview - (12.83 SQM)	● Office (3)	
B00J - R0010 - Interview - (12.88 SQM)	● Office (3)	
B00J - R0012 - Movement - (26.62 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - Duplicating Workroom - (12.81 SQM)	● Office (3)	
B00K - R0002 - Outdoor Workshop - (95.65 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00K - R0003 - Welding/Hot Metals Area - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00K - R0011 - Materials Workshop - Type 2 - (120.81 SQM)	● Student Space (75)	
B00K - R0012 - General Learning Space - (60.01 SQM) - Teaching Space: 1	● Student Space (46)	
B00K - R0013 - General Learning Space - (60.06 SQM) - Teaching Space: 1	● Student Space (46)	
B00K - R0020 - Preparation - (14.03 SQM)	Not Applicable	Circulation or storage space.
B00K - R0021 - General Learning Space - (59.13 SQM) - Teaching Space: 1	● Student Space (46)	
B00K - R0022 - Materials Workshop - Type 2 - (104.8 SQM)	● Student Space (90)	
B00K - R0023 - General Learning Space - (60.88 SQM) - Teaching Space: 1	● Student Space (46)	
B00L - R0001 - Entry - (24.82 SQM)	Not Applicable	Circulation or storage space.
B00L - R0006 - Movement - (10.3 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Seminar - (12.95 SQM)	● Office (3)	
B00L - R0010 - Seminar - (12.95 SQM)	● Office (3)	
B00L - R0011 - Audio Visual Workroom - (28.3 SQM)	● Student Space (78)	
B00L - R0015 - Computer Learning Space - (64.75 SQM) - Teaching Space: 1	● Student Space (59)	
B00L - R0016 - Workroom - (56.86 SQM)	● Office (14)	
B00L - R0018 - Main Area - (236.64 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Staff Study - (16.32 SQM)	● Office (4)	
B00M - R0009 - Interview - (12.8 SQM)	● Office (3)	
B00M - R0010 - Interview - (13.06 SQM)	● Office (3)	
B00M - R0011 - Movement - (32.98 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Duplicating Workroom - (30.34 SQM)	● Office (7)	
B00M - R0013 - Staff Study - (94.77 SQM)	● Office (23)	
B00M - R0014 - Commonroom - (77.21 SQM)	● Office (19)	
B00N - R0004 - Movement - (22.38 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Movement - (19.74 SQM)	Not Applicable	Circulation or storage space.
B00N - R0012 - Multi-Purpose Space - (477.34 SQM)	● Student Space (221)	
B00O - R0001 - Canteen - (44.7 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0007 - General Learning Space - (59.82 SQM) - Teaching Space: 1	● Student Space (46)	
B00Q - R0008 - General Learning Space - (59.82 SQM) - Teaching Space: 1	● Student Space (46)	
B00Q - R0009 - Visual Arts Workshop - (99.25 SQM)	● Student Space (75)	
B00Q - R0010 - Dark Room - (27.23 SQM)	● Office (6)	
B00Q - R0011 - Preparation - (46.07 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0012 - Movement - (11.09 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0017 - General Learning Space - (60.13 SQM) - Teaching Space: 1	● Student Space (46)	
B00Q - R0018 - General Learning Space - (60.29 SQM) - Teaching Space: 1	● Student Space (46)	
B00Q - R0019 - Science Laboratory - (99.54 SQM)	● Student Space (75)	
B00R - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (30)	
B00R - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (38)	
B00R - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (25)	
B00R - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (38)	
B00R - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (25)	
B00S - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (25)	
B00S - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (38)	
B00S - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (25)	
B00S - R0006 - Home Base - (59.19 SQM) - Teaching Space: 1	● Student Space (38)	
B00S - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (25)	
B00T - R0002 - Seminar - Type 2 - (19.12 SQM)	● Office (4)	
B00T - R0005 - Computer Learning Space - (91.37 SQM) - Teaching Space: 1	● Student Space (75)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 601 10739 - OS 601 10739 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (78)	
OS 601 10742 - OS 601 10742 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (78)	
OS 601 10999 - OS 601 10999 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (78)	
OS 601 12844 - OS 601 12844 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (78)	