











Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (16.64 SQM)	Office (4)	
B00A - R0002 - Clerical Office - (11.79 SQM)	Office (2)	
B00A - R0003 - Entry Vestibule - (10.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Sick Bay - (13.11 SQM)	Student Space (6)	
B00A - R0008 - Principal - (16.03 SQM)	Office (4)	
B00A - R0012 - Principal - (17.44 SQM)	Office (4)	
B00A - R9003 - Special Programs Room - (44.36 SQM)	Student Space (20)	
B00A - R9004 - Staff Kitchen - (8.38 SQM)	Office (2)	
B00B - R0001 - Movement - (79.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Communal Space - (55.55 SQM)	Student Space (25)	
B00B - R0009 - Home Base - (58.59 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R0010 - Home Base - (56.88 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R1001 - Movement - (65.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Home Base - (57.11 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R1003 - Home Base - (56.08 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R1004 - Home Base - (55.84 SQM) - Teaching Space: 1	Student Space (65)	
B00C - R0001 - Home Base - E - (44.86 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0002 - Practical Activities - E - (10.26 SQM)	Student Space (4)	
B00C - R0006 - Home Base - E - (55.81 SQM) - Teaching Space: 1	Student Space (75)	
B00C - R0007 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Movement - (18.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Reading Area - (111.51 SQM)	Student Space (51)	
B00C - R1002 - Movement - (6 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (56.82 SQM) - Teaching Space: 1	Student Space (195)	
B00D - R0006 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (223)	
B00D - R0009 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Home Base - (57.47 SQM) - Teaching Space: 1	Student Space (223)	
B00D - R9003 - Special Programs Room - (56.63 SQM)	Student Space (26)	
B00E - R0001 - Home Base - (56.95 SQM) - Teaching Space: 1	Student Space (149)	
B00E - R0004 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Home Base - (57.18 SQM) - Teaching Space: 1	Student Space (149)	
B00E - R0008 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Home Base - (57.17 SQM) - Teaching Space: 1	Student Space (223)	
B00F - R0003 - Movement - (12.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (57.07 SQM) - Teaching Space: 1	Student Space (195)	
B00F - R0008 - Movement - (9.55 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Withdrawal Space - 1hb - (21.85 SQM)	Student Space (10)	
B00G - R0004 - Movement - (7.69 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (63.37 SQM) - Teaching Space: 1	Student Space (186)	
B00G - R0008 - Home Base - (85.6 SQM) - Teaching Space: 1	Student Space (223)	
B00G - R0012 - Movement - (20.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Deputy Principal - (17.36 SQM)	Office (4)	
B00G - R0016 - Movement - (21.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Movement - (33.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (57.02 SQM) - Teaching Space: 1	Student Space (223)	
B00H - R0005 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Movement - (10.56 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (19.89 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Canteen - (22.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0013 - Interview - (14.95 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0023 - Staff Room - (11.2 SQM)	 Office (2)	
B00J - R0025 - Staff Room - (90.62 SQM)	 Office (22)	
B00J - R0026 - Staff Kitchen - (22.62 SQM)	 Office (5)	
B00J - R0028 - Movement - (23.79 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Home Base - (57.37 SQM) - Teaching Space: 1	 Student Space (223)	
B00K - R0004 - Movement - (5.49 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Home Base - (57.45 SQM) - Teaching Space: 1	 Student Space (223)	
B00K - R0008 - Home Base - (57.05 SQM) - Teaching Space: 1	 Student Space (297)	
B00K - R0011 - Movement - (6.71 SQM)	Not Applicable	Circulation or storage space.
B00K - R0013 - Home Base - (57.29 SQM) - Teaching Space: 1	 Student Space (297)	
B00K - R0017 - Movement - (21.24 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Communal Space - (146.89 SQM)	 Student Space (68)	
B00N - R0002 - Raised Platform - (57.61 SQM)	Not Applicable	Circulation or storage space.
B00N - R0016 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00N - R0017 - Movement - (10.8 SQM)	Not Applicable	Circulation or storage space.
B00N - R0019 - Movement - (13.28 SQM)	Not Applicable	Circulation or storage space.