

SCHOOL:	Mawarra Public School (4466)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Camden
LOCAL GOVERNMENT AREA:	Camden

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.














Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (53.31 SQM)	Office (13)	
B00A - R0002 - Duplicating Workroom - (13.56 SQM)	Office (3)	
B00A - R0006 - Staff Room Annexe - (12.99 SQM)	Office (3)	
B00A - R0007 - Sick Bay - (11.29 SQM)	Student Space (40)	
B00A - R0008 - Clerical Office - (18.3 SQM)	Office (4)	
B00A - R0009 - Entry Vestibule - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal - (19.69 SQM)	Office (4)	
B00A - R0012 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (72.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Reading Area - (177.92 SQM)	Student Space (166)	
B00C - R0001 - Home Base - (60.32 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0002 - Practical Activities - 1hb - (11.25 SQM)	Student Space (28)	
B00C - R0004 - Practical Activities - 1hb - (11.71 SQM)	Student Space (28)	
B00C - R0005 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0006 - Home Base - (60.95 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0007 - Practical Activities - 1hb - (11.26 SQM)	Student Space (28)	
B00C - R0010 - Practical Activities - 1hb - (11.25 SQM)	Student Space (28)	
B00C - R0011 - Home Base - (60.22 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0012 - Movement - (93.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Canteen - (27.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Interview - (12.43 SQM)	Office (3)	
B00D - R0009 - Staff Room Annexe - (13.77 SQM)	Office (3)	
B00D - R0012 - Staff Room Annexe - (14.29 SQM)	Office (3)	
B00D - R0017 - Movement - (31.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (75.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (94.24 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0005 - Home Base - (94.81 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0013 - Home Base - (64.64 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0014 - Home Base - (64.64 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0019 - Movement - (106.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Room Annexe - (13.88 SQM)	Office (3)	
B00F - R0002 - Practical Activities - 1hb - (11.5 SQM)	Student Space (31)	
B00F - R0003 - Home Base - (61.76 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0004 - Home Base - (61.6 SQM) - Teaching Space: 1	Student Space (35)	
B00F - R0005 - Practical Activities - 1hb - (11.5 SQM)	Student Space (31)	
B00F - R0010 - Movement - (75.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (35.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Communal Space - (202.94 SQM)	Student Space (37)	
B00G - R0008 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (9.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Raised Platform - (48.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (14.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Special Programs Room - (32.15 SQM)	Student Space (31)	
B00G - R0018 - Staff Kitchen - (18.61 SQM)	Office (4)	
B00H - R0002 - Practical Activities/Movement - 1hb - (18.55 SQM)	Student Space (26)	
B00H - R0004 - Home Base - (60.5 SQM) - Teaching Space: 1	Student Space (33)	
B00H - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0006 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (33)	
B00H - R0008 - Practical Activities/Movement - 1hb - (19.14 SQM)	 Student Space (26)	
B00H - R0010 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Special Programs Room - (32.29 SQM)	 Student Space (33)	
B00I - R0002 - Practical Activities/Movement - 1hb - (18.4 SQM)	 Student Space (26)	
B00I - R0004 - Home Base - (60.39 SQM) - Teaching Space: 1	 Student Space (33)	
B00I - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	 Student Space (21)	
B00I - R0006 - Home Base - (60.56 SQM) - Teaching Space: 1	 Student Space (33)	
B00I - R0008 - Practical Activities/Movement - 1hb - (19.13 SQM)	 Student Space (26)	
B00I - R0010 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0013 - Special Programs Room - (32.34 SQM)	 Student Space (33)	
OH 060 17030 - OH 060 17030 - OSHC Hub 60 - (SQM)	 Student Space (38)	
OS 602 10201 - OS 602 10201 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (87)	
OS 602 15816 - OS 602 15816 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16787 - OS 602 16787 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	