

| | |
|-------------------------------|---|
| SCHOOL: | Mayfield East Public School (2506) |
| AMU REGION: | Hunter/Central Coast |
| STATE ELECTORATE: | Newcastle |
| LOCAL GOVERNMENT AREA: | Newcastle |

2506 - Mayfield East Public School
Site Plan (11527)



1:690

Printed: 30-Mar-2021

Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B00A - R0001 - Movement - (17.85 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0002 - Sick Bay - (9.17 SQM) | ● Student Space (4) | |
| B00A - R0004 - Duplicating Workroom - (13.44 SQM) | ● Office (3) | |
| B00A - R0005 - Movement - (10.7 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0006 - Staff Room Annexe - (14.95 SQM) | ● Office (3) | |
| B00A - R0007 - Staff Room Annexe - (14.95 SQM) | ● Office (3) | |
| B00A - R0009 - Principal - (15.26 SQM) | ● Office (3) | |
| B00A - R0010 - Entry Vestibule - (9.43 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0011 - Clerical Office - (18.41 SQM) | ● Office (4) | |
| B00B - R0002 - Movement - (108.89 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R0003 - Clerical Office - (12.65 SQM) | ● Office (3) | |
| B00B - R0005 - Duplicating Workroom - (12.38 SQM) | ● Office (3) | |
| B00B - R0006 - Home Base - (42.51 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R0007 - Practical Activities - 1hb - (5.17 SQM) | ● Student Space (2) | |
| B00B - R0008 - Home Base - (47.63 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R0009 - Home Base - (47.56 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R0014 - Special Programs Room - (17.42 SQM) | ● Student Space (8) | |
| B00B - R0015 - Home Base - (47.63 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R0016 - Home Base - (47.62 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R0022 - Practical Activities - 4hb - (27.1 SQM) | ● Student Space (12) | |
| B00B - R1001 - Movement - (17.04 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1002 - Withdrawal Space - 1hb - (9.5 SQM) | ● Student Space (4) | |
| B00B - R1003 - Movement - (82.97 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1004 - Home Base - (49.17 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R1005 - Home Base - (49.35 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R1006 - Home Base - (49.16 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R1007 - Home Base - (49.22 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R1008 - Home Base - (49.43 SQM) - Teaching Space: 1 | ● Student Space (71) | |
| B00B - R1009 - Movement - (17.12 SQM) | Not Applicable | Circulation or storage space. |
| B00B - R1010 - Special Programs Room - (17.46 SQM) | ● Student Space (8) | |
| B00C - R0002 - Movement - (40.23 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0001 - Staff Room - (61.38 SQM) | ● Office (15) | |
| B00D - R0002 - Movement - (11.03 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0007 - Special Programs Room - (74.07 SQM) | ● Student Space (34) | |
| B00D - R0009 - Movement - (77.99 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0011 - Movement - (8.37 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0012 - Special Programs Room - (47.67 SQM) | ● Student Space (22) | |
| B00D - R0013 - Special Programs Room - (56.14 SQM) | ● Student Space (26) | |
| B00E - R0001 - Movement - (59.95 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0002 - Canteen - (23.01 SQM) | Not Applicable | Circulation or storage space. |
| B00E - R0004 - Movement - (8.68 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0002 - Communal Space - (144.79 SQM) | ● Student Space (67) | |
| B00H - R0003 - Movement - (5.6 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0004 - Raised Platform - (62.32 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0005 - Movement - (11.3 SQM) | Not Applicable | Circulation or storage space. |
| B00H - R0006 - Movement - (13.52 SQM) | Not Applicable | Circulation or storage space. |
| OS 602 18301 - OS 602 18301 - Learning Unit - Standard With P.A.A. - (76 SQM) | ● Student Space (35) | |
| OS 606 19146 - OS 606 19146 - Learning Unit - Standard With P.A.A A/C - (76 SQM) | ● Student Space (35) | |