

<b>SCHOOL:</b>	<b>Mulwaree High School (8468)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Goulburn</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Goulburn Mulwaree</b>

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Commonroom - (10.56 SQM)	Office (2)	
B00A - R0008 - Movement - (40.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Interview/Office - Type 1 - (27.08 SQM)	Office (6)	
B00A - R0016 - Movement - (26.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Commonroom - (116.03 SQM)	Office (29)	
B00A - R0022 - Clinic - Boys - (13.5 SQM)	Office (3)	
B00A - R0023 - Principal Office - (21.92 SQM)	Office (5)	
B00A - R0031 - Commonroom - (22.27 SQM)	Office (5)	
B00A - R0034 - Duplicating Workroom - (25.91 SQM)	Office (6)	
B00A - R0037 - Movement - (8.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Movement - (8.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Movement - (93.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0042 - Outdoor Learning Area - (66.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Deputy Principal Office - (22.75 SQM)	Office (5)	
B00A - R0048 - Senior Study - (71.65 SQM)	Office (17)	
B00A - R0049 - Deputy Principal Office - (48.66 SQM)	Office (12)	
B00A - R0053 - Student Reception - (20.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Movement - (25.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Movement - (14.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0056 - Administration - Clerical - (62.33 SQM)	Office (15)	
B00A - R0057 - Interview/Meeting - (16.36 SQM)	Office (4)	
B00A - R0058 - Public Reception - (18.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (64.53 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1002 - General Learning Space - (53.13 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - Movement - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - General Learning Space - (53.22 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1005 - General Learning Space - (64.27 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1006 - Movement - (61.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R1007 - General Learning Space - (53 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - General Learning Space - (52.78 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - General Learning Space - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - Staff Study - (30.61 SQM)	Office (7)	
B00A - R1011 - Staff Study - (12.56 SQM)	Office (3)	
B00A - R1012 - Ancillary Staff - (16.65 SQM)	Office (4)	
B00A - R1014 - Clinic - Girls - (17.12 SQM)	Office (4)	
B00A - R1015 - Staff Study - (12.74 SQM)	Office (3)	
B00A - R1021 - Movement - (74.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Movement - (63.18 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Music Learning Space - (93.94 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0003 - Staff Study - (32.69 SQM)	Office (8)	
B00B - R0005 - Laboratory L.S. - (94.31 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0007 - Movement - (132.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Laboratory L.S. - (88.03 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0012 - Laboratory L.S. - (88.03 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0015 - Staff Study - (24.31 SQM)	Office (6)	
B00B - R0021 - Preparation - Science - (50.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Laboratory L.S. - (92.95 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R1007 - Movement - (135.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1023 - Seminar - Type 2 - (51.31 SQM)	Office (12)	
B00B - R1024 - Laboratory L.S. - (63.22 SQM) - Teaching Space: 1	Student Space (29)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1025 - Laboratory L.S. - (63.01 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1026 - Seminar - Type 2 - (51.55 SQM)	Office (12)	
B00B - R1030 - Laboratory L.S. - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1031 - Seminar - Type 2 - (36.91 SQM)	Office (9)	
B00B - R1032 - Preparation - (49.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Multi-Purpose Space - (457.63 SQM)	Student Space (212)	
B00C - R0009 - Student Canteen - (11.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Student Canteen - (54.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (132.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (130.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Stage - (101.74 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Movement - (29.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Movement - (87.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Music Learning Space - (81.47 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R1002 - Movement - (21.15 SQM)	Not Applicable	Circulation or storage space.
B00C - R1003 - Music Learning Space - (81.02 SQM) - Teaching Space: 1	Student Space (37)	
B00C - R1004 - Movement - (232.58 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Multi-Purpose Space - (42.15 SQM)	Student Space (19)	
B00C - R1015 - Movement - (31.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Materials Technology L.S. - (67.63 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0007 - Metal Technology Bay - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Metal Technology Bay - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Metal Technology Bay - (10.68 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Welding Area - (9.96 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Materials Technology L.S. - (67.06 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R0014 - Materials Technology L.S. - (78.97 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0015 - Wood Technology Bay - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Wood Technology Bay - (5.75 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Materials Technology L.S. - (77.46 SQM) - Teaching Space: 1	Student Space (35)	
B00D - R0023 - Movement - (163.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Art Learning Space - (61.03 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0026 - Art Learning Space - (60.59 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0028 - Staff Study - (11.09 SQM)	Office (2)	
B00D - R0031 - Metal Technology Bay - (68.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0034 - Hospitality Space - (19.58 SQM)	Student Space (9)	
B00D - R0035 - Hospitality Space - (41.76 SQM)	Student Space (19)	
B00D - R1001 - Staff Study - (55.76 SQM)	Office (13)	
B00D - R1005 - Computer Learning Space - (66.07 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1007 - Movement - (7.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Computer Learning Space - (66.3 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1009 - Movement - (179.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Food Technology L.S. - (96.23 SQM) - Teaching Space: 1	Student Space (44)	
B00D - R1016 - Darkroom Space - (31.82 SQM)	Office (7)	
B00D - R1018 - Design L.S. - (69.35 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1020 - Design L.S. - (69.19 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R1021 - Preparation - Materials - (5.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1022 - Staff Study - (19.46 SQM)	Office (4)	
B00D - R1026 - Kitchen - Type 1 - (91.66 SQM)	Student Space (42)	
B00D - R1027 - Movement - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R1028 - Preparation - Materials - (12.68 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1029 - Preparation - Materials - (12.84 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - General Learning Space - (52.63 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0010 - Staff Study - (26.6 SQM)	● Office (6)	
B00E - R0011 - General Learning Space - (51.98 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0012 - General Learning Space - (63.23 SQM) - Teaching Space: 1	● Student Space (29)	
B00E - R0013 - General Learning Space - (67.04 SQM) - Teaching Space: 1	● Student Space (31)	
B00E - R0015 - Movement - (123.19 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Staff Room - (40.57 SQM)	● Office (10)	
B00E - R0017 - Movement - (60.5 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - General Learning Space - (52.42 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1004 - General Learning Space - (52.49 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1006 - Senior Seminar - (41.76 SQM)	● Office (10)	
B00E - R1009 - Staff Study - (25.31 SQM)	● Office (6)	
B00E - R1010 - General Learning Space - (53.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - General Learning Space - (65.11 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1012 - General Learning Space - (66.1 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1013 - Movement - (120.41 SQM)	Not Applicable	Circulation or storage space.
B00F - M0003 - Movement - (43.17 SQM)	Not Applicable	Circulation or storage space.
B00F - M0004 - Workroom - (47.04 SQM)	● Office (11)	
B00F - M1001 - Movement - (100.88 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Main Area - (203.47 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Workroom - (20.17 SQM)	● Office (5)	
B00F - R0006 - Seminar - (25.73 SQM)	● Office (6)	
B00F - R0007 - Movement - (54.2 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (108.8 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Seminar - (14.98 SQM)	● Office (3)	
B00F - R1003 - Seminar - (15.17 SQM)	● Office (3)	
B00F - R1004 - Seminar - (15.4 SQM)	● Office (3)	
B00F - R1005 - Seminar - (15.17 SQM)	● Office (3)	
B00F - R1006 - Seminar - (14.86 SQM)	● Office (3)	
B00J - R0005 - Movement - (36.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (13.65 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Movement - (14.22 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Lecture Space - (26.96 SQM) - Teaching Space: 2	● Student Space (12)	
OS 601 13513 - OS 601 13513 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13535 - OS 601 13535 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13834 - OS 601 13834 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14851 - OS 601 14851 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14905 - OS 601 14905 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14984 - OS 601 14984 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16319 - OS 601 16319 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 13026 - OS 602 13026 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	