

SCHOOL:	Oak Flats High School (8906)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Shellharbour
LOCAL GOVERNMENT AREA:	Shellharbour

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (140.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Darkroom Space - (25.35 SQM)	Office (6)	
B00A - R0011 - Food Technology L.S. - (65.75 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R0013 - Design L.S. - (78.91 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0019 - Staff Study - (25.31 SQM)	Office (6)	
B00A - R0021 - Preparation - (15.8 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Laboratory L.S. - (92.31 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0033 - Preparation - (22.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Food Technology L.S. - (101.05 SQM) - Teaching Space: 1	Student Space (46)	
B00A - R1002 - General Learning Space - (53.06 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - General Learning Space - (51.07 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1005 - General Learning Space - (51.4 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1006 - Staff Study - (25.27 SQM)	Office (6)	
B00A - R1007 - Staff Study - (25.31 SQM)	Office (6)	
B00A - R1008 - Computer Learning Space - (52.62 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - Computer Learning Space - (52.55 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1013 - Staff Study - (31.58 SQM)	Office (7)	
B00A - R1015 - Design L.S. - (64.32 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1020 - General Learning Space - (65.71 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1023 - Movement - (120.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Movement - (8.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (218.4 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Student Canteen - (42.93 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Materials Technology L.S. - (100.99 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R0005 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (40.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Design L.S. - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0008 - Design/Technology L.S. - (51.62 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0009 - Staff Study - (27.99 SQM)	Office (6)	
B00C - R0012 - Movement - (50.83 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Materials Technology L.S. - (75.52 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0015 - Wood Technology Bay - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0016 - Wood Technology Bay - (8.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Materials Technology L.S. - (77.47 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R0019 - Music Learning Space - (71.22 SQM) - Teaching Space: 1	Student Space (33)	
B00C - R9003 - Movement - (8.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R9006 - Movement - (30.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R9008 - Movement - (22.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R9012 - Movement - (10.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R9013 - Workshop Area - (34.23 SQM)	Student Space (15)	
B00C - R9014 - Metal Technology Bay - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R0038 - Staff Study - (104.75 SQM)	Office (26)	
B00D - R0039 - Movement - (153.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Interview/Meeting - (40.39 SQM)	Office (10)	
B00D - R0042 - Deputy Principal Office - (17.43 SQM)	Office (4)	
B00D - R0047 - Interview/Meeting - (12.65 SQM)	Office (3)	
B00D - R0048 - Principal Office - (25.21 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0049 - Deputy Principal Office - (18.45 SQM)	Office (4)	
B00D - R0050 - Clinic - Boys - (13.65 SQM)	Office (3)	
B00D - R0052 - Clinic - Girls - (14.12 SQM)	Office (3)	
B00D - R0053 - Administration - Clerical - (61.28 SQM)	Office (15)	
B00D - R0055 - Interview/Meeting - (11.17 SQM)	Office (2)	
B00D - R0056 - Interview/Meeting - (11.7 SQM)	Office (2)	
B00D - R0057 - Deputy Principal Office - (11.39 SQM)	Office (2)	
B00D - R1001 - Music Learning Space - (65.9 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1005 - Staff Study - (36.43 SQM)	Office (9)	
B00D - R1008 - General Learning Space - (51.48 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1009 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1010 - General Learning Space - (51.48 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1012 - Staff Study - (24.4 SQM)	Office (6)	
B00D - R1017 - General Learning Space - (51.55 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1023 - Movement - (101.26 SQM)	Not Applicable	Circulation or storage space.
B00D - R1024 - General Learning Space - (64.45 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1025 - General Learning Space - (45.8 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0001 - Movement - (6.7 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Art Learning Space - (52.57 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Art Learning Space - (51.77 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0007 - Art Learning Space - (51.84 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - Staff Study - (52.78 SQM)	Office (13)	
B00E - R0011 - Laboratory L.S. - (85.49 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0012 - Preparation - (28.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Growing/Breeding - (9.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Laboratory L.S. - (84.33 SQM) - Teaching Space: 1	Student Space (39)	
B00E - R0015 - Staff Study - (25.8 SQM)	Office (6)	
B00E - R0017 - Movement - (103.41 SQM)	Not Applicable	Circulation or storage space.
B00E - R0019 - Movement - (32.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Staff Study - (39.86 SQM)	Office (9)	
B00E - R1005 - General Learning Space - (38.22 SQM) - Teaching Space: 1	Student Space (17)	
B00E - R1006 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1007 - General Learning Space - (51.35 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1008 - General Learning Space - (52.71 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - General Learning Space - (52.64 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1010 - General Learning Space - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1011 - General Learning Space - (51.33 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1012 - General Learning Space - (50.98 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R1013 - Staff Study - (25.96 SQM)	Office (6)	
B00E - R1015 - Movement - (99.8 SQM)	Not Applicable	Circulation or storage space.
B00H - M1001 - Main Area - (134.48 SQM)	Not Applicable	Circulation or storage space.
B00H - M1003 - Seminar - (20.15 SQM)	Office (5)	
B00H - R0001 - Laboratory L.S. - (87.59 SQM) - Teaching Space: 1	Student Space (40)	
B00H - R0003 - Movement - (40.48 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Laboratory L.S. - (89.04 SQM) - Teaching Space: 1	Student Space (41)	
B00H - R0005 - Preparation - (47.86 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Laboratory L.S. - (90.75 SQM) - Teaching Space: 1	Student Space (42)	
B00H - R0008 - Laboratory L.S. - (87.78 SQM) - Teaching Space: 1	Student Space (40)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0010 - Preparation - (47.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (30.98 SQM)	Not Applicable	Circulation or storage space.
B00H - R1002 - Workroom - (20.88 SQM)	Office (5)	
B00H - R1006 - Main Area - (379.84 SQM)	Not Applicable	Circulation or storage space.
B00H - R1007 - Seminar - (12.94 SQM)	Office (3)	
B00H - R1008 - Seminar - (12.72 SQM)	Office (3)	
B00H - R1012 - Seminar - (11.8 SQM)	Office (2)	
B00H - R1013 - Seminar - (11.55 SQM)	Office (2)	
B00H - R1014 - Seminar - (11.49 SQM)	Office (2)	
B00H - R1015 - Audio Visual Workroom - (28.36 SQM)	Student Space (13)	
B00H - R1017 - Movement - (24.26 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Pupil Entry - (22.97 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Student Canteen - (16.34 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Multi-Purpose Space - (440.76 SQM)	Student Space (204)	
B00J - R0014 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Stage - (86.72 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - General Assistants - (10.43 SQM)	Office (2)	
B00M - R0001 - Movement - (19.75 SQM)	Not Applicable	Circulation or storage space.
NS 020 13394 - NS 020 13394 - Staff Study/Store - (38 SQM)	Not Applicable	Circulation or storage space.
NS 110 13411 - NS 110 13411 - Learning Unit - Single Secondary/Secure - (57 SQM)	Student Space (26)	
NS 200 13415 - NS 200 13415 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 12175 - OS 600 12175 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 17672 - OS 600 17672 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 11724 - OS 601 11724 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13507 - OS 601 13507 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14189 - OS 601 14189 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14991 - OS 601 14991 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	