


VENTILATION AUDIT REPORT Version 2

SCHOOL:	Orange Grove Public School (2812)
AMU REGION:	Sydney
STATE ELECTORATE:	Balmain
LOCAL GOVERNMENT AREA:	Inner West

2812 - Orange Grove Public School
Site Plan (11581)








Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (16.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Room - (47.19 SQM)	Office (11)	
B00A - R0012 - Movement - (16.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Principal - (18.26 SQM)	Office (4)	
B00A - R0023 - Movement - (72.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Clerical/Printing - (36.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Sick Bay - (10.01 SQM)	Student Space (4)	
B00A - R0030 - Home Base - (47.71 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0031 - Home Base - (47.08 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0032 - Communal Space - (138.95 SQM)	Student Space (64)	
B00A - R1001 - Movement - (86.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Home Base - (47.91 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1005 - Home Base - (47.97 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1006 - Home Base - (47.97 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1007 - Home Base - (47.8 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1008 - Deputy Principal - (8.27 SQM)	Office (2)	
B00A - R1009 - Home Base - (54.92 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0001 - Practical Activities - 1hb - (8.83 SQM)	Student Space (4)	
B00B - R0003 - Movement - (18.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Withdrawal Space - 1hb - (19.15 SQM)	Student Space (8)	
B00B - R0005 - Withdrawal Space - 1hb - (19.19 SQM)	Student Space (8)	
B00B - R0006 - Staff Room Annexe - (8.8 SQM)	Office (2)	
B00B - R0008 - Special Programs Room - (42.74 SQM)	Student Space (19)	
B00B - R0009 - Practical Activities - 1hb - (42.84 SQM)	Student Space (19)	
B00B - R0010 - Home Base - (30.51 SQM) - Teaching Space: 1	Student Space (17)	
B00B - R0011 - Practical Activities - 1hb - (11.55 SQM)	Student Space (5)	
B00B - R0016 - Movement - (10.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Practical Activities - 1hb - (12.3 SQM)	Student Space (5)	
B00B - R0019 - Withdrawal Space - 1hb - (28.88 SQM)	Student Space (13)	
B00B - R0020 - Home Base - (42.47 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0021 - Communal Space - (133.51 SQM)	Student Space (61)	
B00B - R0022 - Home Base - (32.52 SQM) - Teaching Space: 1	Student Space (18)	
B00C - R0003 - Special Programs Room - (42.08 SQM)	Student Space (19)	
B00C - R0010 - Reading Area - (223.01 SQM)	Student Space (103)	
B00D - R0001 - Staff Room Annexe - (16.12 SQM)	Office (4)	
B00D - R0002 - Movement - (6.13 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - (71.17 SQM) - Teaching Space: 1	Student Space (40)	
B00D - R0005 - Home Base - (44.7 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0006 - Home Base - (45.42 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0016 - Home Base - (48.1 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0017 - Home Base - (48.11 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0018 - Home Base - (50.38 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0019 - Movement - (18.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Practical Activities - 1hb - (28.53 SQM)	Student Space (13)	
B00D - R0022 - Movement - (37.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Canteen - (22.32 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Movement - (30.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0010 - Withdrawal - Pre - (12.22 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0013 - Home Base - Pre - (84.41 SQM) - Teaching Space: 1	 Student Space (47)	
B00E - R0015 - Movement - (17.85 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (21.92 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Canteen - (13.55 SQM)	Not Applicable	Circulation or storage space.
OS 602 10150 - OS 602 10150 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 11752 - OS 602 11752 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 612 10531 - OS 612 10531 - Learning Unit - Double With Resource - (152 SQM)	 Student Space (70)	
OS 612 19528 - OS 612 19528 - Learning Unit - Double With Resource - (152 SQM)	 Student Space (70)	