

| | |
|-------------------------------|--------------------------------|
| SCHOOL: | Peel High School (8525) |
| AMU REGION: | North Western NSW |
| STATE ELECTORATE: | Tamworth |
| LOCAL GOVERNMENT AREA: | Tamworth |

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the '**Advice for school based staff**' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B001 - R0001 - Design L.S. - (64 SQM) - Teaching Space: 1 | Student Space (35) | |
| B001 - R0002 - Movement - (8.88 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0003 - Materials Technology L.S. - (80.23 SQM) - Teaching Space: 1 | Student Space (37) | |
| B001 - R0004 - Materials Technology L.S. - (104.56 SQM) - Teaching Space: 1 | Student Space (48) | |
| B001 - R0006 - Staff Study - (24.55 SQM) | Office (6) | |
| B001 - R0011 - Materials Technology L.S. - (65.17 SQM) - Teaching Space: 1 | Student Space (30) | |
| B001 - R0014 - Seminar/Technology Space - (24.6 SQM) | Office (6) | |
| B001 - R0015 - Design L.S. - (64 SQM) - Teaching Space: 1 | Student Space (38) | |
| B001 - R0016 - Workshop - (49.42 SQM) | Student Space (30) | |
| B001 - R0018 - Art Learning Space - (62.85 SQM) - Teaching Space: 1 | Student Space (35) | |
| B001 - R0019 - Staff Study - (14.78 SQM) | Office (3) | |
| B001 - R0021 - Art Learning Space - (65.18 SQM) - Teaching Space: 1 | Student Space (30) | |
| B001 - R0022 - Movement - (9.38 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0024 - Computer Learning Space - (64.46 SQM) - Teaching Space: 1 | Student Space (29) | |
| B001 - R0025 - Senior Study - (31.24 SQM) | Office (7) | |
| B001 - R0027 - Movement - (73.54 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0028 - Art Learning Space - (63.5 SQM) - Teaching Space: 1 | Student Space (29) | |
| B001 - R0030 - Movement - (164.31 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0033 - Outdoor Workshop - (98.17 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0034 - Metal Technology Bay - (165.95 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0035 - Movement - (144.33 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0001 - Laboratory L.S. - (91.5 SQM) - Teaching Space: 1 | Student Space (50) | |
| B002 - R0002 - Movement - (9.13 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0003 - Laboratory L.S. - (91.53 SQM) - Teaching Space: 1 | Student Space (50) | |
| B002 - R0004 - Preparation - (23.53 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0005 - Laboratory L.S. - (91.9 SQM) - Teaching Space: 1 | Student Space (52) | |
| B002 - R0006 - Preparation - (48.68 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0007 - Laboratory L.S. - (91.59 SQM) - Teaching Space: 1 | Student Space (52) | |
| B002 - R0009 - Staff Study - (36.37 SQM) | Office (9) | |
| B002 - R0013 - Laboratory L.S. - (91.49 SQM) - Teaching Space: 1 | Student Space (52) | |
| B002 - R0014 - Preparation - (48.67 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0015 - Laboratory L.S. - (91.49 SQM) - Teaching Space: 1 | Student Space (52) | |
| B002 - R0016 - Preparation - (23.43 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0017 - Movement - (157.2 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0018 - Food Technology L.S. - (101.41 SQM) - Teaching Space: 1 | Student Space (65) | |
| B002 - R0019 - Staff Study - (14.89 SQM) | Office (3) | |
| B002 - R0020 - Senior Study - (64.18 SQM) | Office (16) | |
| B002 - R0026 - Design L.S. - (63.17 SQM) - Teaching Space: 1 | Student Space (35) | |
| B002 - R0029 - Food Technology L.S. - (101.41 SQM) - Teaching Space: 1 | Student Space (56) | |
| B002 - R0030 - Food/Research Space - (16.07 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0038 - Movement - (89.57 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0040 - Outdoor Workshop - (37.23 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0003 - Movement - (19.67 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0004 - Music Learning Space - (89.89 SQM) - Teaching Space: 1 | Student Space (49) | |
| B003 - R0005 - Tiered Learning Area - (185.59 SQM) | Student Space (86) | |
| B003 - R0016 - Movement - (36.03 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0017 - Movement - (36.62 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0018 - Movement - (64.49 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R1001 - Staff Study - (16.72 SQM) | Office (4) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B003 - R1002 - Movement - (12.53 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R1004 - Music Learning Space - (70.05 SQM) - Teaching Space: 1 | ● Student Space (90) | |
| B004 - M0001 - Seminar - (9.95 SQM) | ○ Office (2) | |
| B004 - M0002 - Main Area - (110.62 SQM) | Not Applicable | Circulation or storage space. |
| B004 - M0005 - Staff Study - (9.95 SQM) | ○ Office (2) | |
| B004 - M0006 - Staff Study - (9.95 SQM) | ○ Office (2) | |
| B004 - M0008 - Seminar - (9.95 SQM) | ○ Office (2) | |
| B004 - R0001 - Main Area - (260.41 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0003 - Movement - (55.93 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0004 - Entry - (15.8 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0006 - Workroom - (42.55 SQM) | ○ Office (10) | |
| B004 - R0007 - Audio Visual Workroom - (45.75 SQM) | ● Student Space (21) | |
| B004 - R0010 - Movement - (55.12 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0012 - Workroom - (15.55 SQM) | ○ Office (3) | |
| B004 - R0013 - Movement - (40.45 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0009 - Movement - (10.95 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0013 - Student Canteen - (61.29 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0014 - Multi-Purpose Space - (478.33 SQM) | ● Student Space (53) | |
| B005 - R0015 - Movement - (10.59 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0017 - Stage - (85.98 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0018 - Movement - (190.98 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0003 - General Learning Space - (51.57 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B006 - R0004 - General Learning Space - (51.21 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B006 - R0005 - General Learning Space - (51.57 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B006 - R0012 - General Learning Space - (50.99 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B006 - R0014 - Movement - (137.99 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0015 - Staff Study - (30.9 SQM) | ○ Office (7) | |
| B006 - R0016 - Staff Study - (6.43 SQM) | ○ Office (1) | |
| B006 - R0017 - Movement - (7.38 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0019 - Commonroom - (71.55 SQM) | ○ Office (17) | |
| B007 - R0003 - Movement - (5.04 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R0004 - General Learning Space - (51.21 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B007 - R0005 - General Learning Space - (50.49 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B007 - R0006 - General Learning Space - (51.21 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B007 - R0009 - General Learning Space - (51.21 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B007 - R0016 - Movement - (148.07 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R0017 - Movement - (19.48 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R0018 - Commonroom - (70.96 SQM) | ○ Office (17) | |
| B007 - R0020 - Movement - (7.4 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R0021 - Staff Study - (28.58 SQM) | ○ Office (7) | |
| B008 - R0001 - General Learning Space - (50.63 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B008 - R0004 - General Learning Space - (51.2 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B008 - R0012 - General Learning Space - (50.84 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B008 - R0013 - General Learning Space - (50.13 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B008 - R0017 - Movement - (152.96 SQM) | Not Applicable | Circulation or storage space. |
| B008 - R0018 - Movement - (19.48 SQM) | Not Applicable | Circulation or storage space. |
| B008 - R0019 - Commonroom - (69.94 SQM) | ○ Office (17) | |
| B008 - R0020 - Staff Study - (28.29 SQM) | ○ Office (7) | |
| B008 - R0022 - Movement - (7.4 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0001 - General Learning Space - (51.21 SQM) - Teaching Space: 1 | ● Student Space (38) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B009 - R0007 - General Learning Space - (50.84 SQM) - Teaching Space: 1 | ● Student Space (28) | |
| B009 - R0009 - General Learning Space - (50.84 SQM) - Teaching Space: 1 | ● Student Space (38) | |
| B009 - R0010 - General Learning Space - (50.7 SQM) - Teaching Space: 1 | ● Student Space (41) | |
| B009 - R0019 - Commonroom - (71.37 SQM) | ● Office (17) | |
| B009 - R0020 - Movement - (7.34 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0022 - Staff Study - (36.01 SQM) | ● Office (9) | |
| B010 - R0001 - Duplicating Workroom - (24.4 SQM) | ● Office (6) | |
| B010 - R0003 - Deputy Principal Office - (24.88 SQM) | ● Office (6) | |
| B010 - R0005 - Leading Teacher - (11.72 SQM) | ● Office (2) | |
| B010 - R0006 - Interview/Office - Type 1 - (15.44 SQM) | ● Office (3) | |
| B010 - R0007 - Interview/Office - Type 1 - (11.92 SQM) | ● Office (2) | |
| B010 - R0010 - Administration - Clerical - (12.08 SQM) | ● Office (3) | |
| B010 - R0012 - Clinic - Boys - (12.09 SQM) | ● Office (3) | |
| B010 - R0015 - Clinic - Girls - (13.18 SQM) | ● Office (3) | |
| B010 - R0018 - Principal Office - (18.05 SQM) | ● Office (4) | |
| B010 - R0019 - Interview/Office - Type 1 - (11.23 SQM) | ● Office (2) | |
| B010 - R0020 - Administration - Clerical - (29.57 SQM) | ● Office (7) | |
| B010 - R0023 - Administration - Clerical - (13.93 SQM) | ● Office (3) | |
| B010 - R0025 - Movement - (18.15 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0029 - Administration - Clerical - (37.92 SQM) | ● Office (9) | |
| B010 - R0033 - Movement - (7.45 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0034 - Public Reception - (77.77 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0035 - Movement - (15.45 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0036 - Student Reception - (54.8 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R0037 - Movement - (10.34 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R1002 - Administration - Clerical - (13.31 SQM) | ● Office (3) | |
| B010 - R1004 - Ancillary Staff - (28.13 SQM) | ● Office (7) | |
| B010 - R1007 - Movement - (15.88 SQM) | Not Applicable | Circulation or storage space. |
| B010 - R1010 - Staff Lounge - (110.95 SQM) | ● Office (27) | |
| B010 - R1011 - Staff Kitchen - (14.67 SQM) | ● Office (3) | |
| B011 - R0003 - Movement - (25.85 SQM) | Not Applicable | Circulation or storage space. |
| OS 601 12633 - OS 601 12633 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 601 13725 - OS 601 13725 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 601 13761 - OS 601 13761 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 601 14137 - OS 601 14137 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 601 15140 - OS 601 15140 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 601 17712 - OS 601 17712 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 601 19731 - OS 601 19731 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (94) | |
| OS 621 17434 - OS 621 17434 - Learning Unit Single - PWD - (95 SQM) | ● Student Space (94) | |