

VENTILATION AUDIT REPORT Version 2



| SCHOOL: | Salt Ash Public School (3035) |
|------------------------|-------------------------------|
| AMU REGION: | Hunter/Central Coast |
| STATE ELECTORATE: | Port Stephens |
| LOCAL GOVERNMENT AREA: | Port Stephens |





Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

| Category | Description | |
|----------|---|--|
| | Category A Operate this space in line with <u>COVID safe school operations</u> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. | |
| • | Category B This space should be occupied at 1 person per 4m ² to comply with <u>COVID safe school operations and the guided use of spaces</u> . The report details the number of people who can be accommodated safely in each of the identified spaces. | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|--|-------------------------------|
| B00A - R0010 - Deputy Principal - (11.47 SQM) | Office (2) | |
| B00A - R0011 - Interview - (8.49 SQM) | Office (2) | |
| B00A - R0014 - Principal - (14.42 SQM) | Office (3) | |
| B00A - R0015 - Sick Bay - (9.01 SQM) | Student Space (4) | |
| B00A - R0016 - Clerical Office/Workroom - (24.24 SQM) | Office (6) | |
| B00A - R0017 - Movement - (30.06 SQM) | Not Applicable | Circulation or storage space. |
| B00D - R0002 - Home Base - (59.29 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00D - R0003 - Practical Activities - 1hb - (17.91 SQM) | Student Space (8) | |
| B00D - R0005 - Practical Activities - 1hb - (17.9 SQM) | Student Space (8) | |
| B00D - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1 | Student Space (32) | |
| B00D - R0009 - Withdrawal Space - 1hb - (11.81 SQM) | Student Space (5) | |
| B00F - R0002 - Canteen - (20.16 SQM) | Not Applicable | Circulation or storage space. |
| B00G - R0006 - Staff Room - (36.87 SQM) | Office (9) | |
| B00G - R0007 - Staff Room Annexe - (13.35 SQM) | Office (3) | |
| B00H - R0005 - Practical Activities - 1hb - (19.09 SQM) | Student Space (8) | |
| B00H - R0006 - Home Base - (60.93 SQM) - Teaching Space: 1 | Student Space (34) | |
| B00H - R0007 - Withdrawal Space - 2hb - (11.66 SQM) | Student Space (5) | |
| B00H - R0008 - Home Base - (61.42 SQM) - Teaching Space: 1 | Student Space (34) | |
| B00H - R0009 - Practical Activities - 1hb - (19.18 SQM) | Student Space (8) | |
| B00I - R0002 - Practical Activities - 1hb - (19.84 SQM) | Student Space (9) | |
| B00I - R0004 - Home Base - (58.11 SQM) - Teaching Space: 1 | Student Space (31) | |
| B00I - R0005 - Withdrawal Space - 2hb - (10.67 SQM) | Student Space (4) | |
| B00I - R0006 - Home Base - (58.11 SQM) - Teaching Space: 1 | Student Space (31) | |
| B00I - R0008 - Practical Activities - 1hb - (19.84 SQM) | Student Space (9) | |
| B00K - R0001 - Communal Space - (114.9 SQM) | Student Space (53) | |
| B00L - R0002 - Reading Area - (53.93 SQM) | Student Space (25) | |
| B00L - R0004 - Special Programs Room - (68.16 SQM) | Student Space (31) | |