

VENTILATION AUDIT REPORT Version 2



SCHOOL:	Sydney Distance Education Primary School (4586)
AMU REGION:	Sydney
STATE ELECTORATE:	Newtown
LOCAL GOVERNMENT AREA:	Sydney





Site plan is indicative only and is included to show building numbers used by the Department.

Ventilation Audit Key

Category	Description	
	Category A Operate this space in line with <u>COVID safe school operations</u> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.	
•	Category B This space should be occupied at 1 person per 4m ² to comply with <u>COVID safe school operations and the guided use of spaces</u> . The report details the number of people who can be accommodated safely in each of the identified spaces.	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (5.73 SQM)	Office (1)	
B00A - R0002 - Entry Vestibule - (11.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (11.37 SQM)	Office (2)	
B00A - R0005 - Movement - (11.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Duplicating Workroom - (12.59 SQM)	Office (3)	
B00A - R0007 - Principal - (10.93 SQM)	Office (2)	
B00A - R0013 - Staff Kitchen - (14.62 SQM)	Office (3)	
B00B - R0002 - Movement - (37.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Special Programs Room - (26.81 SQM)	Student Space (12)	
B00B - R0004 - Practical Activities - (11.67 SQM)	Student Space (5)	
B00B - R1002 - Movement - (24.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Home Base - (51.23 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1004 - Practical Activities - (7.37 SQM)	Student Space (3)	
B00B - R1007 - Special Programs Room - (13.1 SQM)	Student Space (6)	
B00E - R0001 - Interview - (12.37 SQM)	Office (3)	
B00E - R0004 - Special Programs Room - (29.99 SQM)	Student Space (13)	