
## **VENTILATION AUDIT REPORT Version 2**



SCHOOL:	Wiangaree Public School (3439)	
AMU REGION:	North Coast	
STATE ELECTORATE:	Lismore	
LOCAL GOVERNMENT AREA:	Kyogle	



Site plan is indicative only and is included to show building numbers used by the Department.

## Ventilation Audit Key

Category	Description	
	Category A Operate this space in line with <u>COVID safe school operations</u> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.	
•	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <u>COVID safe school operations and the guided use of spaces</u> . The report details the number of people who can be accommodated safely in each of the identified spaces.	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal Office - (18.5 SQM)	Office (4)	
B00A - R0002 - Clerical Office - (12.95 SQM)	Office (3)	
B00A - R0005 - Home Base - (44.15 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0006 - Home Base - (44.35 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0007 - Practical Activities - 1hb - (24.98 SQM)	Student Space (11)	
B00A - R0008 - Staff Room - (26.47 SQM)	Office (6)	
B00A - R9001 - Special Programs Room - (23.96 SQM)	Student Space (11)	
B00A - R9004 - Movement - (5.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R9005 - Movement - (13.93 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Reading Area - (59.86 SQM)	Student Space (27)	