VENTILATION AUDIT REPORT Version 2



SCHOOL:	Yennora Public School (3986)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Fairfield
LOCAL GOVERNMENT AREA:	Fairfield

The Department of Education's ventilation and asset use recommendations are complete.

For your school, the capacity for spaces has been reviewed based on the available openable windows and doors, their orientation and the presence of mechanical ventilation methods.

Improving air quality by maximising fresh air in each classroom is one of a range of measures employed by the department to reduce the risk of COVID-19 transmission. To view the comprehensive range of measures in place, visit the 'Advice for school based staff' page on the intranet. You should use this ventilation report alongside your school COVID safety plan.

Should you have any questions about your report, please contact your local Asset Services Officer to discuss these further.

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <u>COVID safe school operations</u> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
0	Category B This space should be occupied at 1 person per 4m ² to comply with <u>COVID safe school operations and the guided use of spaces</u> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Special Programs Room - (53.59 SQM)	Student Space (91)	
B00A - R0002 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (81)	
B00A - R0006 - Home Base - (53.3 SQM) - Teaching Space: 1	Student Space (81)	
B00A - R0010 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (81)	
B00A - R0012 - Movement - (49.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (13.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (64.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (65)	
B00A - R0019 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (65)	
B00A - R0024 - Sick Bay - (6.64 SQM)	Student Space (3)	
B00A - R0026 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (65)	
B00A - R0027 - Home Base - (53.59 SQM) - Teaching Space: 1	Student Space (65)	
B00B - R0011 - Home Base - (79.19 SQM) - Teaching Space: 1	Student Space (116)	
B00B - R0014 - Interview - (15.76 SQM)	Office (3)	
B00B - R0016 - Movement - (12.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (14.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Practical Activities - 1hb - (9.27 SQM)	Student Space (4)	
B00C - R0007 - Home Base - (79.4 SQM) - Teaching Space: 1	Student Space (70)	
B00D - R0001 - Canteen - (20.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Reading Area - (91.45 SQM)	Student Space (79)	
NS 120 12030 - NS 120 12030 - Learning Unit Primary Single - PWD - (76 SQM)	Student Space (59)	
OS 503 70078 - OS 503 70078 - Admin Lib Staff/Principal/Clerk/Store - (152 SQM)	Office (38)	
OS 510 13210 - OS 510 13210 - Staff Common Room - (114 SQM)	Office (28)	
OS 601 12027 - OS 601 12027 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (70)	
OS 601 12029 - OS 601 12029 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (80)	
OS 601 13427 - OS 601 13427 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (81)	
OS 601 19720 - OS 601 19720 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (61)	
OS 601 19721 - OS 601 19721 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (61)	
OS 601 19722 - OS 601 19722 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (61)	
OS 602 19694 - OS 602 19694 - Learning Unit - Standard With P.A.A (76 SQM)	Student Space (61)	
OS 614 12026 - OS 614 12026 - Learning Unit - Double Kindergarten - (190 SQM)	Student Space (61)	