

VENTILATION AUDIT REPORT

SCHOOL:	Adamstown Public School (1008)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Newcastle
LOCAL GOVERNMENT AREA:	Newcastle

1008 - Adamstown Public School
Site Plan (13018)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Duplicating Workroom - (14.84 SQM)	Office (3)	
B00A - R0002 - Movement - (36.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office - (14.05 SQM)	Office (3)	
B00A - R0005 - Principal - (19.3 SQM)	Office (4)	
B00A - R0007 - Entry Vestibule - (9.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (52.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Staff Room Annexe - (11.51 SQM)	Office (2)	
B00A - R0012 - Sick Bay - (10.14 SQM)	Student Space (4)	
B00A - R0013 - Deputy Principal - (11.62 SQM)	Office (2)	
B00A - R0015 - Staff Room - (19.47 SQM)	Office (4)	
B00A - R0019 - Staff Room - (72.86 SQM)	Office (18)	
B00B - R0002 - Movement - (157.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Reading Area - (88.93 SQM)	Student Space (41)	
B00B - R0011 - Reading Area - (58.45 SQM)	Student Space (27)	
B00B - R0017 - Canteen - (26.81 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Home Base - (57.85 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0024 - Practical Activities - 1hb - (13.7 SQM)	Student Space (6)	
B00B - R0026 - Home Base - (59.4 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0027 - Home Base - (59.41 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R0029 - Practical Activities - 1hb - (7.52 SQM)	Student Space (3)	
B00B - R0030 - Movement - (6.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0032 - Movement - (93.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Movement - (44.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Home Base - (57.77 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1003 - Movement - (7.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (61.72 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1006 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Movement - (141.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Home Base - (57.79 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1012 - Movement - (6.49 SQM)	Not Applicable	Circulation or storage space.
B00B - R1013 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1015 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - Home Base - (59.01 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1018 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Home Base - (57.64 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1021 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R1022 - Home Base - (61.41 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1024 - Movement - (6.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R1027 - Home Base - (57.63 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1029 - Movement - (6.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R1030 - Home Base - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1032 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R1033 - Home Base - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1035 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Movement - (22.78 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Communal Space - (175.24 SQM)	Student Space (81)	
B00C - R0014 - Staff Kitchen - (7.95 SQM)	Office (1)	
B00C - R0018 - Raised Platform - (49.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (19.32 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0004 - Home Base - (60.59 SQM) - Teaching Space: 1	● Student Space (28)	
B00D - R0005 - Withdrawal Space - 2hb - (11.64 SQM)	● Student Space (5)	
B00D - R0006 - Practical Activities - 1hb - (19.32 SQM)	● Student Space (8)	
B00D - R0007 - Home Base - (60.59 SQM) - Teaching Space: 1	● Student Space (28)	
OS 602 16296 - OS 602 16296 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	