

VENTILATION AUDIT REPORT

| | |
|-------------------------------|---------------------------------|
| SCHOOL: | Airds High School (8493) |
| AMU REGION: | South Western Sydney |
| STATE ELECTORATE: | Campbelltown |
| LOCAL GOVERNMENT AREA: | Campbelltown |

8493 - Airds High School
Site Plan (10177)




















Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B001 - R0002 - Welding Area - (10.3 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0015 - Metal Technology L.S. - (71.66 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B001 - R0016 - Metal Technology L.S. - (71.23 SQM) - Teaching Space: 1 | ● Student Space (33) | |
| B001 - R0017 - Metal Technology Bay - (43.38 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0021 - Metal Technology Bay - (84.63 SQM) | Not Applicable | Circulation or storage space. |
| B001 - R0022 - Art Learning Space - (85.91 SQM) - Teaching Space: 1 | ● Student Space (39) | |
| B001 - R1001 - Wood Technology L.S. - (83.2 SQM) - Teaching Space: 1 | ● Student Space (38) | |
| B001 - R1004 - Design L.S. - (52.35 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B001 - R1005 - Staff Study - (25.74 SQM) | ○ Office (6) | |
| B001 - R1006 - Design L.S. - (52.65 SQM) - Teaching Space: 1 | ● Student Space (24) | |
| B001 - R1009 - Wood Technology L.S. - (82.92 SQM) - Teaching Space: 1 | ● Student Space (38) | |
| B001 - R1013 - Movement - (52.13 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0031 - Movement - (53.1 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0032 - Movement - (85.05 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R0036 - Materials Technology L.S. - (147.66 SQM) - Teaching Space: 1 | ● Student Space (68) | |
| B002 - R0041 - Multi-Purpose Space - (148.27 SQM) | ● Student Space (68) | |
| B002 - R0043 - Student Canteen - (54.68 SQM) | Not Applicable | Circulation or storage space. |
| B002 - R1009 - Movement - (66.01 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0002 - Food Technology L.S. - (82.38 SQM) - Teaching Space: 1 | ● Student Space (38) | |
| B003 - R0008 - Textiles Technology L.S. - (65.74 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B003 - R0011 - Staff Study - (32.16 SQM) | ○ Office (8) | |
| B003 - R0016 - Movement - (73.66 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0017 - Food/Research Space - (43.41 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R0018 - Food Technology L.S. - (81.74 SQM) - Teaching Space: 1 | ● Student Space (37) | |
| B003 - R0019 - Preparation - Materials - (21.96 SQM) | Not Applicable | Circulation or storage space. |
| B003 - R1001 - Textiles Technology L.S. - (65.31 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B003 - R1002 - Music Learning Space - (131.01 SQM) - Teaching Space: 1 | ● Student Space (60) | |
| B003 - R1003 - Staff Study - (32.66 SQM) | ○ Office (8) | |
| B003 - R1004 - Music Learning Space - (65.58 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B003 - R1005 - Dark Room - (13.43 SQM) | ○ Office (3) | |
| B003 - R1006 - Art Learning Space - (65.76 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B003 - R1007 - Art Learning Space - (65.76 SQM) - Teaching Space: 1 | ● Student Space (30) | |
| B003 - R1009 - Movement - (77.17 SQM) | Not Applicable | Circulation or storage space. |
| B004 - M1001 - Multi Media Workshop - (64.03 SQM) | Not Applicable | Circulation or storage space. |
| B004 - M1002 - Study Space - (85.4 SQM) | Not Applicable | Circulation or storage space. |
| B004 - M1003 - Staff Study - (21.32 SQM) | ○ Office (5) | |
| B004 - R0001 - Laboratory L.S. - (89.31 SQM) - Teaching Space: 1 | ● Student Space (41) | |
| B004 - R0002 - Staff Study - (91.2 SQM) | ○ Office (22) | |
| B004 - R0003 - Preparation - Science - (49.42 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0006 - Laboratory L.S. - (89.41 SQM) - Teaching Space: 1 | ● Student Space (41) | |
| B004 - R0007 - Preparation - Science - (49.28 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0008 - Movement - (58.22 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R0019 - Laboratory L.S. - (90.85 SQM) - Teaching Space: 1 | ● Student Space (42) | |
| B004 - R1002 - Tea Room - (14.32 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R1013 - Staff Study - (27.67 SQM) | ○ Office (6) | |
| B004 - R1015 - Main Entry - (29.21 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R1016 - Main Area - (344.84 SQM) | Not Applicable | Circulation or storage space. |
| B004 - R1018 - Interview/Office - Type 1 - (13.09 SQM) | ○ Office (3) | |
| B005 - R0012 - Principal Office - (22.97 SQM) | ○ Office (5) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B005 - R0015 - Deputy Principal Office - (20.14 SQM) | Office (5) | |
| B005 - R0016 - Deputy Principal Office - (16.07 SQM) | Office (4) | |
| B005 - R0025 - Commonroom - (80.08 SQM) | Office (20) | |
| B005 - R0026 - Tea Room - (11.6 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0033 - Deputy Principal Office - (18.18 SQM) | Office (4) | |
| B005 - R0034 - Principal Office - (16.87 SQM) | Office (4) | |
| B005 - R0035 - Deputy Principal Office - (18.39 SQM) | Office (4) | |
| B005 - R0037 - Movement - (19.69 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0039 - Movement - (61.71 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R0040 - Administration - Clerical - (64.8 SQM) | Office (16) | |
| B005 - R0041 - Movement - (18.39 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R1001 - General Learning Space - (53.74 SQM) - Teaching Space: 1 | Student Space (24) | |
| B005 - R1002 - Computer Learning Space - (53.52 SQM) - Teaching Space: 1 | Student Space (24) | |
| B005 - R1005 - General Learning Space - (59.71 SQM) - Teaching Space: 1 | Student Space (27) | |
| B005 - R1007 - General Learning Space - (59.93 SQM) - Teaching Space: 1 | Student Space (27) | |
| B005 - R1008 - General Learning Space - (53.96 SQM) - Teaching Space: 1 | Student Space (25) | |
| B005 - R1009 - General Learning Space - (40.58 SQM) - Teaching Space: 1 | Student Space (18) | |
| B005 - R1010 - Staff Study - (41.01 SQM) | Office (10) | |
| B005 - R1012 - Tea Room - (17.93 SQM) | Not Applicable | Circulation or storage space. |
| B005 - R1013 - General Learning Space - (40.75 SQM) - Teaching Space: 1 | Student Space (18) | |
| B005 - R1014 - Movement - (53.63 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0001 - General Assistants - (22.48 SQM) | Office (5) | |
| B006 - R0003 - Laboratory L.S. - (90.52 SQM) - Teaching Space: 1 | Student Space (41) | |
| B006 - R0004 - Preparation - Science - (49.34 SQM) | Not Applicable | Circulation or storage space. |
| B006 - R0005 - Seminar/Technology Space - (90.71 SQM) | Office (22) | |
| B006 - R1004 - General Learning Space - (90.71 SQM) - Teaching Space: 1 | Student Space (42) | |
| B006 - R1006 - Seminar/Technology Space - (90.71 SQM) | Office (22) | |
| B006 - R1013 - Craft Room - (29.71 SQM) | Office (7) | |
| B007 - R0001 - General Learning Space - (53.09 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R0002 - General Learning Space - (52.42 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R0003 - Staff Study - (26.28 SQM) | Office (6) | |
| B007 - R0004 - Performance Workspace - (53.89 SQM) - Teaching Space: 1 | Student Space (25) | |
| B007 - R0006 - Interview/Office - Type 1 - (10.98 SQM) | Office (2) | |
| B007 - R0012 - General Learning Space - (53.23 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R0013 - General Learning Space - (53.74 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R0015 - General Learning Space - (52.21 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R0016 - Movement - (40.3 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R0017 - Movement - (29.66 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R1001 - Computer Learning Space - (53.09 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R1002 - General Learning Space - (53.88 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R1003 - General Learning Space - (54.55 SQM) - Teaching Space: 1 | Student Space (25) | |
| B007 - R1004 - General Learning Space - (54.55 SQM) - Teaching Space: 1 | Student Space (25) | |
| B007 - R1009 - General Learning Space - (53.3 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R1011 - General Learning Space - (53.6 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R1012 - General Learning Space - (53.82 SQM) - Teaching Space: 1 | Student Space (24) | |
| B007 - R1014 - Movement - (18.33 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R1015 - Movement - (26.4 SQM) | Not Applicable | Circulation or storage space. |
| B007 - R1016 - Staff Study - (52.15 SQM) | Office (13) | |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|--|---|-------------------------------|
| B008 - R0002 - General Learning Space - (53.01 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R0003 - Staff Study - (24.83 SQM) |  Office (6) | |
| B008 - R0004 - General Learning Space - (53.67 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R0006 - General Learning Space - (53.74 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R0007 - General Learning Space - (53.09 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R0013 - Tea Room - (10.88 SQM) | Not Applicable | Circulation or storage space. |
| B008 - R0016 - Special Learning Space - (27.34 SQM) - Teaching Space: 1 |  Student Space (12) | |
| B008 - R0019 - Movement - (78.72 SQM) | Not Applicable | Circulation or storage space. |
| B008 - R1001 - General Learning Space - (53.88 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R1002 - Computer Learning Space - (53.08 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R1003 - Staff Study - (18.39 SQM) |  Office (4) | |
| B008 - R1004 - General Learning Space - (53.75 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R1005 - General Learning Space - (53.74 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R1007 - General Learning Space - (53.38 SQM) - Teaching Space: 1 |  Student Space (24) | |
| B008 - R1012 - General Learning Space - (54.63 SQM) - Teaching Space: 1 |  Student Space (25) | |
| B008 - R1013 - General Learning Space - (54.7 SQM) - Teaching Space: 1 |  Student Space (25) | |
| B008 - R1014 - Movement - (18.3 SQM) | Not Applicable | Circulation or storage space. |
| B008 - R1015 - Movement - (27.58 SQM) | Not Applicable | Circulation or storage space. |
| B008 - R1017 - Staff Study - (50.91 SQM) |  Office (12) | |
| B009 - R0006 - Movement - (7.19 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0009 - Stage - (59.57 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0010 - Movement - (25.23 SQM) | Not Applicable | Circulation or storage space. |
| B009 - R0013 - Staff Kitchen - (13.62 SQM) |  Office (3) | |
| B009 - R0017 - Multi-Purpose Space - (486.89 SQM) |  Student Space (225) | |