


VENTILATION AUDIT REPORT

































SCHOOL:	Ajuga School (5748)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown




5748 - Ajuga School
Site Plan (10435)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0003 - Withdrawal Space - 1hb - (6.55 SQM)	 Student Space (3)	
B00C - R0007 - General Learning Space - (49.45 SQM) - Teaching Space: 1	 Student Space (22)	
B00C - R0008 - General Learning Space - (39.57 SQM) - Teaching Space: 1	 Student Space (18)	
B00C - R0010 - Special Programs Room - (78.44 SQM)	 Student Space (36)	
B00C - R0012 - Clerical Office - (10.34 SQM)	 Office (2)	
B00C - R0013 - Clerical Office - (10.36 SQM)	 Office (2)	
B00C - R0021 - Principal - (29.9 SQM)	 Office (7)	
B00C - R0022 - General Learning Space X2 - (58.75 SQM) - Teaching Space: 2	 Student Space (27)	
B00C - R0024 - Withdrawal Space - 1hb - (6.49 SQM)	 Student Space (3)	
B00C - R0029 - Clerical Office - (6.84 SQM)	 Office (1)	
B00C - R0032 - Movement - (10.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Entry Vestibule - (20.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R0037 - Staff Room - (34.19 SQM)	 Office (8)	
B00C - R0039 - Clerical Office/Workroom - (17.93 SQM)	 Office (4)	
B00D - R0007 - General Learning Space - (47.14 SQM) - Teaching Space: 1	 Student Space (21)	
B00D - R0008 - General Learning Space - (40.19 SQM) - Teaching Space: 1	 Student Space (18)	
B00D - R0010 - Special Programs Room - (78.43 SQM)	 Student Space (36)	
B00D - R0011 - Staff Room Annexe - (10.35 SQM)	 Office (2)	
B00D - R0012 - Staff Room Annexe - (10.36 SQM)	 Office (2)	
B00D - R0013 - Movement - (9.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0015 - Food/Research Space - (10.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Seminar/Study - (19.09 SQM)	 Office (4)	
B00D - R0027 - Home Base/Practical Activities - (49.36 SQM) - Teaching Space: 1	 Student Space (22)	
B00D - R0028 - Home Base/Practical Activities - (38 SQM) - Teaching Space: 1	 Student Space (17)	
B00G - R0001 - Home Base/Practical Activities - M - (54.54 SQM) - Teaching Space: 1	 Student Space (25)	
B00G - R0002 - Breakout Area - (9.84 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Breakout Area - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Practical Activities - 1hb - (22.82 SQM)	 Student Space (10)	
B00G - R0005 - Home Base/Practical Activities - M - (50.88 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0006 - Breakout Area - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Breakout Area - (8.96 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Practical Activities - 1hb - (22.72 SQM)	 Student Space (10)	
B00G - R0009 - Home Base - M - (51.08 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0010 - Breakout Area - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R0011 - Breakout Area - (9.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Practical Activities - 1hb - (22.87 SQM)	 Student Space (10)	
B00G - R0021 - Home Base/Practical Activities - M - (50.73 SQM) - Teaching Space: 1	 Student Space (23)	
B00G - R0022 - Breakout Area - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Breakout Area - (9.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0024 - Practical Activities - 1hb - (22.89 SQM)	 Student Space (10)	
B00G - R0025 - Home Base/Practical Activities - M - (54.22 SQM) - Teaching Space: 1	 Student Space (25)	
B00G - R0026 - Breakout Area - (9.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0027 - Breakout Area - (9.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0028 - Practical Activities - 1hb - (22.9 SQM)	 Student Space (10)	
B00G - R0032 - Home Base - (38.6 SQM) - Teaching Space: 1	 Student Space (17)	
B00G - R0034 - Home Base - (38.89 SQM) - Teaching Space: 1	 Student Space (18)	
B00G - R0036 - Outdoor Learning Area - (39.01 SQM)	Not Applicable	Circulation or storage space.
B00G - R0037 - Outdoor Learning Area - (49.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0038 - Outdoor Learning Area - (48.62 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0039 - Practical Activities - (6.32 SQM)	 Student Space (2)	
B00G - R0040 - Practical Activities - (6.35 SQM)	 Student Space (2)	
OS 601 18271 - OS 601 18271 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	