

VENTILATION AUDIT REPORT

SCHOOL:	Albion Park High School (8586)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Kiama
LOCAL GOVERNMENT AREA:	Shellharbour

8586 - Albion Park High School
Site Plan (10775)



1:1,643

Printed: 31-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Movement - (5.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Movement - (7.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Multi-Purpose Space - (478.03 SQM)	● Student Space (221)	
B00A - R0014 - General Assistants - (12.29 SQM)	● Office (3)	
B00A - R0018 - Gymnasium - (92.08 SQM)	● Student Space (42)	
B00B - R0003 - Ancillary Staff - (21.67 SQM)	● Office (5)	
B00B - R0005 - Interview/Office - Type 1 - (13.47 SQM)	● Office (3)	
B00B - R0009 - Clinic - Girls - (13.98 SQM)	● Office (3)	
B00B - R0010 - Deputy Principal Office - (16.5 SQM)	● Office (4)	
B00B - R0012 - Administration - Clerical - (43.23 SQM)	● Office (10)	
B00B - R0014 - Staff Study - (25.44 SQM)	● Office (6)	
B00B - R0016 - Principal Office - (19.22 SQM)	● Office (4)	
B00B - R0017 - Interview/Office - Type 1 - (12.86 SQM)	● Office (3)	
B00B - R0019 - Duplicating Workroom - (30.37 SQM)	● Office (7)	
B00B - R0020 - Teachers Aides - (13.99 SQM)	● Office (3)	
B00B - R0021 - Interview/Office - Type 1 - (13.62 SQM)	● Office (3)	
B00B - R0024 - Movement - (42.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Pupil Entry - (22.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Public Entry - (30.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0027 - Movement - (58.55 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Performance Workspace - (208.75 SQM) - Teaching Space: 1	● Student Space (96)	
B00C - R0011 - Music Learning Space - (79.01 SQM) - Teaching Space: 1	● Student Space (36)	
B00C - R0012 - Movement - (94.8 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Design L.S. - (76.65 SQM) - Teaching Space: 1	● Student Space (35)	
B00C - R0016 - Staff Study - (26.61 SQM)	● Office (6)	
B00C - R0017 - Movement - (8.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Design L.S. - (73.5 SQM) - Teaching Space: 1	● Student Space (34)	
B00C - R0020 - Food Technology L.S. - (105.35 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0021 - Food/Research Space - (21.43 SQM)	Not Applicable	Circulation or storage space.
B00C - R0022 - Seminar/Technology Space - (12.06 SQM)	● Office (3)	
B00C - R0023 - Food Technology L.S. - (105.23 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0024 - Movement - (69.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R0026 - Staff Study - (17.91 SQM)	● Office (4)	
B00C - R0027 - Practice/Seminar - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0030 - Practice/Seminar - (26.18 SQM)	Not Applicable	Circulation or storage space.
B00C - R0031 - Music Learning Space - (62.2 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0032 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0033 - Staff Kitchen - (16.91 SQM)	● Office (4)	
B00D - R0001 - Movement - (11.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (322.65 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Staff Study - (13.24 SQM)	● Office (3)	
B00D - R0008 - Study Space - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Interview/Office - Type 1 - (39.03 SQM)	● Office (9)	
B00D - R0010 - Study Space - (15.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - General Learning Space - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0014 - General Learning Space - (52.73 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0015 - General Learning Space - (48.06 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0016 - General Learning Space - (48.23 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0018 - General Learning Space - (47.81 SQM) - Teaching Space: 1	● Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0019 - General Learning Space - (48.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0020 - General Learning Space - (47.15 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0022 - Computer Learning Space - (64.89 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0025 - Commonroom - (112.2 SQM)	● Office (28)	
B00D - R1001 - Movement - (281.46 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Staff Study - (14.99 SQM)	● Office (3)	
B00D - R1005 - Staff Study - (37.96 SQM)	● Office (9)	
B00D - R1006 - Staff Study - (39.24 SQM)	● Office (9)	
B00D - R1007 - Study Space - (15.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - General Learning Space - (48.87 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1011 - General Learning Space - (48.87 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1012 - General Learning Space - (48.09 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1013 - General Learning Space - (48.1 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1015 - General Learning Space - (48.26 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1016 - General Learning Space - (47.93 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1017 - General Learning Space - (47.39 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R1019 - General Learning Space - (48.45 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R1020 - General Learning Space - (54.98 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0001 - Movement - (310.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Interview/Office - Type 1 - (12.82 SQM)	● Office (3)	
B00E - R0007 - General Learning Space - (52.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0008 - General Learning Space - (52.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0009 - Computer Learning Space - (71.16 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R0011 - Study Space - (15.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Staff Study - (26.63 SQM)	● Office (6)	
B00E - R1004 - Interview/Office - Type 1 - (11.47 SQM)	● Office (2)	
B00E - R1005 - General Learning Space - (44.77 SQM) - Teaching Space: 1	● Student Space (20)	
B00E - R1006 - General Learning Space - (47.91 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R1007 - General Learning Space - (47.74 SQM) - Teaching Space: 1	● Student Space (22)	
B00E - R1008 - General Learning Space - (49.77 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1010 - Study Space - (15.23 SQM)	Not Applicable	Circulation or storage space.
B00E - R1011 - Staff Study - (26.62 SQM)	● Office (6)	
B00F - R0001 - Movement - (111.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Laboratory L.S. - (91.12 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0003 - Laboratory L.S. - (92.45 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0004 - Movement - (14.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Laboratory L.S. - (92.14 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0006 - Laboratory L.S. - (92.24 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0007 - Laboratory L.S. - (91.98 SQM) - Teaching Space: 1	● Student Space (42)	
B00F - R0008 - Movement - (19.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Preparation - (63.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0013 - Laboratory L.S. - (89.32 SQM) - Teaching Space: 1	● Student Space (41)	
B00F - R0016 - Movement - (42.13 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - General Learning Space - (57.25 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0003 - General Learning Space - (57.2 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0006 - Metal Technology Bay - (36.97 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - General Learning Space - (95.49 SQM) - Teaching Space: 1	● Student Space (44)	
B00G - R0009 - Staff Study - (42.11 SQM)	● Office (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0010 - General Learning Space - (94.3 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R0011 - Wood Technology Bay - (26.33 SQM)	Not Applicable	Circulation or storage space.
B00G - R0016 - Staff Study - (31.22 SQM)	● Office (7)	
B00G - R0017 - Movement - (93.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0019 - General Learning Space - (88.04 SQM) - Teaching Space: 1	● Student Space (40)	
B00G - R0020 - Materials Workshop - Type 2 - (268.45 SQM)	● Student Space (124)	
B00H - R0001 - Movement - (146.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Staff Study - (21.92 SQM)	● Office (5)	
B00H - R0004 - Art Learning Space - (62.33 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0006 - Study Space - (22.61 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Art Learning Space - (61.01 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0010 - Darkroom Space - (28.25 SQM)	● Office (7)	
B00H - R0011 - Art Learning Space - (61.28 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0013 - Art Learning Space - (63.29 SQM) - Teaching Space: 1	● Student Space (29)	
B00H - R0015 - Interview/Office - Type 1 - (12.1 SQM)	● Office (3)	
B00H - R0016 - Movement - (101.63 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Main Area - (447.3 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Audio Visual Workroom - (32.76 SQM)	● Student Space (15)	
B00I - R0003 - Workroom - (46.47 SQM)	● Office (11)	
B00I - R0005 - Movement - (12.25 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Seminar - (13.48 SQM)	● Office (3)	
B00I - R0009 - Seminar - (13.52 SQM)	● Office (3)	
B00I - R0010 - Seminar - (13.52 SQM)	● Office (3)	
B00I - R0011 - Seminar - (13.43 SQM)	● Office (3)	
B00I - R0012 - Seminar - (13.53 SQM)	● Office (3)	
B00K - R0001 - Student Canteen - (54.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Wood Technology Bay - (71.68 SQM)	Not Applicable	Circulation or storage space.
OS 601 10671 - OS 601 10671 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 10705 - OS 601 10705 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11076 - OS 601 11076 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12925 - OS 601 12925 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19454 - OS 601 19454 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19883 - OS 601 19883 - Learning Unit - Standard/Withdrawal - (SQM)	● Student Space ()	
OS 601 19884 - OS 601 19884 - Learning Unit - Standard/Withdrawal - (SQM)	● Student Space ()	