



# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Albury High School (8101)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Albury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Albury</b>

8101 - Albury High School  
Site Plan (12002)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - General Learning Space - (60.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0003 - Principal Office - (27.98 SQM)	○ Office (6)	
B00A - R0004 - Principal Office - (26.45 SQM)	○ Office (6)	
B00A - R0008 - Administration - Clerical - (26.15 SQM)	○ Office (6)	
B00A - R0009 - Movement - (39.64 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (257.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Deputy Principal Office - (10.33 SQM)	○ Office (2)	
B00A - R0012 - Deputy Principal Office - (16.14 SQM)	○ Office (4)	
B00A - R0014 - Leading Teacher - (8.61 SQM)	○ Office (2)	
B00A - R0015 - Duplicating Workroom - (33.15 SQM)	○ Office (8)	
B00A - R0016 - General Learning Space - (55.16 SQM) - Teaching Space: 1	● Student Space (25)	
B00A - R0017 - Senior Study - (60.09 SQM)	○ Office (15)	
B00A - R0021 - Staff Study - (10.68 SQM)	○ Office (2)	
B00A - R0022 - Pupil Entry - (10.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Commonroom - (79.01 SQM)	○ Office (19)	
B00A - R0025 - Clinic - Girls - (14.78 SQM)	○ Office (3)	
B00A - R0026 - Clinic - Boys - (14.87 SQM)	○ Office (3)	
B00A - R0028 - Interview/Office - Type 1 - (10.77 SQM)	○ Office (2)	
B00A - R0029 - Staff Study - (12.62 SQM)	○ Office (3)	
B00A - R0034 - Staff Study - (10.69 SQM)	○ Office (2)	
B00A - R0041 - Administration - Clerical - (47.73 SQM)	○ Office (11)	
B00A - R1001 - General Learning Space - (61.37 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1003 - General Learning Space - (56.57 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1006 - Staff Study - (81.22 SQM)	○ Office (20)	
B00A - R1007 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1008 - General Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1009 - General Learning Space - (61.21 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R1010 - Movement - (157.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Staff Study - (11.19 SQM)	○ Office (2)	
B00A - R1015 - Movement - (250.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Interview/Office - Type 1 - (11.58 SQM)	○ Office (2)	
B00A - R1017 - Staff Study - (11.53 SQM)	○ Office (2)	
B00A - R1019 - Movement - (32.48 SQM)	Not Applicable	Circulation or storage space.
B00B - M2003 - Main Area - (68.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Movement - (30.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Computer Learning Space - (56.12 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0006 - Computer Learning Space - (61.83 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0008 - Computer Learning Space - (57.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0014 - General Learning Space - (61.9 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0016 - General Learning Space - (61.82 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0018 - General Learning Space - (57.52 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0020 - Movement - (55.27 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (29.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R1002 - Movement - (25.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Laboratory L.S. - (83.81 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R1007 - Laboratory L.S. - (82.47 SQM) - Teaching Space: 1	● Student Space (38)	
B00B - R1008 - Movement - (59 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1011 - Laboratory L.S. - (91.14 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R1014 - Preparation - (31.54 SQM)	Not Applicable	Circulation or storage space.
B00B - R1017 - Movement - (20.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Preparation - Science - (44.38 SQM)	Not Applicable	Circulation or storage space.
B00B - R2002 - Workroom - (17.72 SQM)	● Office (4)	
B00B - R2004 - Movement - (26.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R2006 - General Learning Space - (72.08 SQM) - Teaching Space: 1	● Student Space (33)	
B00B - R2007 - Main Area - (325.64 SQM)	Not Applicable	Circulation or storage space.
B00B - R2008 - Study Space - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R2009 - Study Space - (11.61 SQM)	Not Applicable	Circulation or storage space.
B00B - R2016 - Study Space - (11.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R2017 - Study Space - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00B - R2018 - Audio Visual Workroom - (28.58 SQM)	● Student Space (13)	
B00B - R2024 - Movement - (30.77 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Materials Technology L.S. - (82.76 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R0006 - Staff Study - (19.27 SQM)	● Office (4)	
B00C - R0007 - Art Learning Space - (63.86 SQM) - Teaching Space: 1	● Student Space (29)	
B00C - R0011 - Movement - (22.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0017 - Movement - (53.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Materials Technology L.S. - (82.57 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R1001 - Materials Technology L.S. - (82.66 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R1003 - Movement - (52 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Darkroom Space - (21.26 SQM)	● Office (5)	
B00C - R1007 - Design L.S. - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R1009 - Design L.S. - (55.03 SQM) - Teaching Space: 1	● Student Space (25)	
B00C - R1010 - Movement - (19.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R1011 - Materials Technology L.S. - (82.58 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R2001 - Staff Study - (33.55 SQM)	● Office (8)	
B00C - R2006 - Leading Teacher - (16.8 SQM)	● Office (4)	
B00C - R2007 - Study Space - (13.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R2008 - Study Space - (12.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R2009 - General Learning Space - (69.51 SQM) - Teaching Space: 1	● Student Space (32)	
B00C - R2010 - Staff Study - (13.98 SQM)	● Office (3)	
B00C - R2012 - Movement - (21.4 SQM)	Not Applicable	Circulation or storage space.
B00C - R2013 - Movement - (58.21 SQM)	Not Applicable	Circulation or storage space.
B00C - R2015 - Art Learning Space - (68.33 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R2016 - Art Learning Space - (68.87 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0001 - Laboratory L.S. - (87 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0002 - Preparation - (48.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Laboratory L.S. - (86.97 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R0004 - Movement - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (58.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (16.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Preparation - (38.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Laboratory L.S. - (85.85 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0013 - Movement - (10.18 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - General Learning Space - (55.18 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1004 - General Learning Space - (53.84 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1007 - General Learning Space - (55.32 SQM) - Teaching Space: 1	● Student Space (25)	
B00D - R1008 - Leading Teacher - (9.64 SQM)	● Office (2)	
B00D - R1009 - Movement - (9.03 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1010 - Movement - (57.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Staff Study - (25.85 SQM)	Office (6)	
B00D - R1012 - Staff Study - (26.05 SQM)	Office (6)	
B00D - R1016 - Movement - (8.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R1019 - General Learning Space - (64.21 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R1020 - General Learning Space - (56.69 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1021 - Staff Study - (9.38 SQM)	Office (2)	
B00D - R1022 - Movement - (9.02 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (47.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Student Canteen - (55.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Movement - (29.57 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (10.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0012 - Staff Study - (7.2 SQM)	Office (1)	
B00E - R0015 - Multi-Purpose Space - (473.96 SQM)	Student Space (219)	
B00E - R0018 - Staff Study - (7.78 SQM)	Office (1)	
B00E - R0019 - Movement - (10.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Movement - (9.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R0031 - Stage - (146.82 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (59.34 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Staff Study - (15.08 SQM)	Office (3)	
B00E - R1004 - Music Learning Space - (102.38 SQM) - Teaching Space: 1	Student Space (47)	
B00E - R1005 - Music Learning Space - (69.22 SQM) - Teaching Space: 1	Student Space (32)	
B00F - R0001 - Food Technology L.S. - (93.22 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0002 - Movement - (256.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Staff Study - (7.02 SQM)	Office (1)	
B00F - R0008 - Staff Study - (14.14 SQM)	Office (3)	
B00F - R0009 - General Learning Space - (50.3 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0010 - General Learning Space - (50.8 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0011 - Staff Study - (36.55 SQM)	Office (9)	
B00F - R0012 - General Learning Space - (49.75 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0014 - General Learning Space - (49.37 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0015 - General Learning Space - (51.01 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R0016 - Materials Technology L.S. - (68.53 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R0019 - Materials Technology L.S. - (64.92 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R0025 - Food Technology L.S. - (93.2 SQM) - Teaching Space: 1	Student Space (43)	
B00F - R0032 - Preparation - (31.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0033 - Staff Kitchen - (16.23 SQM)	Office (4)	
B00F - R1001 - Movement - (270.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Staff Study - (17.45 SQM)	Office (4)	
B00F - R1004 - Staff Study - (32.81 SQM)	Office (8)	
B00F - R1008 - Staff Study - (14.07 SQM)	Office (3)	
B00F - R1009 - General Learning Space - (50.15 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1010 - General Learning Space - (51.88 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1011 - General Learning Space - (49.68 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1013 - General Learning Space - (49.6 SQM) - Teaching Space: 1	Student Space (23)	
B00F - R1014 - General Learning Space - (52.02 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R1017 - General Learning Space - (56.7 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R1018 - General Learning Space - (48.9 SQM) - Teaching Space: 1	Student Space (22)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1020 - Staff Study - (7.82 SQM)	Office (1)	
B00G - R0005 - General Assistants - (25.78 SQM)	Office (6)	
B00G - R0011 - Movement - (19.82 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Gymnasium - (269.01 SQM)	Student Space (124)	
B00L - R0001 - Movement - (109.97 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Study Space - (23.53 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Movement - (31.33 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Study Space - (17.93 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Senior Study - (15.22 SQM)	Office (3)	
B00L - R0006 - Study Space - (24.89 SQM)	Not Applicable	Circulation or storage space.
B00L - R0008 - Staff Kitchen - (14.64 SQM)	Office (3)	
B00L - R0012 - Movement - (16.01 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Movement - (22.84 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Interview/Office - Type 1 - (8.19 SQM)	Office (2)	
B00L - R0016 - Staff Study - (17.97 SQM)	Office (4)	
B00L - R0017 - Staff Study - (16.62 SQM)	Office (4)	
B00M - R0001 - Movement - (47.93 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Movement - (18 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Staff Kitchen - (12.06 SQM)	Office (3)	
B00M - R0006 - Performance Workshop - (96.93 SQM)	Student Space (44)	
B00M - R0007 - Performance Workshop - (62.99 SQM)	Student Space (29)	
B00P - R0002 - Wood Technology Bay - (22.3 SQM)	Not Applicable	Circulation or storage space.
B00X - R0005 - Gymnasium - (50.8 SQM)	Student Space (23)	
B00X - R0006 - Design/Technology L.S. - (40.95 SQM) - Teaching Space: 1	Student Space (18)	
B00X - R0007 - Wood Technology Bay - (45.23 SQM)	Not Applicable	Circulation or storage space.
OS 602 10797 - OS 602 10797 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	