


VENTILATION AUDIT REPORT

SCHOOL:	Aldavilla Public School (4601)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Kempsey

4601 - Aldavilla Public School
Site Plan (10454)



1:1,197

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0002 - Deputy Principal - (12.5 SQM)	Office (3)	
B001 - R0003 - Deputy Principal - (12.36 SQM)	Office (3)	
B001 - R0004 - Principal - (16.64 SQM)	Office (4)	
B001 - R0005 - Duplicating Workroom - (20.12 SQM)	Office (5)	
B001 - R0006 - Interview - (12.35 SQM)	Office (3)	
B001 - R0009 - Movement - (23.18 SQM)	Not Applicable	Circulation or storage space.
B001 - R0011 - Sick Bay - (8.86 SQM)	Student Space (4)	
B001 - R0017 - Staff Room Annexe - (19.86 SQM)	Office (4)	
B001 - R0020 - Staff Room - (38.33 SQM)	Office (9)	
B001 - R0021 - Staff Kitchen - (8.44 SQM)	Office (2)	
B001 - R0028 - Entry Vestibule - (11.44 SQM)	Not Applicable	Circulation or storage space.
B001 - R0029 - Clerical Office/Workroom - (22.08 SQM)	Office (5)	
B002 - R0001 - Canteen - (27.64 SQM)	Not Applicable	Circulation or storage space.
B003 - R0003 - Special Programs Room - (31.08 SQM)	Student Space (14)	
B003 - R0004 - Reading Area - (160.51 SQM)	Student Space (74)	
B004 - R0003 - Home Base - (63.52 SQM) - Teaching Space: 1	Student Space (29)	
B004 - R0004 - Practical Activities - 1hb - (18.78 SQM)	Student Space (8)	
B004 - R0006 - Practical Activities - 1hb - (19.66 SQM)	Student Space (9)	
B004 - R0007 - Home Base - (58.23 SQM) - Teaching Space: 1	Student Space (27)	
B004 - R0008 - Withdrawal Space - 2hb - (11.48 SQM)	Student Space (5)	
B004 - R0012 - Practical Activities - 1hb - (19.66 SQM)	Student Space (9)	
B004 - R0014 - Home Base - (58.23 SQM) - Teaching Space: 1	Student Space (27)	
B004 - R0015 - Practical Activities - 1hb - (19.66 SQM)	Student Space (9)	
B004 - R0016 - Home Base - (63.54 SQM) - Teaching Space: 1	Student Space (29)	
B005 - R0004 - Special Programs Room - (63.09 SQM)	Student Space (29)	
B005 - R0005 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B005 - R0006 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B005 - R0007 - Home Base - (57.33 SQM) - Teaching Space: 1	Student Space (26)	
B005 - R0009 - Withdrawal Space - 2hb - (11.11 SQM)	Student Space (5)	
B005 - R0010 - Home Base - (57.32 SQM) - Teaching Space: 1	Student Space (26)	
B005 - R0012 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B005 - R0014 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B005 - R0015 - Home Base - (57.33 SQM) - Teaching Space: 1	Student Space (26)	
B005 - R0017 - Withdrawal Space - 2hb - (11.15 SQM)	Student Space (5)	
B005 - R0020 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B005 - R0021 - Home Base - (57.32 SQM) - Teaching Space: 1	Student Space (26)	
B005 - R0023 - Practical Activities - 1hb - (19.86 SQM)	Student Space (9)	
B005 - R0024 - Home Base - (62.95 SQM) - Teaching Space: 1	Student Space (29)	
B006 - R0007 - Movement - (11.17 SQM)	Not Applicable	Circulation or storage space.
B006 - R0008 - Staff Kitchen - (10.09 SQM)	Office (2)	
B006 - R0009 - Communal Space - (181.04 SQM)	Student Space (83)	
B006 - R0011 - Raised Platform - (49.97 SQM)	Not Applicable	Circulation or storage space.
B007 - R0005 - Practical Activities/Movement - 1hb - (19.01 SQM)	Student Space (8)	
B007 - R0007 - Home Base - (60.69 SQM) - Teaching Space: 1	Student Space (28)	
B007 - R0008 - Withdrawal Space - 2hb - (11.4 SQM)	Student Space (5)	
B007 - R0009 - Home Base - (58.71 SQM) - Teaching Space: 1	Student Space (27)	
B007 - R0011 - Practical Activities/Movement - 1hb - (19.99 SQM)	Student Space (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R0016 - Special Programs Room - (34.58 SQM)	● Student Space (16)	
OS 602 13543 - OS 602 13543 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	