

VENTILATION AUDIT REPORT

SCHOOL:	Alfords Point Public School (4605)
AMU REGION:	Sydney
STATE ELECTORATE:	Miranda
LOCAL GOVERNMENT AREA:	Sutherland

4605 - Alfords Point Public School
Site Plan (10564)



1:914

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (28.13 SQM)	Office (7)	
B00A - R0002 - Entry Vestibule - (18.53 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Clerical Office/Workroom - (21.42 SQM)	Office (5)	
B00A - R0004 - Interview - (12.56 SQM)	Office (3)	
B00A - R0005 - Sick Bay - (8.3 SQM)	Student Space (3)	
B00A - R0007 - Principal - (16.89 SQM)	Office (4)	
B00A - R0009 - Principal - (12.26 SQM)	Office (3)	
B00A - R0010 - Principal - (14.29 SQM)	Office (3)	
B00A - R0015 - Movement - (43.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Staff Room - (47.8 SQM)	Office (11)	
B00A - R0017 - Staff Room - (19.25 SQM)	Office (4)	
B00A - R0018 - Movement - (68.16 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Special Programs Room - (37.66 SQM)	Student Space (17)	
B00B - R0004 - Reading Area - (170.62 SQM)	Student Space (79)	
B00B - R0006 - Movement - (60.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (23.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0002 - Home Base - (60.06 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0003 - Home Base - (60.15 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0005 - Home Base - (60.02 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0006 - Home Base - (60.28 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0009 - Practical Activities - 1hb - (19.41 SQM)	Student Space (9)	
B00C - R0010 - Withdrawal Space - 2hb - (11.69 SQM)	Student Space (5)	
B00C - R0011 - Practical Activities - 1hb - (19.45 SQM)	Student Space (9)	
B00C - R0014 - Practical Activities - 1hb - (19.19 SQM)	Student Space (8)	
B00C - R0015 - Withdrawal Space - 2hb - (11.81 SQM)	Student Space (5)	
B00C - R0016 - Practical Activities - 1hb - (18.74 SQM)	Student Space (8)	
B00C - R0019 - Practical Activities - 1hb - (19.02 SQM)	Student Space (8)	
B00C - R0020 - Withdrawal Space - 2hb - (11.87 SQM)	Student Space (5)	
B00C - R0021 - Practical Activities - 1hb - (19.49 SQM)	Student Space (9)	
B00C - R0023 - Movement - (122.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Practical Activities - 1hb - (19.35 SQM)	Student Space (8)	
B00D - R0003 - Movement - (120.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Withdrawal Space - 2hb - (11.84 SQM)	Student Space (5)	
B00D - R0005 - Practical Activities - 1hb - (19.05 SQM)	Student Space (8)	
B00D - R0007 - Home Base - (60.08 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0008 - Home Base - (59.23 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0009 - Home Base - (60.06 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0010 - Home Base - (59.34 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0011 - Practical Activities - 1hb - (19.53 SQM)	Student Space (9)	
B00D - R0013 - Withdrawal Space - 2hb - (11.69 SQM)	Student Space (5)	
B00D - R0014 - Practical Activities - 1hb - (19.49 SQM)	Student Space (9)	
B00D - R0023 - Movement - (28.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Communal Space - (147.33 SQM)	Student Space (68)	
B00E - R0002 - Raised Platform - (60 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Movement - (6.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.