

VENTILATION AUDIT REPORT

SCHOOL:	Ambarvale Public School (4505)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Campbelltown
LOCAL GOVERNMENT AREA:	Campbelltown

4505 - Ambarvale Public School
Site Plan (10182)











1:1,069

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0009 - Practical Activities - 1hb - (36.3 SQM)	● Student Space (16)	
B00A - R0011 - Home Base - (58.94 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0013 - Withdrawal Space - 1hb - (11.05 SQM)	● Student Space (5)	
B00A - R0015 - Home Base - (58.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0009 - Practical Activities - 1hb - (36.41 SQM)	● Student Space (16)	
B00B - R0011 - Home Base - (58.85 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0014 - Withdrawal Space - 1hb - (11.02 SQM)	● Student Space (5)	
B00B - R0016 - Home Base - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0009 - Practical Activities - 1hb - (45.62 SQM)	● Student Space (21)	
B00C - R0011 - Home Base - (58.86 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0014 - Withdrawal Space - 1hb - (8.12 SQM)	● Student Space (3)	
B00C - R0016 - Home Base - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0018 - Home Base - (58.93 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0020 - Withdrawal Space - 1hb - (8.15 SQM)	● Student Space (3)	
B00D - R0003 - Canteen - (44.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Movement - (38.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Raised Platform - (35.73 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Communal Space - (243.72 SQM)	● Student Space (113)	
B00E - R0001 - Home Base - (61.72 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0004 - Withdrawal Space - 1hb - (18.09 SQM)	● Student Space (8)	
B00E - R0005 - Home Base - (61.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00E - R0008 - Practical Activities - 1hb - (26.39 SQM)	● Student Space (12)	
B00F - R0004 - Home Base - (61.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0007 - Withdrawal Space - 1hb - (19.4 SQM)	● Student Space (9)	
B00F - R0008 - Home Base - (61.67 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0011 - Practical Activities - 1hb - (24.92 SQM)	● Student Space (11)	
B00G - R0003 - Home Base - (61.51 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0006 - Withdrawal Space - 1hb - (17.96 SQM)	● Student Space (8)	
B00G - R0007 - Home Base - (60.85 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0010 - Practical Activities - 1hb - (23.78 SQM)	● Student Space (11)	
B00G - R0013 - Staff Room Annexe - (11.54 SQM)	● Office (2)	
B00G - R0014 - Home Base - (60.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0018 - Home Base - (63.68 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0021 - Practical Activities - 1hb - (26.02 SQM)	● Student Space (12)	
B00H - R0004 - Home Base - (70.93 SQM) - Teaching Space: 1	● Student Space (32)	
B00H - R0008 - Withdrawal Space - 1hb - (17.9 SQM)	● Student Space (8)	
B00H - R0010 - Home Base - (75.84 SQM) - Teaching Space: 1	● Student Space (35)	
B00H - R0012 - Practical Activities - 1hb - (25.34 SQM)	● Student Space (11)	
B00H - R0015 - Home Base - (71.41 SQM) - Teaching Space: 1	● Student Space (33)	
B00H - R0019 - Withdrawal Space - 1hb - (17.52 SQM)	● Student Space (8)	
B00H - R0023 - Home Base - (73.33 SQM) - Teaching Space: 1	● Student Space (34)	
B00H - R0024 - Practical Activities - 1hb - (24.27 SQM)	● Student Space (11)	
B00I - R0001 - Staff Room - (93.03 SQM)	● Office (23)	
B00I - R0005 - Staff Room Annexe - (14.02 SQM)	● Office (3)	
B00I - R0006 - Staff Room Annexe - (13.17 SQM)	● Office (3)	
B00I - R0007 - Movement - (22.2 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Principal - (20.72 SQM)	● Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0010 - Clerical Office - (12.32 SQM)	 Office (3)	
B00I - R0011 - Duplicating Workroom - (14 SQM)	 Office (3)	
B00I - R0012 - Clerical Office - (11.16 SQM)	 Office (2)	
B00I - R0021 - Principal - (17.57 SQM)	 Office (4)	
B00I - R0022 - Entry Vestibule - (11.14 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Movement - (14.62 SQM)	Not Applicable	Circulation or storage space.
B00I - R1009 - Seminar/Study - (13.09 SQM)	 Office (3)	
B00I - R1010 - Seminar/Study - (13.75 SQM)	 Office (3)	
B00I - R1013 - Special Programs Room - (31.48 SQM)	 Student Space (14)	
B00I - R1016 - Reading Area - (221.63 SQM)	 Student Space (102)	