

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Anna Bay Public School (1040)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Port Stephens</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Port Stephens</b>

1040 - Anna Bay Public School  
Site Plan (10185)



1:1,501

Printed: 18-Aug-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (20.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (33.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Special Programs Room - (11.96 SQM)	● Student Space (5)	
B00A - R0010 - Special Programs Room - (13.39 SQM)	● Student Space (6)	
B00A - R0012 - Home Base - (74.3 SQM) - Teaching Space: 1	● Student Space (34)	
B00B - R0001 - Movement - (44.58 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - 1hb - (22.38 SQM)	● Student Space (10)	
B00B - R0004 - Home Base - (56.29 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0005 - Withdrawal Space - 1hb - (11.61 SQM)	● Student Space (5)	
B00B - R0006 - Home Base - (56.28 SQM) - Teaching Space: 1	● Student Space (26)	
B00B - R0008 - Practical Activities - 1hb - (22.38 SQM)	● Student Space (10)	
B00C - R0007 - Canteen - (45.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Withdrawal Space - 1hb - (52.39 SQM)	● Student Space (24)	
B00E - R0003 - Movement - (10.86 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Withdrawal Space - 2hb - (13.23 SQM)	● Student Space (6)	
B00F - R0002 - Interview - (12.62 SQM)	○ Office (3)	
B00F - R0004 - Movement - (58.98 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (53.55 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0006 - Home Base - (53.71 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0007 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Practical Activities - 1hb - (13.4 SQM)	● Student Space (6)	
B00F - R0010 - Home Base - (67.19 SQM) - Teaching Space: 1	● Student Space (31)	
B00J - R0002 - Movement - (18.76 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (22.38 SQM)	● Student Space (10)	
B00K - R0003 - Movement - (44.6 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Home Base - (56.3 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0005 - Withdrawal Space - 1hb - (11.4 SQM)	● Student Space (5)	
B00K - R0006 - Home Base - (56.3 SQM) - Teaching Space: 1	● Student Space (26)	
B00K - R0007 - Practical Activities - 1hb - (22.38 SQM)	● Student Space (10)	
B00L - R0001 - Movement - (82.92 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Home Base - (89.26 SQM) - Teaching Space: 1	● Student Space (41)	
B00M - R0001 - Home Base - (62.38 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0004 - Practical Activities - 1hb - (19.58 SQM)	● Student Space (9)	
B00M - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	● Student Space (4)	
B00M - R0006 - Home Base - (62.31 SQM) - Teaching Space: 1	● Student Space (28)	
B00M - R0008 - Practical Activities - 1hb - (19.64 SQM)	● Student Space (9)	
B00M - R0009 - Movement - (38.27 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Movement - (38.53 SQM)	Not Applicable	Circulation or storage space.
B00N - R0009 - Practical Activities - (18.7 SQM)	● Student Space (8)	
B00N - R0010 - Home Base - Bd/Cd/Ed - (55.1 SQM) - Teaching Space: 1	● Student Space (25)	
B00N - R0012 - Home Base - Bd/Cd/Ed - (55.96 SQM) - Teaching Space: 1	● Student Space (25)	
B00N - R0013 - Practical Activities - (19.02 SQM)	● Student Space (8)	
B00O - R0001 - Entry Vestibule - (24.52 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Clerical Office - (58.47 SQM)	○ Office (14)	
B00O - R0003 - Sick Bay - (9.64 SQM)	● Student Space (4)	
B00O - R0005 - Staff Room - (60.97 SQM)	○ Office (15)	
B00O - R0006 - Staff Room - (25.93 SQM)	○ Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00O - R0008 - Interview - (17.11 SQM)	Office (4)	
B00O - R0014 - Deputy Principal - (12.93 SQM)	Office (3)	
B00O - R0015 - Deputy Principal - (13.12 SQM)	Office (3)	
B00O - R0016 - Principal - (17.42 SQM)	Office (4)	
B00O - R0017 - Interview - (13.31 SQM)	Office (3)	
B00O - R0018 - Movement - (63.68 SQM)	Not Applicable	Circulation or storage space.
B00O - R0019 - Movement - (84.24 SQM)	Not Applicable	Circulation or storage space.
B00P - R0006 - Movement - (8.82 SQM)	Not Applicable	Circulation or storage space.
B00P - R0007 - Raised Platform - (61.38 SQM)	Not Applicable	Circulation or storage space.
B00P - R0008 - Movement - (24.25 SQM)	Not Applicable	Circulation or storage space.
B00P - R0017 - Movement - (14.38 SQM)	Not Applicable	Circulation or storage space.
B00P - R0019 - Movement - (7.36 SQM)	Not Applicable	Circulation or storage space.
B00P - R0020 - Communal Space - (202.54 SQM)	Student Space (93)	
B00P - R0021 - Movement - (7 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0006 - Reading Area - (229.94 SQM)	Student Space (106)	
B00R - R0002 - Practical Activities - 1hb - (19.9 SQM)	Student Space (9)	
B00R - R0003 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00R - R0005 - Withdrawal Space - 2hb - (11.69 SQM)	Student Space (5)	
B00R - R0006 - Practical Activities - 1hb - (19.9 SQM)	Student Space (9)	
B00R - R0007 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00R - R0009 - Practical Activities - 1hb - (19.9 SQM)	Student Space (9)	
B00R - R0010 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
B00R - R0012 - Withdrawal Space - 2hb - (11.69 SQM)	Student Space (5)	
B00R - R0013 - Practical Activities - 1hb - (19.9 SQM)	Student Space (9)	
B00R - R0014 - Home Base - (59.69 SQM) - Teaching Space: 1	Student Space (27)	
OH 045 17049 - OH 045 17049 - OSHC Hub 45 - ( SQM)	Student Space ( )	
OS 601 13234 - OS 601 13234 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14108 - OS 601 14108 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	