

VENTILATION AUDIT REPORT

SCHOOL:	Annandale North Public School (1042)
AMU REGION:	Sydney
STATE ELECTORATE:	Balmain
LOCAL GOVERNMENT AREA:	Inner West

1042 - Annandale North Public School
Site Plan (10860)



1:467

Printed: 20-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (12.57 SQM)	Office (3)	
B00A - R0004 - Entry Vestibule - (23.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Clerical Office - (10.61 SQM)	Office (2)	
B00A - R0006 - Clerical Office/Workroom - (10.26 SQM)	Office (2)	
B00A - R0012 - Duplicating Workroom - (19.99 SQM)	Office (4)	
B00A - R0014 - Deputy Principal - (13.89 SQM)	Office (3)	
B00A - R0015 - Deputy Principal - (12.68 SQM)	Office (3)	
B00A - R0018 - Movement - (13.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (109.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Home Base - (58.31 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R0036 - Home Base - (54.98 SQM) - Teaching Space: 1	Student Space (25)	
B00A - R0037 - Home Base - (58.23 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1001 - Home Base - (56.56 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1004 - Home Base - (57.42 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1008 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1009 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1013 - Home Base - (62.73 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1018 - Movement - (127.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Practical Activities/Movement - 1hb - (13.08 SQM)	Student Space (6)	
B00B - R0020 - Home Base - (55.59 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0021 - Movement - (32.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Canteen - (30.38 SQM)	Not Applicable	Circulation or storage space.
B00C - M0002 - Movement - (13.54 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (47.66 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0002 - Home Base - (47.43 SQM) - Teaching Space: 1	Student Space (22)	
B00C - R0003 - Home Base - (47.13 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0004 - Home Base - (46.92 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R0008 - Staff Room - (51 SQM)	Office (12)	
B00C - R0010 - Movement - (6.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (50.82 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0016 - Movement - (98.62 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Reading Area - (96.87 SQM)	Student Space (44)	
B00C - R1003 - Reading Area - (17.85 SQM)	Student Space (8)	
B00C - R1005 - Home Base - (47.4 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1006 - Home Base - (47.21 SQM) - Teaching Space: 1	Student Space (21)	
B00C - R1010 - Home Base - (50.63 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1011 - Home Base - (50.75 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R1012 - Movement - (74.1 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Special Programs Room - (31.55 SQM)	Student Space (14)	
B00D - R0004 - Special Programs Room - (31.6 SQM)	Student Space (14)	
B00D - R0013 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (7.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Communal Space - (280.03 SQM)	Student Space (129)	