


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Arcadia Vale Public School (4132)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Lake Macquarie</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

4132 - Arcadia Vale Public School  
Site Plan (10854)



1:1,108

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0005 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (50.89 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0001 - Canteen - (22.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Home Base - (53.81 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0006 - Home Base - (53.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0004 - Reading Area - (76.88 SQM)	● Student Space (35)	
B00E - R0001 - Movement - (20.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Practical Activities - 1hb - (19.87 SQM)	● Student Space (9)	
B00F - R0004 - Home Base - (60.95 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0005 - Withdrawal Space - 1hb - (10.75 SQM)	● Student Space (4)	
B00F - R0006 - Home Base - (61.15 SQM) - Teaching Space: 1	● Student Space (28)	
B00F - R0008 - Practical Activities - 1hb - (19.95 SQM)	● Student Space (9)	
B00G - R0002 - Practical Activities - 1hb - (19.84 SQM)	● Student Space (9)	
B00G - R0004 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0005 - Withdrawal Space - 2hb - (10.67 SQM)	● Student Space (4)	
B00G - R0006 - Home Base - (58.11 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R0008 - Practical Activities - 1hb - (19.84 SQM)	● Student Space (9)	
OS 502 14787 - OS 502 14787 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	