


VENTILATION AUDIT REPORT

SCHOOL:	Armidale Secondary College (8915)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Armidale

8915 - Armidale Secondary College
Site Plan (10102)

























Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Computer Learning Space - (92.02 SQM)	● Student Space (42)	
B001 - R0002 - Darkroom Space - (44.7 SQM)	● Office (11)	
B001 - R0004 - Growing/Breeding - (9.64 SQM)	Not Applicable	Circulation or storage space.
B001 - R0005 - Computer Learning Space - (92.03 SQM)	● Student Space (42)	
B001 - R0007 - Staff Study - (51.15 SQM)	● Office (12)	
B001 - R0015 - Clerical Office - (15.84 SQM)	● Office (3)	
B001 - R0018 - Staff Study - (16.06 SQM)	● Office (4)	
B001 - R0019 - Main Area - (218.48 SQM)	Not Applicable	Circulation or storage space.
B001 - R0030 - General Learning Space - (56.71 SQM)	● Student Space (26)	
B001 - R0033 - Movement - (10.36 SQM)	Not Applicable	Circulation or storage space.
B001 - R0034 - Movement - (10.35 SQM)	Not Applicable	Circulation or storage space.
B001 - R0035 - General Learning Space - (57.25 SQM)	● Student Space (26)	
B001 - R0038 - Laboratory L.S. - (92.04 SQM)	● Student Space (42)	
B001 - R0039 - Preparation - (56.65 SQM)	Not Applicable	Circulation or storage space.
B001 - R0041 - Laboratory L.S. - (90.51 SQM)	● Student Space (41)	
B001 - R0042 - Entry - (13.96 SQM)	Not Applicable	Circulation or storage space.
B001 - R0044 - Main Area - (64.64 SQM)	Not Applicable	Circulation or storage space.
B001 - R0046 - Staff Study - (33.62 SQM)	● Office (8)	
B001 - R0047 - Performance Workspace - (116.49 SQM)	● Student Space (54)	
B001 - R0053 - Movement - (442.42 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Laboratory L.S. - (91.52 SQM)	● Student Space (42)	
B001 - R1002 - Preparation - (48.54 SQM)	Not Applicable	Circulation or storage space.
B001 - R1003 - Growing/Breeding - (10.17 SQM)	Not Applicable	Circulation or storage space.
B001 - R1004 - Laboratory L.S. - (92.31 SQM)	● Student Space (42)	
B001 - R1006 - Staff Study - (51.08 SQM)	● Office (12)	
B001 - R1014 - Workroom - (15.98 SQM)	● Office (3)	
B001 - R1015 - Workroom - (15.93 SQM)	● Office (3)	
B001 - R1016 - Workroom - (16.34 SQM)	● Office (4)	
B001 - R1026 - General Learning Space - (57.17 SQM)	● Student Space (26)	
B001 - R1027 - General Learning Space - (56.13 SQM)	● Student Space (26)	
B001 - R1030 - General Learning Space - (56.14 SQM)	● Student Space (26)	
B001 - R1031 - General Learning Space - (57.18 SQM)	● Student Space (26)	
B001 - R1032 - Laboratory L.S. - (91.67 SQM)	● Student Space (42)	
B001 - R1034 - Preparation - (56.44 SQM)	Not Applicable	Circulation or storage space.
B001 - R1035 - Laboratory L.S. - (92.12 SQM)	● Student Space (42)	
B001 - R1038 - Interview - (33.7 SQM)	● Office (8)	
B001 - R1039 - Movement - (54.3 SQM)	Not Applicable	Circulation or storage space.
B001 - R1040 - Movement - (65.78 SQM)	Not Applicable	Circulation or storage space.
B001 - R1041 - Movement - (253.25 SQM)	Not Applicable	Circulation or storage space.
B001 - R1042 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B001 - R1043 - Movement - (10.02 SQM)	Not Applicable	Circulation or storage space.
B001 - R1044 - Study Space - (173.28 SQM)	Not Applicable	Circulation or storage space.
B001 - R1046 - General Learning Space - (116.46 SQM)	● Student Space (54)	
B002 - R0002 - Canteen - (73.2 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Movement - (23.99 SQM)	Not Applicable	Circulation or storage space.
B002 - R0012 - Movement - (7.02 SQM)	Not Applicable	Circulation or storage space.
B002 - R0014 - Principal - (35.71 SQM)	● Office (8)	
B002 - R0017 - Clerical Office - (17.44 SQM)	● Office (4)	
B002 - R0019 - Public Entry - (22.4 SQM)	Not Applicable	Circulation or storage space.
B002 - R0020 - Clinic - Girls - (12.62 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B002 - R0021 - Clerical Office - (48.88 SQM)	Office (12)	
B002 - R0025 - Movement - (328.78 SQM)	Not Applicable	Circulation or storage space.
B002 - R1001 - Movement - (13.27 SQM)	Not Applicable	Circulation or storage space.
B002 - R1002 - Movement - (14.62 SQM)	Not Applicable	Circulation or storage space.
B002 - R1003 - Ancillary Staff - (27.7 SQM)	Office (6)	
B002 - R1004 - Commonroom - (243.14 SQM)	Office (60)	
B002 - R1006 - Clinic - Girls - (6 SQM)	Office (1)	
B002 - R1014 - Staff Study - (16.32 SQM)	Office (4)	
B002 - R1015 - Clinic - Boys - (12.24 SQM)	Office (3)	
B002 - R1016 - Seminar - (13.8 SQM)	Office (3)	
B002 - R1017 - Seminar - (12.84 SQM)	Office (3)	
B002 - R1020 - Staff Study - (16.15 SQM)	Office (4)	
B002 - R1027 - Duplicating Workroom - (15.13 SQM)	Office (3)	
B002 - R1029 - General Learning Space - (25.83 SQM)	Student Space (11)	
B002 - R1031 - Duplicating Workroom - (28.63 SQM)	Office (7)	
B002 - R1032 - Movement - (90.92 SQM)	Not Applicable	Circulation or storage space.
B003 - M0004 - Music Learning Space - (89.54 SQM)	Student Space (41)	
B003 - M0006 - Music Learning Space - (34.72 SQM)	Student Space (16)	
B003 - M0007 - Staff Study - (77.67 SQM)	Office (19)	
B003 - M0008 - Movement - (10.68 SQM)	Not Applicable	Circulation or storage space.
B003 - M0009 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B003 - R0007 - Staff Study - (9.04 SQM)	Office (2)	
B003 - R0016 - Staff Study - (10.46 SQM)	Office (2)	
B003 - R0023 - Multi-Purpose Space - (108.39 SQM)	Student Space (50)	
B003 - R0024 - Movement - (129.37 SQM)	Not Applicable	Circulation or storage space.
B003 - R0025 - Gymnasium - (460.09 SQM)	Student Space (213)	
B003 - R0029 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
B003 - R0030 - Movement - (159.71 SQM)	Not Applicable	Circulation or storage space.
B003 - R0031 - Fitness Laboratory - (49.85 SQM)	Student Space (23)	
B004 - R0001 - Design L.S. - (66.01 SQM)	Student Space (30)	
B004 - R0003 - Design L.S. - (66.23 SQM)	Student Space (30)	
B004 - R0006 - Food Technology L.S. - (94.32 SQM)	Student Space (43)	
B004 - R0008 - Food Technology L.S. - (93.1 SQM)	Student Space (43)	
B004 - R0013 - Design L.S. - (65.75 SQM)	Student Space (30)	
B004 - R0017 - General Learning Space - (66.4 SQM)	Student Space (30)	
B004 - R0021 - Staff Study - (34.65 SQM)	Office (8)	
B004 - R0035 - Staff Study - (31.96 SQM)	Office (7)	
B004 - R0037 - Movement - (28.13 SQM)	Not Applicable	Circulation or storage space.
B004 - R0038 - Movement - (122.52 SQM)	Not Applicable	Circulation or storage space.
B004 - R0039 - Art Learning Space - (104.44 SQM)	Student Space (48)	
B004 - R0040 - Art Learning Space - (85.39 SQM)	Student Space (39)	
B004 - R0041 - Art Entry/Display - (14.19 SQM)	Not Applicable	Circulation or storage space.
B004 - R0042 - Art Learning Space - (40.48 SQM)	Student Space (18)	
B004 - R0044 - Movement - (66.94 SQM)	Not Applicable	Circulation or storage space.
B004 - R0045 - Workshop - (176.71 SQM)	Student Space (81)	
B004 - R0048 - Welding Area - (8.56 SQM)	Not Applicable	Circulation or storage space.
B004 - R0049 - Welding Area - (11.45 SQM)	Not Applicable	Circulation or storage space.
B004 - R0050 - Welding Area - (6.19 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R0051 - Workshop Area - (152.43 SQM)	 Student Space (70)	
B004 - R0052 - Movement - (17.44 SQM)	Not Applicable	Circulation or storage space.
B004 - R0053 - Food Technology L.S. - (36.51 SQM)	 Student Space (16)	
B004 - R0055 - Preparation - Materials - (11.9 SQM)	Not Applicable	Circulation or storage space.
B004 - R0057 - Movement - (6.56 SQM)	Not Applicable	Circulation or storage space.
B005 - R0008 - Duplicating Workroom - (13.95 SQM)	 Office (3)	
B005 - R0010 - General Learning Space - (51.65 SQM)	 Student Space (23)	
B005 - R0011 - General Learning Space - (51.65 SQM)	 Student Space (23)	
B005 - R0013 - Movement - (10.17 SQM)	Not Applicable	Circulation or storage space.
B005 - R0014 - Staff Study - (25.5 SQM)	 Office (6)	
B005 - R0017 - Serviced Learning Space - (52.82 SQM)	 Student Space (24)	
B005 - R0018 - Movement - (9.6 SQM)	Not Applicable	Circulation or storage space.
B005 - R0019 - General Learning Space - (52.23 SQM)	 Student Space (24)	
B005 - R0020 - General Learning Space - (52.22 SQM)	 Student Space (24)	
B005 - R0023 - General Assistants - (22.29 SQM)	 Office (5)	
B005 - R0026 - Movement - (240.45 SQM)	Not Applicable	Circulation or storage space.
B005 - R0029 - Staff Study - (25.5 SQM)	 Office (6)	
B005 - R1004 - General Learning Space - (52.29 SQM)	 Student Space (24)	
B005 - R1005 - General Learning Space - (52.37 SQM)	 Student Space (24)	
B005 - R1006 - General Learning Space - (52.58 SQM)	 Student Space (24)	
B005 - R1007 - Staff Study - (52.62 SQM)	 Office (13)	
B005 - R1008 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B005 - R1009 - Movement - (9.52 SQM)	Not Applicable	Circulation or storage space.
B005 - R1011 - General Learning Space - (51.5 SQM)	 Student Space (23)	
B005 - R1012 - General Learning Space - (51.5 SQM)	 Student Space (23)	
B005 - R1014 - Seminar - Type 1 - (26.47 SQM)	 Office (6)	
B005 - R1018 - Movement - (241.16 SQM)	Not Applicable	Circulation or storage space.
B006 - R0003 - Movement - (27.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R0001 - Public Reception - (40.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Movement - (93.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (10.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Interview/Meeting - (15.09 SQM)	 Office (3)	
B00A - R0005 - Interview/Office - Type 2 - (12.68 SQM)	 Office (3)	
B00A - R0009 - Interview/Meeting - (14.82 SQM)	 Office (3)	
B00A - R0010 - Interview/Office - Type 1 - (15.32 SQM)	 Office (3)	
B00A - R0012 - Interview/Meeting - (12.15 SQM)	 Office (3)	
B00A - R0013 - Interview/Meeting - (12.26 SQM)	 Office (3)	
B00A - R0020 - Staff Kitchen - (5.22 SQM)	 Office (1)	
B00A - R0021 - Clinic - (12.7 SQM)	 Office (3)	
B00A - R0022 - Interview/Meeting - (12.5 SQM)	 Office (3)	
B00A - R0023 - Interview/Office - Type 2 - (12.7 SQM)	 Office (3)	
B00A - R0024 - Interview/Meeting - (10.83 SQM)	 Office (2)	
B00A - R0025 - Public Reception - (13.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Student Reception - (25.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Administration - Clerical - (58.24 SQM)	 Office (14)	
B00A - R0030 - Principal Office - (22.19 SQM)	 Office (5)	
B00A - R0031 - Deputy Principal Office - (12.26 SQM)	 Office (3)	
B00A - R0032 - Deputy Principal Office - (14.02 SQM)	 Office (3)	
B00A - R0033 - Deputy Principal Office - (15.46 SQM)	 Office (3)	














Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0034 - Administration - Executive - (19.66 SQM)	Office (4)	
B00A - R0035 - Movement - (25.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Main Area - (249.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Senior Study - (60.55 SQM)	Office (15)	
B00A - R1004 - Seminar/Study - (11.71 SQM)	Office (2)	
B00A - R1005 - Seminar/Study - (12 SQM)	Office (3)	
B00A - R1006 - Seminar/Study - (12.08 SQM)	Office (3)	
B00A - R1007 - Seminar/Study - (12.26 SQM)	Office (3)	
B00A - R1008 - Movement - (61.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Computer Learning Space - (60.69 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R1014 - Main Entry - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (41.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R2001 - Staff Lounge - (117.69 SQM)	Office (29)	
B00A - R2005 - Staff Study - (12.9 SQM)	Office (3)	
B00A - R2006 - Staff Study - (12.75 SQM)	Office (3)	
B00A - R2007 - Staff Study - (14.27 SQM)	Office (3)	
B00A - R2015 - Interview/Meeting - (22.88 SQM)	Office (5)	
B00A - R2017 - Movement - (7.35 SQM)	Not Applicable	Circulation or storage space.
B00A - R2018 - Staff Kitchen - (40.22 SQM)	Office (10)	
B00A - R2020 - Staff Lounge - (127.86 SQM)	Office (31)	
B00B - R0004 - Practical Activities - (35.52 SQM)	Student Space (16)	
B00B - R0005 - Special Learning Space - (70.46 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0013 - Staff Kitchen - (34.22 SQM)	Office (8)	
B00B - R0014 - Staff Study - (33.78 SQM)	Office (8)	
B00B - R0015 - General Learning Space - (67.99 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0016 - General Learning Space - (66.16 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0017 - Movement - (101.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Movement - (34.08 SQM)	Not Applicable	Circulation or storage space.
B00B - R0051 - Staff Kitchen - (5.52 SQM)	Office (1)	
B00B - R0053 - Tiered Learning Area - (13.81 SQM)	Student Space (6)	
B00B - R0054 - Outdoor Learning Area - (47.95 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (59.03 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1004 - Shared Learning Space - (44.79 SQM)	Student Space (20)	
B00B - R1005 - General Learning Space - (60.77 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1006 - General Learning Space - (58.1 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1007 - Staff Study - (40.04 SQM)	Office (10)	
B00B - R1008 - General Learning Space - (58.46 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1009 - General Learning Space - (59.86 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1010 - General Learning Space - (59.21 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1011 - Movement - (111.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R1012 - Tiered Learning Area - (12.87 SQM)	Student Space (5)	
B00B - R1015 - Outdoor Learning Area - (52.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R1018 - Staff Kitchen - (10.34 SQM)	Office (2)	
B00C - R0010 - Movement - (129.37 SQM)	Not Applicable	Circulation or storage space.
B00C - R0011 - Shared Learning Space - (58.22 SQM)	Student Space (27)	
B00C - R0013 - Seminar - (32.94 SQM)	Office (8)	
B00C - R0014 - Study Space - (26.94 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - General Learning Space - (60.33 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0016 - Staff Kitchen - (10.04 SQM)	Office (2)	
B00C - R0017 - General Learning Space - (58.16 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0018 - General Learning Space - (59.84 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0019 - General Learning Space - (55.03 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0021 - Staff Study - (38.83 SQM)	Office (9)	
B00C - R0023 - General Learning Space - (55.25 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R0024 - General Learning Space - (60.12 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0025 - General Learning Space - (60.51 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0029 - Tiered Learning Area - (13.6 SQM)	Student Space (6)	
B00C - R1001 - General Learning Space - (61.57 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1002 - General Learning Space - (59.08 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1004 - Movement - (123.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - General Learning Space - (60.16 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1006 - General Learning Space - (60.59 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1007 - General Learning Space - (58.27 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1008 - Staff Study - (39.95 SQM)	Office (9)	
B00C - R1009 - General Learning Space - (58.42 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1010 - General Learning Space - (60.46 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1011 - General Learning Space - (60.07 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R1012 - Seminar - (39.66 SQM)	Office (9)	
B00C - R1014 - Tiered Learning Area - (12.87 SQM)	Student Space (5)	
B00C - R1015 - Shared Learning Space - (52.3 SQM)	Student Space (24)	
B00C - R1016 - Outdoor Learning Area - (52.09 SQM)	Not Applicable	Circulation or storage space.
B00C - R1017 - Staff Kitchen - (10.2 SQM)	Office (2)	
B00D - R0003 - Movement - (128.34 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Practical Activities - (59.53 SQM)	Student Space (27)	
B00D - R0012 - Seminar - (32.68 SQM)	Office (8)	
B00D - R0013 - General Learning Space - (60.48 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0014 - Study Space - (27.02 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Staff Kitchen - (10.3 SQM)	Office (2)	
B00D - R0017 - General Learning Space - (59.36 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0018 - General Learning Space - (58 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0019 - General Learning Space - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0021 - Staff Study - (39.33 SQM)	Office (9)	
B00D - R0023 - General Learning Space - (55.84 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0024 - General Learning Space - (59.02 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R0025 - Computer Learning Space - (57.49 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0052 - Tiered Learning Area - (13.82 SQM)	Student Space (6)	
B00D - R1001 - General Learning Space - (62.35 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1002 - General Learning Space - (58.26 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1004 - Movement - (123.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - General Learning Space - (60.06 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1006 - General Learning Space - (61.11 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1007 - General Learning Space - (58.51 SQM) - Teaching Space: 1	Student Space (27)	
B00D - R1008 - Staff Study - (39.73 SQM)	Office (9)	
B00D - R1009 - General Learning Space - (58.39 SQM) - Teaching Space: 1	Student Space (27)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1010 - General Learning Space - (60.37 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R1011 - General Learning Space - (57.94 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R1013 - Seminar - (33.49 SQM)	Office (8)	
B00D - R1014 - Tiered Learning Area - (12.87 SQM)	Student Space (5)	
B00D - R1015 - Practical Activities - (50.52 SQM)	Student Space (23)	
B00D - R1016 - Outdoor Learning Area - (51.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R1021 - Staff Kitchen - (10.16 SQM)	Office (2)	
B00E - R0001 - Staff Study - (24.05 SQM)	Office (6)	
B00E - R0009 - Movement - (62.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Seminar Space - (18.46 SQM)	Office (4)	
B00E - R0016 - Science Laboratory - (71.46 SQM)	Student Space (33)	
B00E - R0018 - Tiered Learning Area - (25.32 SQM)	Student Space (11)	
B00E - R0019 - General Learning Space - (64.19 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0020 - Movement - (86.42 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Seminar - (18.75 SQM)	Office (4)	
B00F - R0002 - General Learning Space - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0003 - Tiered Learning Area - (13.59 SQM)	Student Space (6)	
B00F - R0005 - General Learning Space - Type 14 - (57.56 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0006 - Outdoor Learning Area - (43.79 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Kitchen - Type 1 - (99.6 SQM)	Student Space (46)	
B00F - R0009 - Movement - (132.36 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Kitchen - Type 2 - (100.9 SQM)	Student Space (46)	
B00F - R0015 - Kitchen - Type 1 - (100.03 SQM)	Student Space (46)	
B00F - R0016 - Staff Study - (78.23 SQM)	Office (19)	
B00F - R0017 - General Learning Space - (64.38 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0018 - General Learning Space - (62.3 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0020 - General Learning Space - (64.38 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0021 - General Learning Space - (64.64 SQM) - Teaching Space: 1	Student Space (29)	
B00F - R0050 - Staff Kitchen - (11.33 SQM)	Office (2)	
B00F - R9003 - Movement - (118.49 SQM)	Not Applicable	Circulation or storage space.
B00F - R9012 - General Learning Space - (65.91 SQM) - Teaching Space: 1	Student Space (30)	
B00F - R9013 - General Learning Space - (68.17 SQM) - Teaching Space: 1	Student Space (31)	
B00F - R9014 - Shared Learning Space - (12.27 SQM)	Student Space (5)	
B00F - R9015 - Multi Media Workshop - (155.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R9018 - General Learning Space - Type 6 - (121.41 SQM) - Teaching Space: 1	Student Space (56)	
B00F - R9019 - General Learning Space - Type 6 - (79.7 SQM) - Teaching Space: 1	Student Space (36)	
B00F - R9020 - Workshop Area - (14.26 SQM)	Student Space (6)	
B00F - R9022 - Movement - (114.61 SQM)	Not Applicable	Circulation or storage space.
B00F - R9026 - General Learning Space - Type 6 - (118.21 SQM) - Teaching Space: 1	Student Space (54)	
B00F - R9029 - Outdoor Workshop - (128.3 SQM)	Not Applicable	Circulation or storage space.
B00F - R9030 - General Learning Space - Type 7 - (105.23 SQM) - Teaching Space: 1	Student Space (48)	
B00F - R9034 - General Learning Space - Type 6 - (108.81 SQM) - Teaching Space: 1	Student Space (50)	
B00F - R9050 - Materials Learning Space - Type 1 - (45.89 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R9051 - Welding Area - (12.99 SQM)	Not Applicable	Circulation or storage space.
B00F - R9052 - Welding Area - (13.26 SQM)	Not Applicable	Circulation or storage space.
B00F - R9055 - Tiered Learning Area - (12.65 SQM)	Student Space (5)	
B00G - R0001 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R8009 - General Learning Space - (70.96 SQM) - Teaching Space: 1	Student Space (32)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R8010 - General Learning Space - (62.86 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R8011 - General Learning Space - Type 10 - (55.51 SQM) - Teaching Space: 0.5	● Student Space (25)	
B00G - R8012 - General Learning Space - Type 10 - (56.61 SQM) - Teaching Space: 0.5	● Student Space (26)	
B00G - R8014 - Preparation - (21.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R8015 - Preparation - (22.11 SQM)	Not Applicable	Circulation or storage space.
B00G - R8016 - Seminar - Type 2 - (18.95 SQM)	● Office (4)	
B00G - R8017 - General Learning Space - Type 10 - (49.14 SQM) - Teaching Space: 0.5	● Student Space (22)	
B00G - R8018 - General Learning Space - (80.38 SQM) - Teaching Space: 1	● Student Space (37)	
B00G - R8019 - General Learning Space - Type 10 - (48.16 SQM) - Teaching Space: 0.5	● Student Space (22)	
B00G - R8020 - Preparation - (47.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R8021 - Preparation - (11.38 SQM)	Not Applicable	Circulation or storage space.
B00G - R8022 - Staff Study - (13.36 SQM)	● Office (3)	
B00G - R8023 - General Learning Space - Type 10 - (56.62 SQM) - Teaching Space: 0.5	● Student Space (26)	
B00G - R8024 - General Learning Space - Type 10 - (56.63 SQM) - Teaching Space: 0.5	● Student Space (26)	
B00G - R8025 - General Learning Space - (65.7 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R8026 - General Learning Space - (71.26 SQM) - Teaching Space: 1	● Student Space (33)	
B00G - R8028 - Movement - (137.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R8029 - General Learning Space - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R8030 - General Learning Space - Type 10 - (68.25 SQM) - Teaching Space: 0.5	● Student Space (31)	
B00G - R8031 - Staff Study - (43 SQM)	● Office (10)	
B00G - R8050 - Shared Learning Space - (59.5 SQM)	● Student Space (27)	
B00G - R8051 - Staff Kitchen - (5.83 SQM)	● Office (1)	
B00G - R8055 - Tiered Learning Area - (12.77 SQM)	● Student Space (5)	
B00G - R9001 - Seminar/Technology Space - (40.3 SQM)	● Office (10)	
B00G - R9002 - Movement - (101.53 SQM)	Not Applicable	Circulation or storage space.
B00G - R9005 - General Learning Space - (65.19 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R9006 - General Learning Space - (56.69 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R9007 - Tiered Learning Area - (10.38 SQM)	● Student Space (4)	
B00G - R9008 - General Learning Space - (56.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R9009 - Staff Study - (40.54 SQM)	● Office (10)	
B00G - R9010 - Shared Learning Space - (60.25 SQM)	● Student Space (27)	
B00G - R9011 - Outdoor Learning Area - (50.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R9012 - General Learning Space - (57.22 SQM) - Teaching Space: 1	● Student Space (26)	
B00G - R9013 - General Learning Space - (59.48 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R9014 - General Learning Space - (58.88 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R9017 - General Learning Space - (65.09 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R9018 - General Learning Space - (69.2 SQM) - Teaching Space: 1	● Student Space (32)	
B00G - R9050 - Staff Kitchen - (10.3 SQM)	● Office (2)	
B00H - M0001 - Multi-Purpose Space - (218.44 SQM)	● Student Space (101)	
B00H - R0001 - Multi-Purpose Space - (1365.02 SQM)	● Student Space (633)	
B00H - R0002 - Movement - (15.31 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (25.4 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Performance Workshop - (19.58 SQM)	● Student Space (9)	
B00I - R0003 - Performance Workshop - (15.59 SQM)	● Student Space (7)	
B00I - R0004 - Seminar - (12.21 SQM)	● Office (3)	
B00I - R0005 - Seminar - (15.58 SQM)	● Office (3)	
B00I - R0006 - Shared Learning Space - (27.47 SQM)	● Student Space (12)	
B00I - R0007 - Performance Workshop - (55.73 SQM)	● Student Space (25)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0008 - General Learning Space - (55.58 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0010 - Movement - (32.67 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Shared Learning Space - (28.19 SQM)	● Student Space (13)	
B00I - R0018 - Student Canteen - (68.6 SQM)	Not Applicable	Circulation or storage space.
B00I - R0021 - Shared Learning Space - (28.19 SQM)	● Student Space (13)	
B00I - R0024 - Movement - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00I - R0025 - Shared Learning Space - (16.57 SQM)	● Student Space (7)	
B00I - R0026 - General Learning Space - (46.57 SQM) - Teaching Space: 1	● Student Space (21)	
B00I - R0027 - General Learning Space - (55.19 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0028 - General Learning Space - (55.13 SQM) - Teaching Space: 1	● Student Space (25)	
B00I - R0029 - Performance Workshop - (99.65 SQM)	● Student Space (46)	
B00I - R0030 - Performance Workshop - (97.77 SQM)	● Student Space (45)	
B00I - R0037 - Performance Workshop - (8.07 SQM)	● Student Space (3)	
B00I - R1001 - Art Learning Space - (228.36 SQM) - Teaching Space: 1	● Student Space (105)	
B00I - R1002 - Art Learning Space - (62.58 SQM) - Teaching Space: 1	● Student Space (29)	
B00I - R1004 - Dark Room - (28.54 SQM)	● Office (7)	
B00I - R1005 - Art Learning Space - (89.99 SQM) - Teaching Space: 1	● Student Space (41)	
B00I - R1010 - Movement - (27.58 SQM)	Not Applicable	Circulation or storage space.
B00I - R1016 - Movement - (17.7 SQM)	Not Applicable	Circulation or storage space.
B00I - R1017 - Staff Kitchen - (16.31 SQM)	● Office (4)	
B00I - R1018 - Art Learning Space - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R1019 - Art Learning Space - (57.6 SQM) - Teaching Space: 1	● Student Space (26)	
B00I - R1020 - Staff Study - (47.55 SQM)	● Office (11)	
B00I - R1021 - Movement - (18.29 SQM)	Not Applicable	Circulation or storage space.
B00I - R1022 - Movement - (12.9 SQM)	Not Applicable	Circulation or storage space.
B00S - R0001 - Growing/Breeding - (22.81 SQM)	Not Applicable	Circulation or storage space.
OS 505 12789 - OS 505 12789 - Admin Staff/Principal/Secure Store - (76 SQM)	● Office (19)	
OS 523 14959 - OS 523 14959 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 523 15141 - OS 523 15141 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 523 15451 - OS 523 15451 - Staff Study With Toilets - (76 SQM)	● Office (19)	
OS 600 11062 - OS 600 11062 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 11127 - OS 600 11127 - Learning Unit - Small - (SQM)	● Student Space ()	
OS 601 19485 - OS 601 19485 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19831 - OS 601 19831 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19832 - OS 601 19832 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 606 19007 - OS 606 19007 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19007 - OS 606 19007 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19007 - OS 606 19007 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19007 - OS 606 19007 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19247 - OS 606 19247 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19327 - OS 606 19327 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19328 - OS 606 19328 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19329 - OS 606 19329 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19330 - OS 606 19330 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 612 12967 - OS 612 12967 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	
OS 616 19376 - OS 616 19376 - Learning Unit - Double Secondary - (133 SQM)	● Student Space (61)	
OS 616 19377 - OS 616 19377 - Learning Unit - Double Secondary - (133 SQM)	● Student Space (61)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 616 19378 - OS 616 19378 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19379 - OS 616 19379 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19380 - OS 616 19380 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19381 - OS 616 19381 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19382 - OS 616 19382 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19383 - OS 616 19383 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19384 - OS 616 19384 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19385 - OS 616 19385 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 616 19386 - OS 616 19386 - Learning Unit - Double Secondary - (133 SQM)	 Student Space (61)	
OS 621 15999 - OS 621 15999 - Learning Unit Single - PWD - (95 SQM)	 Student Space (44)	
OS 700 15950 - OS 700 15950 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 710 10970 - OS 710 10970 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	
OS 750 19375 - OS 750 19375 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 750 19387 - OS 750 19387 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	
OS 780 11753 - OS 780 11753 - Woodwork/Metalwork/Heat Area/Store - (114 SQM)	Not Applicable	Circulation or storage space.