

VENTILATION AUDIT REPORT

SCHOOL:	Artarmon Public School (1061)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Lane Cove
LOCAL GOVERNMENT AREA:	Willoughby

1061 - Artarmon Public School
Site Plan (13539)



1:526

Printed: 14-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Clerical Office - (13.73 SQM)	Office (3)	
B00A - R0003 - Clerical Office - (11.85 SQM)	Office (2)	
B00A - R0005 - Principal - (17.91 SQM)	Office (4)	
B00A - R0022 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Home Base - (51.97 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0025 - Home Base - (53.25 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1003 - Special Programs Room - (16.81 SQM)	Student Space (7)	
B00A - R1004 - Movement - (6.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R1006 - Staff Room Annexe - (10.93 SQM)	Office (2)	
B00A - R1007 - Staff Room Annexe - (10.85 SQM)	Office (2)	
B00A - R1008 - Movement - (17.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Home Base - (73.98 SQM) - Teaching Space: 1	Student Space (34)	
B00A - R1015 - Movement - (85.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Staff Kitchen - (5.02 SQM)	Office (1)	
B00B - R0009 - Home Base - (46.73 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0017 - Movement - (10.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Staff Room Annexe - (10.27 SQM)	Office (2)	
B00B - R0022 - Movement - (29.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0025 - Staff Room - (46.9 SQM)	Office (11)	
B00B - R0026 - Staff Room - (51.94 SQM)	Office (12)	
B00B - R0030 - Movement - (80.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0031 - Duplicating Workroom - (27.38 SQM)	Office (6)	
B00B - R0032 - Clerical Office - (19.22 SQM)	Office (4)	
B00B - R0033 - Movement - (17.71 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Interview - (11.83 SQM)	Office (2)	
B00B - R0035 - Deputy Principal - Type 1 - (11.51 SQM)	Office (2)	
B00B - R0036 - Deputy Principal - Type 2 - (11.83 SQM)	Office (2)	
B00B - R0037 - Principal - (15.77 SQM)	Office (3)	
B00B - R0039 - Sick Bay - (9.78 SQM)	Student Space (4)	
B00B - R1001 - Special Programs Room - (12.97 SQM)	Student Space (6)	
B00B - R1004 - Home Base - (47.4 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1005 - Home Base - (47.3 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R1006 - Home Base - (47.95 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1007 - Home Base - (47.96 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1008 - Movement - (105.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R1009 - Special Programs Room - (27.25 SQM)	Student Space (12)	
B00B - R1012 - Home Base - (55.79 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R1013 - Home Base - (50.72 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0002 - Deputy Principal - (11.43 SQM)	Office (2)	
B00H - R0003 - Movement - (17.14 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Clerical Office - (12.87 SQM)	Office (3)	
B00H - R0007 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Home Base - (46.77 SQM) - Teaching Space: 1	Student Space (21)	
B00H - R0009 - Home Base - (46.77 SQM) - Teaching Space: 1	Student Space (21)	
B00H - R0010 - Home Base - (46.77 SQM) - Teaching Space: 1	Student Space (21)	
B00H - R0011 - Home Base - (47.47 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R0012 - Communal Space - (140.35 SQM)	Student Space (65)	
B00H - R0013 - Movement - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Movement - (6.68 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0019 - Movement - (6.24 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Movement - (17.77 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Staff Room - (15.46 SQM)	Office (3)	
B00H - R1006 - Home Base - (47.77 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R1007 - Home Base - (47.76 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R1008 - Home Base - (47.76 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R1009 - Home Base - (48.15 SQM) - Teaching Space: 1	Student Space (22)	
B00H - R1010 - Special Programs Room - (93.8 SQM)	Student Space (43)	
B00H - R1011 - Special Programs Room - (16.49 SQM)	Student Space (7)	
B00H - R1012 - Movement - (21.38 SQM)	Not Applicable	Circulation or storage space.
B00H - R9002 - Canteen - (45.99 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Reading Area - (225.1 SQM)	Student Space (104)	
B00M - R0004 - Movement - (10.42 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Home Base - (58.27 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1002 - Home Base - (60.16 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1003 - Home Base - (60.16 SQM) - Teaching Space: 1	Student Space (27)	
B00M - R1004 - Practical Activities - 1hb - (20.44 SQM)	Student Space (9)	
B00M - R1005 - Practical Activities - 1hb - (17.68 SQM)	Student Space (8)	
B00M - R1006 - Practical Activities - 1hb - (18.91 SQM)	Student Space (8)	
B00M - R1007 - Withdrawal Space - 2hb - (11.64 SQM)	Student Space (5)	
B00M - R1008 - Withdrawal Space - 1hb - (9.14 SQM)	Student Space (4)	
B00N - R0002 - Home Base - (63.58 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R0003 - Practical Activities - 1hb - (6.9 SQM)	Student Space (3)	
B00N - R0005 - Withdrawal Space - 2hb - (11.16 SQM)	Student Space (5)	
B00N - R0007 - Home Base - (63.28 SQM) - Teaching Space: 1	Student Space (29)	
B00N - R0008 - Practical Activities - (6.9 SQM)	Student Space (3)	
B00N - R1002 - Home Base - (65.49 SQM) - Teaching Space: 1	Student Space (30)	
B00N - R1003 - Practical Activities - (6.74 SQM)	Student Space (3)	
B00N - R1005 - Withdrawal Space - 2hb - (11.39 SQM)	Student Space (5)	
B00N - R1007 - Home Base/Practical Activities - (64.77 SQM) - Teaching Space: 1	Student Space (30)	
B00N - R1008 - Practical Activities - (7 SQM)	Student Space (3)	
B00S - R0002 - Movement - (40.22 SQM)	Not Applicable	Circulation or storage space.
B00S - R0003 - Reading Area - (116.99 SQM)	Student Space (54)	
B00S - R0006 - Special Programs Room - (24.02 SQM)	Student Space (11)	
B00S - R0007 - Special Programs Room - (24.02 SQM)	Student Space (11)	
B00S - R0008 - Communal Space - (58.06 SQM)	Student Space (26)	
B00S - R0015 - Home Base - (49.99 SQM) - Teaching Space: 1	Student Space (23)	
B00S - R0017 - Home Base - (50.24 SQM) - Teaching Space: 1	Student Space (23)	
B00S - R0018 - Home Base - (49.47 SQM) - Teaching Space: 1	Student Space (22)	
B00S - R0020 - Withdrawal Space - 2hb - (9.57 SQM)	Student Space (4)	
B00S - R0021 - Movement - (14.12 SQM)	Not Applicable	Circulation or storage space.
B00S - R0022 - Communal Space - (15.37 SQM)	Student Space (7)	
B00S - R0023 - Practical Activities - 4hb - (28.21 SQM)	Student Space (13)	
B00S - R0024 - Home Base - (49.23 SQM) - Teaching Space: 1	Student Space (22)	
B00S - R0025 - Home Base - (49.73 SQM) - Teaching Space: 1	Student Space (23)	
B00S - R0027 - Staff Kitchen - (6.31 SQM)	Office (1)	
B00S - R0028 - Practical Activities - M - 1hb - (13.43 SQM)	Student Space (6)	
B00S - R0029 - Reading Area - (60.98 SQM)	Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R0031 - Movement - (72.82 SQM)	Not Applicable	Circulation or storage space.
B00S - R1002 - Movement - (105.83 SQM)	Not Applicable	Circulation or storage space.
B00S - R1003 - Practical Activities - (60.46 SQM)	● Student Space (28)	
B00S - R1004 - Communal Space - (76.04 SQM)	● Student Space (35)	
B00S - R1005 - Home Base - (49.24 SQM) - Teaching Space: 1	● Student Space (22)	
B00S - R1006 - Home Base - (49.58 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R1007 - Home Base - (49.58 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R1008 - Withdrawal Space - 2hb - (15.12 SQM)	● Student Space (7)	
B00S - R1015 - Home Base - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R1017 - Home Base - (50.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R1018 - Home Base - (49.17 SQM) - Teaching Space: 1	● Student Space (22)	
B00S - R1019 - Communal Space - (63.89 SQM)	● Student Space (29)	
B00S - R1020 - Withdrawal Space - 2hb - (13.34 SQM)	● Student Space (6)	
B00S - R1021 - Movement - (9.92 SQM)	Not Applicable	Circulation or storage space.
B00S - R1022 - Communal Space - (21.17 SQM)	● Student Space (9)	
B00S - R1023 - Practical Activities - (32.74 SQM)	● Student Space (15)	
B00S - R1025 - Home Base - (49.73 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R1026 - Home Base - (49.29 SQM) - Teaching Space: 1	● Student Space (22)	
B00S - R2002 - Movement - (110.34 SQM)	Not Applicable	Circulation or storage space.
B00S - R2003 - Practical Activities - (59.68 SQM)	● Student Space (27)	
B00S - R2004 - Communal Space - (74.86 SQM)	● Student Space (34)	
B00S - R2005 - Home Base - (49.41 SQM) - Teaching Space: 1	● Student Space (22)	
B00S - R2006 - Home Base - (50.27 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R2007 - Home Base - (50.1 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R2008 - Withdrawal Space - 2hb - (14.49 SQM)	● Student Space (6)	
B00S - R2015 - Home Base - (50.04 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R2017 - Home Base - (50.22 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R2018 - Home Base - (49 SQM) - Teaching Space: 1	● Student Space (22)	
B00S - R2019 - Movement - (9.92 SQM)	Not Applicable	Circulation or storage space.
B00S - R2020 - Withdrawal Space - 2hb - (12.78 SQM)	● Student Space (5)	
B00S - R2022 - Communal Space - (62.56 SQM)	● Student Space (29)	
B00S - R2023 - Practical Activities - (33.8 SQM)	● Student Space (15)	
B00S - R2024 - Home Base - (49.62 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R2025 - Home Base - (49.81 SQM) - Teaching Space: 1	● Student Space (23)	
B00S - R2034 - Communal Space - (21.01 SQM)	● Student Space (9)	
B00T - R0001 - Communal Space - (58.1 SQM)	● Student Space (26)	
B00T - R0002 - Movement - (56.3 SQM)	Not Applicable	Circulation or storage space.
B00T - R0003 - Canteen - (18.77 SQM)	Not Applicable	Circulation or storage space.
B00T - R9001 - Communal Space - (228.44 SQM)	● Student Space (105)	
B00T - R9007 - Movement - (9.56 SQM)	Not Applicable	Circulation or storage space.
B00T - R9011 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00T - R9013 - Movement - (19.52 SQM)	Not Applicable	Circulation or storage space.
B00T - R9014 - Movement - (42.42 SQM)	Not Applicable	Circulation or storage space.
B00T - R9018 - Tiered Learning Space - (89.78 SQM)	● Student Space (41)	