

# VENTILATION AUDIT REPORT














<b>SCHOOL:</b>	<b>Ashcroft Public School (4344)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Liverpool</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (14.12 SQM)	Office (3)	
B00A - R0002 - Clerical Office - (14.12 SQM)	Office (3)	
B00A - R0004 - Entry Vestibule - (15.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Principal - (21.36 SQM)	Office (5)	
B00A - R0006 - Movement - (27.83 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Staff Room Annexe - (9.01 SQM)	Office (2)	
B00A - R0016 - Home Base - (56.59 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0019 - Movement - (7.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Duplicating Workroom - (45.67 SQM)	Office (11)	
B00A - R0025 - Staff Room Annexe - (10.5 SQM)	Office (2)	
B00A - R0026 - Home Base - (56.59 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0029 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Home Base - (57.22 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R0002 - Staff Room Annexe - (30.79 SQM)	Office (7)	
B00B - R0007 - Staff Room - (56.47 SQM)	Office (14)	
B00B - R0010 - Movement - (7.05 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Communal Space - (103.81 SQM)	Student Space (48)	
B00B - R0016 - Raised Platform - (9.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Home Base - (56.78 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0005 - Movement - (16.51 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Home Base - (56.62 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0015 - Home Base - (56.62 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0018 - Movement - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Home Base - (56.77 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0001 - Home Base - (57.53 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0009 - Home Base - (56.75 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0010 - Home Base - (56.75 SQM) - Teaching Space: 1	Student Space (26)	
B00D - R0018 - Home Base - (57.06 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0004 - Movement - (8.11 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Seminar/Study - (39.94 SQM)	Office (9)	
B00F - R0006 - Movement - (21.37 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Movement - (6.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Reading Area - (86.14 SQM)	Student Space (39)	
B00G - R0001 - Movement - (17.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (52.2 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0003 - Home Base - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0002 - Home Base - (51.03 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0003 - Home Base - (50.84 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R0005 - Movement - (7.92 SQM)	Not Applicable	Circulation or storage space.
B00I - R0003 - Canteen - (31.35 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (15.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Home Base - (57.28 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0004 - Movement - (5.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R0010 - Home Base - (57.51 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0011 - Home Base - (57.36 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0013 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0019 - Movement - (41.57 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Interview - (15.19 SQM)	 Office (3)	
B00J - R0025 - Staff Room Annexe - (18.58 SQM)	 Office (4)	
B00K - R0005 - Home Base - (85.89 SQM) - Teaching Space: 1	 Student Space (39)	
B00K - R0006 - Home Base - (56.73 SQM) - Teaching Space: 1	 Student Space (26)	
B00K - R0008 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00K - R0014 - Home Base - (56.73 SQM) - Teaching Space: 1	 Student Space (26)	
B00K - R0015 - Home Base - (81.96 SQM) - Teaching Space: 1	 Student Space (38)	
B00K - R0016 - Movement - (6.35 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Outdoor Learning Area - (67.37 SQM)	Not Applicable	Circulation or storage space.
B00K - R0021 - Outdoor Learning Area - (67.37 SQM)	Not Applicable	Circulation or storage space.
B00K - R0022 - Movement - (95.47 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Home Base - (56.94 SQM) - Teaching Space: 1	 Student Space (26)	
B00L - R0004 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Home Base - (56.47 SQM) - Teaching Space: 1	 Student Space (26)	
B00L - R0010 - Home Base - (56.47 SQM) - Teaching Space: 1	 Student Space (26)	
B00L - R0013 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R0018 - Home Base - (56.94 SQM) - Teaching Space: 1	 Student Space (26)	
B00O - R0006 - Movement - (6.62 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Entry Vestibule - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00P - R0005 - Home Base - Pre - (68.94 SQM) - Teaching Space: 1	 Student Space (31)	
B00P - R0006 - Practical Activities - Pre - (46.31 SQM)	 Student Space (21)	
B00P - R0015 - Movement - (69.32 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0001 - Communal Space - (145.26 SQM)	 Student Space (67)	
B00Q - R0002 - Raised Platform - (58.8 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0017 - Movement - (12.96 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0018 - Movement - (13.73 SQM)	Not Applicable	Circulation or storage space.