


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Ashfield Public School (1065)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Summer Hill</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Inner West</b>

1065 - Ashfield Public School  
Site Plan (12292)



## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (18.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Room - (69.29 SQM)	Office (17)	
B00A - R0010 - Principal - (19.38 SQM)	Office (4)	
B00A - R0011 - Interview - (12.64 SQM)	Office (3)	
B00A - R0016 - Clerical Office - (13.02 SQM)	Office (3)	
B00A - R0017 - Sick Bay - (8.46 SQM)	Student Space (3)	
B00A - R0018 - Deputy Principal - (13.06 SQM)	Office (3)	
B00A - R0023 - Duplicating Workroom - (13.97 SQM)	Office (3)	
B00A - R0027 - Entry Vestibule - (10.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (37.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Entry Vestibule - (11.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Seminar/Study - (11.85 SQM)	Office (2)	
B00A - R1010 - Seminar/Study - (12.05 SQM)	Office (3)	
B00A - R1011 - Reading Area - (53.17 SQM)	Student Space (24)	
B00A - R1013 - Reading Area - (175.27 SQM)	Student Space (81)	
B00A - R2002 - Movement - (23.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R2013 - Movement - (16.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R2016 - Home Base - (51.28 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R2017 - Practical Activities - 1hb - (18.25 SQM)	Student Space (8)	
B00A - R2018 - Home Base - (51.41 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R2019 - Practical Activities - 1hb - (18.3 SQM)	Student Space (8)	
B00A - R2020 - Practical Activities - 1hb - (18.4 SQM)	Student Space (8)	
B00A - R2021 - Home Base - (51.39 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R2022 - Practical Activities - 1hb - (18.37 SQM)	Student Space (8)	
B00A - R2023 - Home Base - (51.32 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0001 - Withdrawal Space - 1hb - (18.81 SQM)	Student Space (8)	
B00B - R0002 - Home Base - (47.79 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R0004 - Home Base - (45.58 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0005 - Home Base - (61.54 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0007 - Home Base - (47.2 SQM) - Teaching Space: 1	Student Space (21)	
B00B - R0008 - Movement - (28.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (18.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Movement - (52.44 SQM)	Not Applicable	Circulation or storage space.
B00B - R0019 - Practical Activities - (12.86 SQM)	Student Space (5)	
B00B - R0021 - Withdrawal Space - 2hb - (11.94 SQM)	Student Space (5)	
B00B - R0022 - Practical Activities - (15.01 SQM)	Student Space (6)	
B00B - R0023 - Practical Activities - (18.5 SQM)	Student Space (8)	
B00B - R0025 - Withdrawal Space - 2hb - (10.98 SQM)	Student Space (5)	
B00B - R0026 - Practical Activities - (17.21 SQM)	Student Space (7)	
B00B - R1003 - Home Base - (49.51 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1005 - Home Base - (48.12 SQM) - Teaching Space: 1	Student Space (22)	
B00B - R1008 - Home Base - (49.67 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1016 - Movement - (96.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R1019 - Home Base - (61.38 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1021 - Practical Activities - (10.83 SQM)	Student Space (5)	
B00B - R1023 - Withdrawal Space - 2hb - (12.1 SQM)	Student Space (5)	
B00B - R1024 - Practical Activities - (15.49 SQM)	Student Space (7)	
B00B - R1026 - Withdrawal Space - 1hb - (11.61 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1027 - Special Programs Room - Type 1 - (39.25 SQM)	● Student Space (18)	
B00C - R0016 - Home Base - (87.07 SQM) - Teaching Space: 1	● Student Space (40)	
B00C - R0021 - Home Base - (56.8 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0024 - Home Base - (57.19 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0027 - Home Base - (57.2 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0031 - Home Base - M - (56.96 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0035 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0059 - Movement - (78.29 SQM)	Not Applicable	Circulation or storage space.
B00C - R0070 - Special Programs Room - (16.05 SQM)	● Student Space (7)	
B00C - R0071 - Home Base - (93.77 SQM) - Teaching Space: 1	● Student Space (43)	
B00C - R0072 - Practical Activities - 1hb - (7.53 SQM)	● Student Space (3)	
B00C - R0073 - Practical Activities - 1hb - (8.29 SQM)	● Student Space (3)	
B00F - R0003 - Communal Space - (148.8 SQM)	● Student Space (69)	
B00F - R0005 - Canteen - (38.73 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Movement - (22.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0011 - Raised Platform - (39.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Movement - (12.58 SQM)	Not Applicable	Circulation or storage space.
OS 600 10357 - OS 600 10357 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 18348 - OS 600 18348 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19614 - OS 600 19614 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 612 13665 - OS 612 13665 - Learning Unit - Double With Resource - (152 SQM)	● Student Space (70)	